



Test Report issued under the responsibility of:

**LYNS-TCI**

## TEST REPORT

### DIN VDE V 0124-100

#### Test requirements for generation units to be connected and operated parallel with the low voltage distribution networks

Report Number ..... : **LS2A25082503EGDE01**

Total pages..... : 231

Tested by (name + signature)..... : Biscuit Ren / Test engineer

Approved by (name + signature) ..... : Lukes Lin / Project Manager

Date of issue ..... : 2025-11-26

Applicant's name ..... : Marstek energy Co., Ltd.

Address ..... : 1-4F, BLDG#9, 1/F, BLDG#5, West Industrial Park, South of the Intersection of Ma'anshan Tunnel and Zhangshe Avenue, Xiangxi High-tech Zone, Hunan Province, China

Manufacturer ..... : Hamedata Technology Co., Limited

Address ..... : 1-3F & 6-8F, BLDG#A, Changfang Industrial Park, No.2 Guihua 5th Road, Pingshan District, Shenzhen, Guangdong, China

Testing laboratory name ..... : Lyns-tci Technology Guangdong Co., Ltd.

Address ..... : Room 1201, Unit 2, Building 18, No. 7, Science and Technology Boulevard, Houjie Town, Dongguan City, Guangdong, 523960 P.R.C

Testing Location ..... : As above

Address ..... : As above

Test specification:

Standard ..... : VDE AR-N 4105:2018-11  
DIN VDE V 0124-100:2020-06

Test Report Form No..... : VDE0124-100 VER.1.1

This report is for your exclusive use. Any copying or replication of this report to or for any other person or entity, or use of our name or trademark, is permitted only with our prior written permission. This report sets forth our findings solely with respect to the test samples identified herein. Our report includes all of the tests requested by you and the results thereof based upon the information that you provided to us. The report would be invalid without specific stamp of test institute and the signatures of tester and approver.

Issued by: Lyns-tci Technology Guangdong Co., Ltd.

Address: Room 1201, Unit 2, Building 18, No. 7, Science and Technology Boulevard, Houjie Town, Dongguan City, Guangdong, 523960 P.R.C

Tel: +86 769 85598986

E-Mail: service-hc@lyns-tci.com

Web: www.lyns-tci.com

Product name .....	MARSTEK VENUS-E (Energy Storage System)	
Trade Mark .....	<b>MARSTEK</b>	
Factory's name .....	Hamedata Technology Co., Limited	
Factory address .....	1-3F & 6-8F, BLDG#A, Changfang Industrial Park, No.2 Guihua 5th Road, Pingshan District, Shenzhen, Guangdong, China	

Model/Type reference .....	MST-BIE5-2500	MST-BIE5-0800
Ratings:		
Battery Model .....	GSP50160119F	
Battery Type .....	LiFePO4	
Battery voltage range [V].....	40-60	
Battery Rated Voltage [V].....	51,2	
Battery Energy[V] .....	5,12kWh	
Maximum charge/discharge current [A] .....	60/60	
Firmware version of the BMS .....	106	
Rated Input AC voltage [V].....	230Vac, L+N+PE, 50Hz	
Rated Input AC Power [kVA] .....	2,5	
Rated Input AC Current [A] .....	10,9	
Max. apparent power [kVA] .....	2,5	
Max. current [A] .....	10,9	
Rated output AC voltage [V].....	230Vac, L+N+PE ,50Hz	
AC Output Rated Current [A] .....	10,9	3,48
Max AC Output Current [A] .....	10,9	3,48
Rated active power $P_{rE}$ [kW].....	2,5	0,8
Maximum active power $P_{E_{max}}$ [kW]....	2,5	0,8
Rated apparent power $S_{rE}$ [kVA] .....	2,5	0,8
Maximum apparent power $S_{E_{max}}$ [kVA] .....	2,5	0,8
Software version.....	113	

## Contents

Revision history of test report .....	4
Copy of marking plate .....	5
General remarks - documentation .....	6
General remarks for testing .....	7
General product information .....	8
General product information .....	10
Assessment .....	11
Annex 1 – Test Results .....	14
<b>5.2 Evidence of permissible network perturbations .....</b>	<b>15</b>
5.2.1 General .....	15
5.2.2 Rapid voltage changes .....	16
5.2.3 Flicker .....	18
5.2.4 Harmonics and interharmonics .....	20
5.2.4.1 a) Harmonics test.....	20
5.2.4.1 b) Test Harmonics DIN EN 61000-4-7 ( $\geq 75$ A per Phase) .....	24
5.2.5 Commutation .....	28
5.2.6 Feed in of DC current .....	29
<b>5.3 Evidence of symmetry behaviour of inverters.....</b>	<b>30</b>
5.3.1 General .....	30
5.3.2.1 Calculation of asymmetry .....	31
<b>5.4 Evidence of the behaviour of the generating unit on the network .....</b>	<b>33</b>
5.4.1 General .....	33
5.4.2 Measurement of the active power and reactive power range.....	34
5.4.3 Measurement of setting accuracy.....	35
5.4.3.4 Measurement of the power gradient.....	36
5.4.3.5 Measurement priority interfaces / energy management system.....	38
5.4.4 Active power feed-in for PGU's at overfrequency .....	40
5.4.5 Active power feed-in of Storage systems for overfrequency .....	44
5.4.6 Active power feed-in for PGUs at underfrequency .....	48
5.4.7 Active power feed-in for Storage systems at underfrequency .....	53
5.4.8 Static voltage stability / reactive power supply .....	57
5.4.8.3 Test of the displacement factor/active power characteristic curve $\cos \varphi (P)$ .....	61
5.4.8.4 Test the reactive power-voltage characteristic $Q(U)$ .....	68
<b>5.5 Testing of NS protection .....</b>	<b>72</b>
5.5.2 NS protection .....	72
5.5.3 Central NS-protection .....	79
5.5.4 Integrated NS protection.....	80
5.5.6 Interface switch.....	81
5.5.7.2 Check of setting values.....	87
5.5.7.3 Wiring check .....	89
5.5.7.4 Voltage and frequency control.....	96
5.5.7.5 Reporting NS protection .....	98
5.5.9 Constructional characteristics of NS protection.....	99
5.5.10 Islanding detection.....	100
<b>5.7 Evidence of <math>P_{AV,E}</math>-Control.....</b>	<b>111</b>
5.7.2.1 Test of control the dynamic.....	112
5.7.2.2 Test disconnection function .....	113
<b>5.8 Evidence dynamic grid support .....</b>	<b>114</b>
Annex 2 – Pictures of the unit .....	225
Annex 3 – Test equipment list .....	230

**Revision history of test report**

<b>Issued Date</b>	<b>Description</b>	<b>Report Number</b>
2025-11-26	Initial issue.	LS2A25082503EGDE01

Copy of marking plate

**MARSTEK VENUS-E**

<b>Model:</b> MST-BIE5-0800	
<b>Battery Energy:</b> 5120Wh	
<b>Type:</b> LiFePO4	
<b>Battery</b>	<b>Depth of Discharge:</b> 90%
	<b>Nominal Voltage:</b> 51.2V
	<b>Capacity:</b> 100Ah
	<b>Design code:</b> IFpP52/61/20/[IP16]M/-30+60/90
<b>Range of Input/Output Operating Voltage:</b> 40-60Vdc	
<b>Max. Charge/Discharge Current:</b> 60Adc	
<b>Rated Power:</b> 0.8kVA	
<b>Rated Current:</b> 3.48Aac	
<b>Rated Voltage:</b> 230Vac	
<b>Rated Frequency:</b> 50HZ	
<b>Grid (Input/Output)</b>	<b>AC Input max. apparent power:</b> 2.5kVA
	<b>AC Output max. apparent power:</b> 0.8kVA
	<b>AC Input max. current:</b> 10.9Aac
	<b>AC Output max. current:</b> 3.48Aac
	<b>Power Factor:</b> >0.8(Default)
	<b>Max. current:</b> 10.9Aac
<b>Rated Output Power:</b> 0.8kVA	
<b>Rated Output Current:</b> 3.48Aac	
<b>Rated Output Voltage:</b> 230Vac	
<b>Rated Frequency:</b> 50HZ	
<b>Backup</b>	<b>AC Output max. apparent power:</b> 3.5kVA
	<b>AC Output max. current:</b> 15.2Aac
	<b>Power Factor:</b> >0.8(Default)
	<b>Max. Output Current:</b> 11.99Aac
<b>Protective Class:</b> I	
<b>Over Voltage Category:</b> DC II/ACIII	
<b>Operating Ambient Temp.:</b> -20 - 55°C	
<b>System</b>	<b>Ingress Protection:</b> IP65
	<b>Inverter topology:</b> Isolated
	<b>Size(L*W*H):</b> 480*153*624mm
	<b>Weight:</b> 60kg
	<b>Production Date:</b> 2025/7/15
<b>S/N:</b> HVE301252 201231	

Marstek Energy Co., Limited  
 Web: [www.marstekenergy.com](http://www.marstekenergy.com)  
 Mail: [info@marstekenergy.com](mailto:info@marstekenergy.com)

**Importer:**  
 Marstek Energy GmbH  
 c/o Rhine Riverside Commerce & Consulting GmbH  
 Gneisenaustraße 8, 40477 Düsseldorf Deutschland

Made in China

**MARSTEK VENUS-E**

<b>Model:</b> MST-BIE5-2500	
<b>Battery Energy:</b> 5120Wh	
<b>Type:</b> LiFePO4	
<b>Battery</b>	<b>Depth of Discharge:</b> 90%
	<b>Nominal Voltage:</b> 51.2V
	<b>Capacity:</b> 100Ah
	<b>Design code:</b> IFpP52/61/20/[IP16]M/-30+60/90
<b>Range of Input/Output Operating Voltage:</b> 40-60Vdc	
<b>Max. Charge/Discharge Current:</b> 60Adc	
<b>Rated Power:</b> 2.5kVA	
<b>Rated Current:</b> 10.9Aac	
<b>Rated Voltage:</b> 230Vac	
<b>Rated Frequency:</b> 50HZ	
<b>Grid (Input/Output)</b>	<b>AC Input max. apparent power:</b> 2.5kVA
	<b>AC Output max. apparent power:</b> 2.5kVA
	<b>AC Input max. current:</b> 10.9Aac
	<b>AC Output max. current:</b> 10.9Aac
	<b>Power Factor:</b> >0.8(Default)
	<b>Max. current:</b> 10.9Aac
<b>Rated Output Power:</b> 2.5kVA	
<b>Rated Output Current:</b> 10.9Aac	
<b>Rated Output Voltage:</b> 230Vac	
<b>Rated Frequency:</b> 50HZ	
<b>Backup</b>	<b>AC Output max. apparent power:</b> 3.5kVA
	<b>AC Output max. current:</b> 15.2Aac
	<b>Power Factor:</b> >0.8(Default)
	<b>Max. Output Current:</b> 11.99Aac
<b>Protective Class:</b> I	
<b>Over Voltage Category:</b> DC II/ACIII	
<b>Operating Ambient Temp.:</b> -20 - 55°C	
<b>System</b>	<b>Ingress Protection:</b> IP65
	<b>Inverter topology:</b> Isolated
	<b>Size(L*W*H):</b> 480*153*624mm
	<b>Weight:</b> 60kg
	<b>Production Date:</b> 2025/7/15
<b>S/N:</b> HVE301252 201231	

Marstek Energy Co., Limited  
 Web: [www.marstekenergy.com](http://www.marstekenergy.com)  
 Mail: [info@marstekenergy.com](mailto:info@marstekenergy.com)

**Importer:**  
 Marstek Energy GmbH  
 c/o Rhine Riverside Commerce & Consulting GmbH  
 Gneisenaustraße 8, 40477 Düsseldorf Deutschland

Made in China

Note:

The marking plates shown above may be only a draft. The use of certification marks on products must be approved by the respective NCBs to which these marks belong. The marking plate is attached to the side surface or the back of the enclosure and is visible after installation.

General remarks - documentation

Possible test case verdicts

Test case does not apply to the test object ....: N/A  
 Test case is not rated .....: N/R  
 Test item does meet the requirement .....: P (Pass)  
 Test item does not meet the requirement ....: F (Fail)

Testing

Date of receipt of test items .....: 2025-09-03  
 Date(s) of performance of tests .....: 2025-09-03 to 2025-11-23


General remarks:

The test result presented in this report relate only to the object(s) tested. This report shall not be reproduced in part or in full without the written approval of the issuing testing laboratory.  
 "(see Annex #)" refers to additional information appended to the report.  
 "(see appended table)" refers to a table appended to the report.  
 Throughout this report a comma / point is used as the decimal separator.  
 Conformity statements are decided in accordance with ILAC-G8:09/2019 Binary Statement for Simple Acceptance Rule, unless otherwise normatively specified or contractually agreed.

Direction definition of P and Q:

in this test report, the regarded system of the voltage and current vectors is the active sign convention system:

- If the inverter feeds to the grid the active power is measured with positive sign.
- If the inverter injects reactive power / current with leading power factor the reactive power / current is marked "leading" or "inductive" (under-excited) or has a negative sign.
- If the inverter injects reactive power / current with lagging power factor the reactive power / current is marked "lagging" or "capacitive" (over-excited) or has a positive sign.



General remarks for testing

**Test setup:**

For the testing 2 test setups were used:

- a) *Test setup 1:* used for tests except islanding prevention testing.




Figure 1 – Test setup 1

- b) *Test setup 2:* Basic test configuration for islanding detection function





Figure 2 – Test circuit for islanding detection function in a power conditioner (inverter) from IEC 62116:2014

**General product information**

Equipment mobility ..... : Permanent connection  
Operating condition ..... : Continuous  
Class of equipment..... : Class I  
Protection against ingress of water ..... : IP65  
Mass of equipment [kg] ..... : Approximately 60kg

**General product information**

The **MST-BIE5-0800** and **MST-BIE5-2500** is a single-phase storage inverter. The inverter is designed to convert the direct current power generated from the battery into grid-compatible AC current and to feed the AC current into the utility grid. (See Figure 3)



**Figure 3 – Scheme of an installation**

**The product was tested on the EUT MST-BIE5-2500.**

Hardware Version: V34

Software Version: 113

**Model Difference:**

The units in the series are identical hardware platform. The implemented control and firmware are identical in all units. There is no difference regarding AC behavior between the PGU-types apart from the power rating deviation and current limitation of each unit.

The units in the product series:

- sharing the same control electronics.
- with the same firmware.
- with the same construction solutions including the power part.
- with the same number of phases.
- with the same power electronics, filters and transducers designed for different sizes of current ratings.

General product information

**Description of the power circuit (Figure 4):**

This inverter converts the DC power of the battery into AC power, with single-phase output and both input and output have varistor grounding protection. It adopts an isolation transformer topology.

The control system adopts a redundant master-slave DSP architecture: U28 is the main DSP responsible for relay control, bus voltage, grid voltage and frequency, AC current (including DC injection) measurement, and calibration of current sensors before startup; U9 is a DSP that independently monitors the voltage and frequency of the power grid. It can disconnect relays separately and communicate with the main DSP for mutual inspection, improving protection reliability.

The output part achieves dual protection through isolation transformers and relays: even if a single relay fails, the isolation transformer can still maintain insulation and disconnect. When the system detects an abnormality in the relay, it will sound an alarm and display an error code. All relays undergo self inspection before starting up.

The current signal is collected by sensors, and both AC and DC components are sent to the main DSP for analysis. The battery voltage and temperature are monitored by BMS and interact with the control board through CAN to manage charging and discharging.

**Working mode:**

**Grid connected mode:** Close relay K1, which can charge the battery or feed power to the grid, with a rated power of 2500 W/800W;

**Off grid mode:** Close relay K2 and supply power to the flyback load through the Backup interface, with a rated power of 2500 W.

In the event of a malfunction, the master-slave DSP collaboratively triggers protection, and if necessary, a relay or isolation transformer is used for secondary disconnection to ensure basic insulation between the battery and the grid.




Figure 4 – Block diagram

**Assessment**

Clause/§	Requirement	Verdict
<b>5.2</b>	<b>Evidence of permissible network perturbations</b>	
5.2.1	General	P
5.2.2	Rapid voltage changes	P
5.2.3	Flicker	P
5.2.4	Harmonics and interharmonics	P
5.2.4.1 a)	Test Harmonics DIN EN 61000-3-2 ( $\leq 16$ A per Phase)	P
5.2.4.1 a)	Test Harmonics DIN EN 61000-3-12 ( $\geq 16$ A and $\leq 75$ A per Phase)	N/A
5.2.4.1 b)	Test Harmonics and interharmonics DIN EN 61000-4-7 ( $\geq 75$ A per Phase)	P
5.2.5	Commutation	N/A
5.2.6	Feed in of DC current	P
<b>5.3</b>	<b>Evidence of symmetry behaviour of inverters</b>	
5.3.1	General	N/A
5.3.2.1	Calculation of the asymmetry of three-phase inverters	N/A
5.3.2.2.1	Failure of single inverter modules	N/A
5.3.2.2.2	Power drop of single inverter modules	N/A
5.3.2.3.2	Symmetrical operation with a symmetry device	N/A
<b>5.4</b>	<b>Evidence of the behaviour of the generating unit on the network</b>	
5.4.1	General	P
5.4.2	Measurement of the active and reactive power range	P
5.4.3.3	Measurement of setting accuracy	P
5.4.3.4	Measurement of the power gradient	P
5.4.3.5	Measurement Priority Interfaces / Energy Management	P
5.4.4	Active power feed-in for PGUs at over-frequency	N/A
5.4.5	Active power feed-in of Storage systems for over-frequency	P
5.4.6	Active power feed-in for PGUs at underfrequency	N/A
5.4.7	Active power feed-in for storage systems at underfrequency	P
5.4.8	Static voltage stability / reactive power supply	P
5.4.8.2	Tests of the Reactive power / $\cos \phi$ setting accuracy	P
	The regulating and control behaviour of the reactive power	P
5.4.8.3	Test of the displacement factor/active power characteristic curve $\cos \phi$ (P)	P
	Test 1) for conducted PGUs - Accuracy (characteristic)	P
	Test 2) for conducted PGUs - dynamics	N/A
	Test 3) supply-dependent PGUs - Accuracy (characteristic curve)	P
	Test 4) supply-dependent PGUs – Dynamic	P
5.4.8.4.1	Test of the accuracy of the Q(U) regulation	N/A

**Assessment**

Clause/§	Requirement	Verdict
5.4.8.4.2	Test of the dynamics of the Q(U) regulation	N/A
<b>5.5</b>	<b>NS-protection</b>	
5.5.2	NS protection	P
5.5.2.1	Functional safety	P
5.5.3	Central NS-protection	N/A
5.5.4	Integrated NS-protection	P
5.5.6	Interface switch	P
5.5.6.2	Central interface switch	N/A
5.5.6.3	Integrated interface switch	P
5.5.7.2	Check of setting values	P
5.5.7.3	Wiring check	N/A
5.5.7.4	Voltage and frequency control	P
5.5.7.4.1	Voltage and frequency control – Single Phase	P
	Voltage and frequency control – Multi Phase (Phase to N)	N/A
	Voltage and frequency control – Multi Phase (Phase to Phase)	N/A
	Voltage and frequency control – Measuring the rise-in voltage protection as a running 10-minute mean value	P
	Voltage and frequency control – Frequency measurement	P
5.5.7.5	Reporting of NS protection	P
5.5.9	Constructional characteristics of NS protection	P
5.5.10.1	General	P
5.5.10.2	Passive Islanding Protection	N/A
5.5.10.3	Islanding protection according to table 6 – Load imbalance (real, reactive load) for test condition A (PGU output = 100%)	P
	Islanding protection according to table 7 – Load imbalance (real, reactive load) for test condition B (PGUT output = 66%)	P
	Islanding protection according to table 8 – Load imbalance (real, reactive load) for test condition C (PGU output = 33%)	P
<b>5.6</b>	<b>Connecting conditions and synchronization</b>	
5.6.1	General	P
5.6.2	Connecting conditions and synchronisation	P
<b>5.7</b>	<b>Evidence of P<sub>AV, E</sub> - Control</b>	
5.7.1	General	N/A
5.7.2.1	Test control dynamic	N/A
5.7.2.2	Test disconnection function	N/A
<b>5.8</b>	<b>Evidence dynamic grid support</b>	
5.8.1	General	P

**Assessment**

Clause/§	Requirement	Verdict
5.8.3	Testing of the dynamic grid support PGU Type 1	N/A
5.8.3	Testing of the dynamic grid support PGU Type 2	P
5.9	<b>Test of Ancillary Unit</b>	

## **Annex 1 – Test Results**

<b>5.2 Evidence of permissible network perturbations</b>	
<b>5.2.1 General</b>	<b>P</b>
<p>The electrical installations of the customer system shall be planned, constructed and operated so that reactions to the network operator's network and to the systems of other customers are permanently reduced to a permissible minimum. Should interfering reactions on the network operator's network occur nonetheless, the customer shall apply measures to his system that are to be coordinated with the network operator. The network operator is entitled to disconnect the power generation system concerned from the network until the deficiencies are corrected.</p> <p><u>System perturbations are defined as:</u></p> <ul style="list-style-type: none"> <li>- Rapid voltage changes</li> <li>- Flicker</li> <li>- Harmonics, interharmonics and higher frequencies (up to 9 kHz)</li> </ul>	

5.2.2 Rapid voltage changes										P
<p>The purpose of the test is to determine <math>k_i</math> and <math>k_{imax}</math>.                      The following three cases must be tested (where applicable).</p> <ul style="list-style-type: none"> <li>- Switch-on for any capacity</li> <li>- Unfavourable case when switching the generator step</li> <li>- Switch-on for nominal capacity</li> </ul> <p>Note: For PV-plants the inverter is the generator</p> <ul style="list-style-type: none"> <li>- Switch-off for nominal capacity (no emergency shutdown, but operative shutdown)</li> </ul> <p>If the manufacturer knows more critical cases (e.g. different <math>\cos \varphi</math> parameters) then these additional have to be tested</p>										
<p><b>Test conditions:</b>                      Frequency: 50 Hz <math>\pm</math> 0,5%                      THD of the voltage supply: <math>\leq</math> 3 %                      Voltage rises of the PGU at 100 <math>P_{E_{max}}</math> %: <math>\leq</math> 3 %</p>										
<p><b>Assessment criterion:</b>                      Limits:  <math>k_{imax} = 1,2</math> for synchronous generators with fine synchronization, converter; (electronic inverter)  <math>k_{imax} = 4</math> for asynchronous generators, which are switched on at 95% to 105% of their synchronous speed, if no further details are available regarding the type of current limitation. With regard to short-term compensation processes, the condition mentioned below for very short voltage changes must also be observed.  <math>k_{imax} = 8</math> for asynchronous generators that are powered up by the network if <math>I_a</math> is unknown.                      (<math>I_a</math> = starting current)</p>										
<b>MST-BIE5-2500</b>										
<b>Switch-on for any capacity (10% <math>P_{E_{max}}</math>)</b>										
Phase	L1			L2			L3			
Single period effective values of the current [A]	0,840	0,997	1,031	--	--	--	--	--	--	
Single period effective values of the voltage [V]	229,9	229,8	229,8	--	--	--	--	--	--	
$k_i$ value [1]	0,019	0,023	0,024	--	--	--	--	--	--	
$k_{imax}$ value [1]	0,024			--			--			
<b>Unfavourable case when switching the generator step (not necessary for electronic inverter)</b>										
Phase	L1			L2			L3			
Single period effective values of the current [A]	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
Single period effective values of the voltage [V]	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
$k_i$ value [1]	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
$k_{imax}$ value [1]	N/A			N/A			N/A			
<b>Switch-on for nominal capacity</b>										
Phase	L1			L2			L3			
Single period effective values of the current [A]	1,938	1,061	1,070	--	--	--	--	--	--	
Single period effective	229,5	229,8	229,9	--	--	--	--	--	--	

values of the voltage [V]									
k <sub>i</sub> value [1]	0,045	0,024	0,025	--	--	--	--	--	--
k <sub>imax</sub> value [1]	0,045			--			--		
<b>Switch-off for nominal capacity</b>									
<b>Phase</b>	<b>L1</b>			<b>L2</b>			<b>L3</b>		
Single period effective values of the current [A]	1,270	0,391	1,461	--	--	--	--	--	--
Single period effective values of the voltage [V]	229,8	229,2	229,7	--	--	--	--	--	--
k <sub>i</sub> value [1]	0,029	0,009	0,034	--	--	--	--	--	--
k <sub>imax</sub> value [1]	0,034								
Grid Frequency [Hz]							50,0		
Grid voltage [V]							230,0		
Rated current I <sub>r</sub> [A]							10,870		
Highest k <sub>imax</sub> value for all switching operations [1]							0,045		
<p>Note:</p> <p>The test results of the <b>MST-BIE5-2500</b> can be applied to other units in the product series directly, since it is identical in hardware and just power derated by software.</p>									

<b>5.2.3 Flicker</b>								<b>P</b>	
<p style="text-align: center;"><b>These tests are designed to provide evidence that the requirements of VDE-AR-N 4100:2019-04 are met.</b></p>									
<p>Adherence to the thresholds for flicker must be verified as followed:</p> <ul style="list-style-type: none"> <li>- For nominal currents ≤ 16 A per conductor to DIN EN 61000-3-3 (VDE 0838-3)</li> <li>- For nominal currents &gt; 16 A and ≤ 75 A per conductor to DIN EN 61000-3-11 (VDE 0838-11)</li> </ul>									
<p><b>Test conditions:</b>                  Voltage: 86% U<sub>n</sub> to 109% U<sub>n</sub>                  Frequency: 50 Hz ± 0,5%                  THD of the voltage supply: ≤ 3 %                  Voltage rises of the PGU at 100% P<sub>Emax</sub>: ≤ 3 %</p>									
<p><b>Assessment criterion:</b>                  Long-term flicker strength P<sub>It</sub> to DIN EN 61000-3-3 (VDE 0838-3) must be ≤ 0,5.                  Determination of the flicker coefficient:</p> $c_{\psi k} = P_{st} \times (S_k / P_n)$ <p>where S<sub>k</sub> is the short-circuit power of the network standby element (during the determination of the appropriate P<sub>st</sub> values)                  The value for the network standby element must be determined separately with measurements for rated currents &gt; 75 A.</p>									
<p><i>Note:</i></p> <p>Grid impedance DIN EN 61000-3-3 (VDE 0838-3) [Ω]:      R<sub>A</sub> = 0,24Ω jX<sub>A</sub> = 0,15Ω / R<sub>N</sub> = 0,16Ω jX<sub>N</sub> = 0,10Ω                  (R<sub>n</sub> and jX<sub>n</sub> only for single-phase units used!)</p> <p>Grid impedance DIN EN 61000-3-11 (VDE 0838-11) [Ω]:      R<sub>A</sub> = 0,24Ω jX<sub>A</sub> = 0,15Ω / R<sub>N</sub> = 0,16Ω jX<sub>N</sub> = 0,10Ω                  (R<sub>n</sub> and jX<sub>n</sub> only for line to neutral single-phase or three units used!)</p> <p style="padding-left: 150px;">R<sub>A</sub> = 0,15Ω jX<sub>A</sub> = 0,15Ω / R<sub>N</sub> = 0,01Ω jX<sub>N</sub> = 0,01Ω                  (R<sub>n</sub> and jX<sub>n</sub> only for line to line three-phase units used!)</p> <p>The test results of the <b>MST-BIE5-2500</b> can be applied to other units in the product series directly, since it is identical in hardware and just power derated by software.</p>									
Test result:									
<b>a) Flicker to DIN EN 61000-3-11 (VDE 0838-3) for generator units ≤ 75 A</b>								<b>P</b>	
<b>EUT</b>		<b>Selection of limits</b>							
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>				<input type="checkbox"/>			
<b>1- phase</b>	<b>3-phase</b>	Equipment with rated current ≤16 A per phase				Equipment with rated current ≤75 A per phase			
<b>MST-BIE5-2500</b>		<i>IEC EN 61000-3-3</i>				<i>IEC EN 61000-3-11</i>			
		Starting		Stopping			Running		
		d <sub>max</sub>	d <sub>c</sub>	T <sub>max</sub>	d <sub>max</sub>	d <sub>c</sub>	T <sub>max</sub>	P <sub>st</sub>	P <sub>It</sub>
<b>Phase L1</b>		1,438	0,002	0,000	0,564	0,002	0,000	0,020	0,019
<b>Phase L2</b>		--	--	--	--	--	--	--	--
<b>Phase L3</b>		--	--	--	--	--	--	--	--
Output voltage of the impedance network [V]					230,0				
Reference impedance according the standard:									
<input checked="" type="checkbox"/> Grid impedance DIN EN 61000-3-3 (VDE 0838-3) [Ω]:      R <sub>A</sub> = 0,24Ω jX <sub>A</sub> = 0,15Ω / R <sub>N</sub> = 0,16Ω jX <sub>N</sub> = 0,10Ω									

<input type="checkbox"/>	Grid impedance DIN EN 61000-3-11 (VDE 0838-3) [ $\Omega$ ]:	(Rn and jXn only for single-phase units used!) $R_A = 0,24\Omega$ $jX_A = 0,15\Omega$ / $R_N = 0,16\Omega$ $jX_N = 0,10\Omega$ (Rn and jXn only for line to neutral single-phase or three units used!)
<input type="checkbox"/>	Grid impedance DIN EN 61000-3-11 (VDE 0838-3) [ $\Omega$ ]:	$R_A = 0,15\Omega$ $jX_A = 0,15\Omega$ / $R_N = 0,01\Omega$ $jX_N = 0,01\Omega$ (Rn and jXn only for line to line three-phase units used!)

**Flicker for rated currents  $\leq 75A$  to DIN EN 61000-3-11 (VDE 0838-3)**

**Assessment criterion:**

Long-term flicker strength:  $P_{It} \leq 0,5$

Grid impedance angle $\psi_k$	<input checked="" type="checkbox"/> $32^\circ$ or <input type="checkbox"/> $45$
-------------------------------	---

Flicker coefficient $c(\psi_k)$	0,400
---------------------------------	-------

<b>b) Flicker to DIN EN 61000-3-3 (VDE 0838-3) for generator units &gt; 75 A</b>	<b>N/A</b>
--	------------

Adherence to the thresholds for flicker must be verified as followed:  
 - For PGUs (power generation units) and PSUs (power supply units) intended for PGSs (power generation systems) with nominal currents > 75 A, the measurements must be conducted as in 5.2.3.2.

**Test conditions:**

Voltage: 86%  $U_n$  to 109%  $U_n$   
 Frequency: 50 Hz  $\pm$  0,5%  
 THD of the voltage supply:  $\leq 3\%$   
 Voltage rise of the PGU at 100%  $P_{E_{max}}$ :  $\leq 3\%$

**Assessment criterion:**

Long-term flicker strength:  $P_{It} \leq 0,5$

**Test result :**

**Flicker for rated currents >75A (at SCR = 20) (Calculation Flickermeter according to TG3)**

Rated Output voltage [V]	--			
Grid impedance angle $\psi_k$ [°]	30	50	70	85
Flicker coefficient $c(\psi_k)$ [1]	--	--	--	--
Short-term Flicker $P_{st}$ [1]	--	--	--	--
Flicker step factor $k(f\psi_k)$ [1]	--	--	--	--
Voltage change factor $k(u\psi_k)$ [1]	--	--	--	--

<b>5.2.4</b>	<b>Harmonics and interharmonics</b>	<b>P</b>
--------------	-------------------------------------	----------

<b>5.2.4.1 a)</b>	<b>Harmonics test</b>	<b>P</b>
-------------------	-----------------------	----------

EUT		Selection of limits		
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
1-phase	3-phase	Class A equipment with input current ≤16 A per phase	Equipment with input current >16 A and ≤75 A per phase	Equipment with input current >75 A per phase
<b>MST-BIE5-2500</b>		<b>IEC EN 61000-3-2</b>	<b>IEC EN 61000-3-12</b>	

Phase	L1	L2	L3
Power Level	30%	30%	30%
AC Power [W]	751	--	--
AC Voltage [V]	229,8	--	--
AC Current [A]	3,272	--	--
Frequency [Hz]	50,00	--	--

Harmonic	Measured value I <sub>h</sub> [A]			Measured value I <sub>h</sub> [%I <sub>1</sub> ]			Limits [A] IEC EN 61000-3-2
	L1	L2	L3	L1	L2	L3	
1st	3,268	--	--	--	--	--	--
2nd	0,007	--	--	0,228	--	--	1,080
3rd	0,039	--	--	1,196	--	--	2,300
4th	0,003	--	--	0,089	--	--	0,430
5th	0,041	--	--	1,269	--	--	1,140
6th	0,004	--	--	0,120	--	--	0,300
7th	0,022	--	--	0,661	--	--	0,770
8th	0,005	--	--	0,147	--	--	0,263
9th	0,020	--	--	0,601	--	--	0,400
10th	0,004	--	--	0,109	--	--	0,184
11th	0,019	--	--	0,585	--	--	0,330
12th	0,003	--	--	0,100	--	--	0,153
13th	0,009	--	--	0,264	--	--	0,210
14th	0,004	--	--	0,108	--	--	0,131
15th	0,018	--	--	0,551	--	--	0,150
16th	0,005	--	--	0,138	--	--	0,115
17th	0,019	--	--	0,574	--	--	0,132
18th	0,004	--	--	0,117	--	--	0,102
19th	0,017	--	--	0,512	--	--	0,188
20th	0,004	--	--	0,127	--	--	0,092
21th	0,010	--	--	0,295	--	--	0,107
22th	0,004	--	--	0,113	--	--	0,084
23th	0,009	--	--	0,285	--	--	0,098
24th	0,004	--	--	0,111	--	--	0,077
25th	0,004	--	--	0,138	--	--	0,090
26th	0,003	--	--	0,103	--	--	0,071

27th	0,006	--	--	0,174	--	--	0,080
28th	0,003	--	--	0,087	--	--	0,066
29th	0,009	--	--	0,283	--	--	0,078
30th	0,003	--	--	0,085	--	--	0,061
31th	0,012	--	--	0,381	--	--	0,073
32th	0,003	--	--	0,087	--	--	0,057
33th	0,010	--	--	0,303	--	--	0,068
34th	0,003	--	--	0,079	--	--	0,054
35th	0,003	--	--	0,087	--	--	0,064
36th	0,002	--	--	0,072	--	--	0,051
37th	0,004	--	--	0,115	--	--	0,061
38th	0,003	--	--	0,077	--	--	0,048
39th	0,004	--	--	0,115	--	--	0,058
40th	0,002	--	--	0,075	--	--	0,046
<b>THD [%]</b>	--	--	--	2,444	--	--	--

<b>Phase</b>	<b>L1</b>	<b>L2</b>	<b>L3</b>	/
<b>Power Level</b>	<b>60%</b>	<b>60%</b>	<b>60%</b>	
<b>AC Power [W]</b>	1500	--	--	
<b>AC Voltage [V]</b>	229,7	--	--	
<b>AC Current [A]</b>	6,532	--	--	
<b>Frequency [Hz]</b>	50,00	--	--	

Harmonic	Measured value I <sub>h</sub> [A]			Measured value I <sub>h</sub> [%I <sub>1</sub> ]			Limits [A] IEC EN 61000-3-2
	L1	L2	L3	L1	L2	L3	
1st	6,530	--	--	--	--	--	--
2nd	0,011	--	--	0,172	--	--	1,080
3rd	0,048	--	--	0,730	--	--	2,300
4th	0,003	--	--	0,051	--	--	0,430
5th	0,034	--	--	0,527	--	--	1,140
6th	0,004	--	--	0,060	--	--	0,300
7th	0,017	--	--	0,258	--	--	0,770
8th	0,004	--	--	0,064	--	--	0,263
9th	0,015	--	--	0,235	--	--	0,400
10th	0,005	--	--	0,073	--	--	0,184
11th	0,021	--	--	0,318	--	--	0,330
12th	0,004	--	--	0,064	--	--	0,153
13th	0,019	--	--	0,290	--	--	0,210
14th	0,004	--	--	0,054	--	--	0,131
15th	0,022	--	--	0,344	--	--	0,150
16th	0,004	--	--	0,067	--	--	0,115
17th	0,025	--	--	0,377	--	--	0,132
18th	0,004	--	--	0,058	--	--	0,102

19th	0,014	--	--	0,217	--	--	0,188
20th	0,004	--	--	0,055	--	--	0,092
21th	0,010	--	--	0,150	--	--	0,107
22th	0,004	--	--	0,061	--	--	0,084
23th	0,013	--	--	0,202	--	--	0,098
24th	0,004	--	--	0,060	--	--	0,077
25th	0,010	--	--	0,151	--	--	0,090
26th	0,004	--	--	0,056	--	--	0,071
27th	0,005	--	--	0,069	--	--	0,080
28th	0,004	--	--	0,067	--	--	0,066
29th	0,006	--	--	0,097	--	--	0,078
30th	0,004	--	--	0,059	--	--	0,061
31th	0,014	--	--	0,210	--	--	0,073
32th	0,004	--	--	0,059	--	--	0,057
33th	0,008	--	--	0,127	--	--	0,068
34th	0,004	--	--	0,057	--	--	0,054
35th	0,005	--	--	0,080	--	--	0,064
36th	0,004	--	--	0,055	--	--	0,051
37th	0,006	--	--	0,084	--	--	0,061
38th	0,004	--	--	0,054	--	--	0,048
39th	0,004	--	--	0,060	--	--	0,058
40th	0,004	--	--	0,055	--	--	0,046
<b>THD [%]</b>	--	--	--	1,304	--	--	--

<b>Phase</b>	<b>L1</b>	<b>L2</b>	<b>L3</b>
<b>Power Level</b>	<b>100%</b>	<b>100%</b>	<b>100%</b>
<b>AC Power [W]</b>	2489	--	--
<b>AC Voltage [V]</b>	229,7	--	--
<b>AC Current [A]</b>	10,838	--	--
<b>Frequency [Hz]</b>	50,00	--	--

Harmonic	Measured value I <sub>h</sub> [A]			Measured value I <sub>h</sub> [%I <sub>1</sub> ]			Limits [A] IEC EN 61000-3-2
	L1	L2	L3	L1	L2	L3	
1st	10,836	--	--		--	--	--
2nd	0,011	--	--	0,102	--	--	1,080
3rd	0,088	--	--	0,815	--	--	2,300
4th	0,004	--	--	0,041	--	--	0,430
5th	0,045	--	--	0,417	--	--	1,140
6th	0,005	--	--	0,042	--	--	0,300
7th	0,028	--	--	0,259	--	--	0,770
8th	0,005	--	--	0,045	--	--	0,263
9th	0,026	--	--	0,241	--	--	0,400
10th	0,004	--	--	0,041	--	--	0,184

11th	0,029	--	--	0,266	--	--	0,330
12th	0,004	--	--	0,034	--	--	0,153
13th	0,030	--	--	0,278	--	--	0,210
14th	0,004	--	--	0,038	--	--	0,131
15th	0,035	--	--	0,323	--	--	0,150
16th	0,005	--	--	0,050	--	--	0,115
17th	0,038	--	--	0,349	--	--	0,132
18th	0,005	--	--	0,042	--	--	0,102
19th	0,029	--	--	0,268	--	--	0,188
20th	0,005	--	--	0,044	--	--	0,092
21th	0,015	--	--	0,141	--	--	0,107
22th	0,005	--	--	0,043	--	--	0,084
23th	0,010	--	--	0,090	--	--	0,098
24th	0,005	--	--	0,050	--	--	0,077
25th	0,013	--	--	0,117	--	--	0,090
26th	0,006	--	--	0,054	--	--	0,071
27th	0,008	--	--	0,069	--	--	0,080
28th	0,007	--	--	0,061	--	--	0,066
29th	0,005	--	--	0,050	--	--	0,078
30th	0,006	--	--	0,060	--	--	0,061
31th	0,011	--	--	0,104	--	--	0,073
32th	0,006	--	--	0,055	--	--	0,057
33th	0,012	--	--	0,107	--	--	0,068
34th	0,006	--	--	0,058	--	--	0,054
35th	0,006	--	--	0,058	--	--	0,064
36th	0,008	--	--	0,070	--	--	0,051
37th	0,007	--	--	0,064	--	--	0,061
38th	0,007	--	--	0,068	--	--	0,048
39th	0,010	--	--	0,091	--	--	0,058
40th	0,007	--	--	0,066	--	--	0,046
<b>THD [%]</b>	--	--	--	1,248	--	--	--

DC Battery (Source) input current		55
DC Battery (Source) input voltage		51,2
P <sub>DC-Sum</sub> [W]		2816
Impedance [Ω]		
	Line	R <sub>A</sub> = 0,24 jX <sub>A</sub> = 0,15
	Neutral	R <sub>N</sub> = 0,16 jX <sub>N</sub> = 0,10

Note:

The test results of the **MST-BIE5-2500** can be applied to other units in the product series directly, since it is identical in hardware and just power derated by software.

<b>5.2.4.1 b) Test Harmonics DIN EN 61000-4-7 (≥75 A per Phase)</b>	<b>P</b>
---	----------

Harmonics											
L1 phase											
P/ P <sub>re</sub> [%]	5	10	20	30	40	50	60	70	80	90	100
Order	I <sub>h</sub> [%]										
1	5,014	9,9176	20,0284	30,0656	40,1304	50,0848	60,076	69,9384	79,994	90,0772	99,6912
2	0,037	0,055	0,064	0,064	0,083	0,101	0,101	0,110	0,110	0,101	0,101
3	0,745	0,653	0,451	0,359	0,359	0,377	0,442	0,524	0,616	0,718	0,810
4	0,046	0,046	0,037	0,028	0,028	0,028	0,028	0,028	0,037	0,046	0,037
5	0,506	0,570	0,469	0,377	0,331	0,322	0,313	0,331	0,350	0,377	0,414
6	0,028	0,037	0,037	0,037	0,037	0,037	0,037	0,037	0,037	0,037	0,046
7	0,248	0,313	0,285	0,202	0,147	0,129	0,156	0,184	0,212	0,239	0,258
8	0,028	0,037	0,028	0,046	0,046	0,046	0,037	0,037	0,046	0,046	0,046
9	0,166	0,175	0,212	0,184	0,156	0,138	0,138	0,156	0,184	0,221	0,239
10	0,028	0,028	0,028	0,037	0,037	0,046	0,046	0,037	0,037	0,037	0,037
11	0,037	0,074	0,147	0,175	0,175	0,175	0,193	0,212	0,230	0,248	0,267
12	0,028	0,037	0,028	0,028	0,037	0,037	0,037	0,037	0,037	0,037	0,037
13	0,092	0,064	0,028	0,083	0,120	0,147	0,175	0,202	0,230	0,248	0,276
14	0,028	0,028	0,037	0,037	0,028	0,028	0,037	0,037	0,037	0,028	0,037
15	0,184	0,202	0,184	0,166	0,166	0,184	0,202	0,230	0,267	0,294	0,322
16	0,037	0,037	0,046	0,046	0,037	0,037	0,037	0,046	0,046	0,046	0,046
17	0,147	0,175	0,193	0,175	0,166	0,193	0,230	0,258	0,294	0,322	0,350
18	0,028	0,028	0,037	0,037	0,037	0,037	0,037	0,037	0,037	0,037	0,046
19	0,092	0,120	0,156	0,156	0,138	0,129	0,129	0,156	0,184	0,221	0,267
20	0,028	0,028	0,028	0,037	0,037	0,037	0,037	0,037	0,037	0,037	0,046
21	0,037	0,037	0,064	0,092	0,092	0,092	0,092	0,092	0,101	0,120	0,138
22	0,018	0,028	0,028	0,037	0,037	0,037	0,037	0,037	0,037	0,037	0,046
23	0,064	0,055	0,055	0,083	0,110	0,120	0,120	0,101	0,092	0,083	0,092
24	0,018	0,018	0,028	0,037	0,028	0,037	0,037	0,037	0,037	0,037	0,046
25	0,037	0,046	0,028	0,037	0,064	0,074	0,092	0,110	0,120	0,120	0,120
26	0,018	0,018	0,028	0,028	0,037	0,037	0,037	0,037	0,037	0,037	0,055
27	0,028	0,028	0,046	0,055	0,046	0,037	0,046	0,046	0,046	0,055	0,074
28	0,018	0,028	0,028	0,028	0,028	0,037	0,037	0,074	0,101	0,055	0,064
29	0,083	0,083	0,083	0,083	0,110	0,074	0,055	0,046	0,037	0,037	0,046
30	0,018	0,018	0,028	0,028	0,028	0,028	0,037	0,046	0,046	0,046	0,055
31	0,055	0,064	0,092	0,110	0,120	0,110	0,129	0,129	0,129	0,110	0,101
32	0,018	0,018	0,028	0,028	0,028	0,037	0,037	0,037	0,046	0,046	0,055
33	0,074	0,074	0,074	0,092	0,101	0,092	0,074	0,074	0,083	0,092	0,110
34	0,018	0,018	0,018	0,028	0,028	0,037	0,037	0,037	0,037	0,046	0,055
35	0,037	0,037	0,028	0,028	0,028	0,037	0,046	0,046	0,046	0,055	0,055
36	0,028	0,028	0,018	0,018	0,028	0,028	0,037	0,037	0,046	0,055	0,074
37	0,028	0,028	0,028	0,037	0,028	0,037	0,055	0,046	0,055	0,064	0,064
38	0,018	0,028	0,028	0,028	0,028	0,028	0,037	0,037	0,046	0,064	0,064
39	0,055	0,055	0,037	0,037	0,037	0,037	0,037	0,046	0,074	0,083	0,092
40	0,018	0,018	0,028	0,018	0,028	0,028	0,037	0,037	0,055	0,055	0,064
THC [%]	1,008	1,012	0,850	0,736	0,705	0,718	0,785	0,883	1,001	1,117	1,242

<b>5.2.4.1 b) Test Harmonics DIN EN 61000-4-7 (≥75 A per Phase)</b>	<b>P</b>
---	----------

<b>Interharmonics</b>											
<b>Test result:</b>											
P/P <sub>TE</sub> [%]	5	10	20	30	40	50	60	70	80	90	100
f [Hz]	I <sub>h</sub> [%]										
75	0,037	0,031	0,027	0,040	0,052	0,056	0,056	0,052	0,050	0,039	0,044
125	0,043	0,033	0,031	0,043	0,054	0,060	0,056	0,048	0,045	0,038	0,044
175	0,036	0,031	0,036	0,048	0,054	0,057	0,050	0,040	0,039	0,039	0,051
225	0,047	0,046	0,041	0,050	0,057	0,058	0,050	0,044	0,041	0,043	0,051
275	0,043	0,045	0,047	0,050	0,056	0,049	0,045	0,040	0,037	0,042	0,053
325	0,041	0,045	0,049	0,059	0,066	0,052	0,049	0,044	0,041	0,046	0,056
375	0,035	0,040	0,055	0,068	0,069	0,055	0,048	0,038	0,037	0,047	0,060
425	0,036	0,033	0,049	0,060	0,063	0,058	0,046	0,042	0,040	0,050	0,061
475	0,042	0,043	0,057	0,064	0,061	0,054	0,044	0,044	0,045	0,056	0,067
525	0,031	0,039	0,053	0,062	0,063	0,053	0,048	0,044	0,044	0,054	0,069
575	0,053	0,059	0,068	0,069	0,064	0,051	0,045	0,045	0,047	0,056	0,066
625	0,047	0,053	0,067	0,070	0,063	0,054	0,049	0,046	0,049	0,057	0,072
675	0,055	0,060	0,066	0,065	0,052	0,044	0,049	0,054	0,053	0,057	0,064
725	0,051	0,066	0,076	0,076	0,066	0,054	0,058	0,060	0,059	0,062	0,072
775	0,081	0,086	0,079	0,065	0,052	0,049	0,057	0,058	0,055	0,055	0,061
825	0,084	0,084	0,079	0,065	0,054	0,056	0,062	0,062	0,059	0,062	0,067
875	0,041	0,041	0,041	0,047	0,064	0,076	0,081	0,073	0,066	0,060	0,061
925	0,056	0,057	0,050	0,044	0,053	0,064	0,070	0,068	0,064	0,058	0,063
975	0,036	0,034	0,042	0,060	0,078	0,079	0,070	0,057	0,052	0,046	0,059
1025	0,039	0,037	0,043	0,062	0,083	0,088	0,083	0,067	0,058	0,049	0,057
1075	0,062	0,072	0,081	0,087	0,085	0,071	0,056	0,049	0,053	0,062	0,070
1125	0,042	0,056	0,073	0,082	0,082	0,073	0,057	0,051	0,055	0,066	0,076
1175	0,090	0,093	0,089	0,078	0,061	0,053	0,064	0,077	0,083	0,085	0,081
1225	0,087	0,101	0,100	0,092	0,076	0,056	0,052	0,068	0,076	0,081	0,081
1275	0,067	0,051	0,042	0,052	0,073	0,093	0,105	0,103	0,094	0,090	0,087
1325	0,092	0,077	0,049	0,047	0,067	0,091	0,108	0,113	0,106	0,093	0,086
1375	0,108	0,126	0,151	0,158	0,146	0,157	0,145	0,114	0,076	0,123	0,140
1425	0,054	0,077	0,110	0,122	0,125	0,117	0,102	0,081	0,068	0,070	0,089
1475	0,069	0,066	0,055	0,043	0,047	0,067	0,092	0,109	0,125	0,133	0,135
1525	0,080	0,097	0,091	0,073	0,057	0,052	0,062	0,084	0,104	0,119	0,125
1575	0,031	0,029	0,035	0,054	0,072	0,082	0,088	0,090	0,084	0,077	0,068
1625	0,046	0,042	0,036	0,060	0,086	0,100	0,109	0,110	0,103	0,092	0,068
1675	0,042	0,048	0,070	0,076	0,075	0,065	0,056	0,055	0,070	0,097	0,108
1725	0,033	0,037	0,053	0,064	0,067	0,060	0,057	0,059	0,068	0,100	0,106
1775	0,103	0,099	0,095	0,078	0,052	0,046	0,055	0,066	0,077	0,100	0,094
1825	0,091	0,102	0,105	0,095	0,074	0,056	0,064	0,067	0,080	0,108	0,104
1875	0,039	0,051	0,073	0,097	0,118	0,125	0,119	0,110	0,105	0,101	0,092
1925	0,044	0,037	0,043	0,076	0,113	0,129	0,129	0,120	0,117	0,101	0,093
1975	0,094	0,081	0,078	0,074	0,059	0,044	0,056	0,081	0,125	0,127	0,136

<b>5.2.4.1 b) Test Harmonics DIN EN 61000-4-7 (≥75 A per Phase)</b>	<b>P</b>
---	----------

**Higher Frequencies**

**Test result:**

P/P <sub>TE</sub> [%]	5	10	20	30	40	50	60	70	80	90	100
f [kHz]	I <sub>h</sub> [%]										
2,1	0,168	0,174	0,194	0,203	0,204	0,195	0,197	0,225	0,268	0,248	0,253
2,3	0,096	0,101	0,109	0,122	0,139	0,174	0,210	0,232	0,247	0,291	0,277
2,5	0,203	0,203	0,229	0,246	0,245	0,231	0,221	0,216	0,238	0,237	0,231
2,7	0,258	0,236	0,210	0,217	0,244	0,271	0,293	0,313	0,316	0,314	0,328
2,9	0,419	0,407	0,393	0,382	0,365	0,334	0,301	0,262	0,228	0,221	0,244
3,1	0,190	0,223	0,265	0,290	0,321	0,333	0,343	0,352	0,353	0,351	0,354
3,3	0,088	0,094	0,126	0,148	0,162	0,167	0,180	0,200	0,214	0,237	0,276
3,5	0,099	0,099	0,106	0,106	0,109	0,114	0,128	0,143	0,162	0,187	0,228
3,7	0,090	0,097	0,106	0,116	0,127	0,131	0,128	0,123	0,120	0,120	0,136
3,9	0,075	0,074	0,074	0,075	0,083	0,090	0,102	0,114	0,126	0,141	0,147
4,1	0,052	0,053	0,055	0,062	0,066	0,071	0,075	0,084	0,090	0,105	0,106
4,3	0,051	0,055	0,059	0,064	0,070	0,076	0,083	0,087	0,094	0,105	0,104
4,5	0,055	0,054	0,057	0,061	0,067	0,073	0,084	0,099	0,123	0,136	0,157
4,7	0,088	0,097	0,110	0,132	0,155	0,180	0,207	0,239	0,279	0,315	0,359
4,9	0,047	0,049	0,050	0,055	0,059	0,062	0,067	0,078	0,079	0,083	0,092
5,1	0,050	0,050	0,053	0,057	0,057	0,055	0,059	0,062	0,065	0,071	0,079
5,3	0,046	0,046	0,044	0,046	0,049	0,054	0,057	0,061	0,065	0,069	0,075
5,5	0,048	0,044	0,041	0,041	0,042	0,042	0,046	0,052	0,057	0,061	0,067
5,7	0,041	0,045	0,045	0,045	0,043	0,044	0,045	0,047	0,046	0,051	0,056
5,9	0,042	0,042	0,046	0,049	0,049	0,047	0,048	0,053	0,059	0,065	0,081
6,1	0,045	0,048	0,051	0,053	0,058	0,064	0,071	0,086	0,100	0,117	0,146
6,3	0,027	0,030	0,035	0,037	0,036	0,034	0,035	0,036	0,036	0,038	0,040
6,5	0,026	0,027	0,028	0,031	0,032	0,032	0,033	0,034	0,033	0,035	0,036
6,7	0,024	0,025	0,028	0,030	0,030	0,030	0,030	0,031	0,031	0,032	0,033
6,9	0,022	0,022	0,024	0,027	0,029	0,028	0,029	0,029	0,029	0,029	0,030
7,1	0,021	0,022	0,023	0,025	0,025	0,026	0,027	0,027	0,027	0,028	0,029
7,3	0,022	0,023	0,023	0,025	0,026	0,027	0,027	0,027	0,029	0,030	0,030
7,5	0,030	0,030	0,030	0,030	0,030	0,030	0,030	0,031	0,031	0,033	0,034
7,7	0,025	0,025	0,026	0,030	0,034	0,027	0,027	0,027	0,027	0,028	0,029
7,9	0,028	0,029	0,030	0,027	0,023	0,030	0,030	0,027	0,025	0,032	0,035
8,1	0,021	0,022	0,023	0,024	0,024	0,023	0,023	0,026	0,030	0,026	0,026
8,3	0,018	0,019	0,019	0,022	0,023	0,022	0,022	0,021	0,020	0,021	0,022
8,5	0,016	0,017	0,018	0,019	0,020	0,021	0,022	0,021	0,020	0,020	0,020
8,7	0,016	0,016	0,018	0,018	0,018	0,018	0,019	0,020	0,020	0,020	0,021
8,9	0,019	0,020	0,020	0,021	0,021	0,020	0,019	0,019	0,019	0,021	0,022

5.2.4.1 b) Test Harmonics DIN EN 61000-4-7 ( $\geq 75$ A per Phase)		P
DC Battery (Source) input current	55	
DC Battery (Source) input voltage	51,2	
P <sub>DC-Sum</sub> [W]	2816	
Impedance [ $\Omega$ ]		
Line	$R_A = 0,24 \text{ j}X_A = 0,15$	
Neutral	$R_N = 0,16 \text{ j}X_N = 0,10$	

<b>5.2.5 Commutation</b>	<b>N/A</b>
<p>This test serves to determine the commutation currents, the project - specific identification and assessment of the</p> <p>Commutation voltage dips according to VDE-AR-N 4100: 2020-06, 5.4.4.5 is required taking into account the short-circuit power at the point of connection.</p> <ul style="list-style-type: none"><li>- This check is only required for mains-controlled inverters.</li></ul>	

<b>5.2.6 Feed in of DC current</b>	<b>P</b>
------------------------------------	----------

**Test procedural:**

The inverter must be used in the adjustment range Test1, Test2 and Test 3.

Each test point shall be held for min 5 minutes and  $I_{AC}$ ,  $U_{AC}$ ,  $I_{dc}$  in AC of each phase has to be recorded.

Measurement of  $I_{dc}$  in AC must be done according to VDE AR-N 4100:2020-06 based on DIN EN 61000-4-7 (VDE-0847-4-7) over 10 fundamental periods.


**Assessment criterion:**

An inverter must not feed more than 0,5% of its rated current  $I_r$  or a maximum of 20 mA (the higher value is to be selected) as direct current.

**MST-BIE5-2500**

Power Level [% of $V_{Ar}$ ]	30% $S_{E_{max}}$ to 40% $S_{E_{max}}$	60% $S_{E_{max}}$ to 70% $S_{E_{max}}$	>95% $S_{E_{max}}$
AC Power [VA]	872	1622	2490
AC Voltage [V]	229,8	229,7	229,7
AC Current [A]	3,796	7,058	10,840
Max. DC Current in AC [mA]	19	20	19
Max. DC Current in AC [% of $I_r$ ]	0,174	0,183	0,174
Average. DC Current in AC [mA]	13	12	12
Average. DC Current in AC [% of $I_r$ ]	0,119	0,110	0,110

**Graphs for MST-BIE5-2500**



**Note:**

The test results of the **MST-BIE5-2500** can be applied to other units in the product series directly, since it is identical in hardware and just power derated by software.

<p><b>5.3 Evidence of symmetry behaviour of inverters</b></p>	<p><b>N/A</b></p>
<p><b>5.3.1 General</b></p>	<p><b>N/A</b></p>
<p>These tests serve to prove the requirements according to VDE-AR-N 4100: 2020-06, 5.5:                  These tests are not applicable for direct connected rotating machines!                  This test is necessary only for electronic inverters!</p>	
<p><b>Note:</b>                  The tests of the “symmetry characteristics of three-phase inverter modules” were performed on the unit with the highest output power. Here is the maximum asymmetry given.</p>	

<b>5.3.2.1 Calculation of asymmetry</b>	<b>N/A</b>
---	------------

**Test procedural:**  
 The maximum absolute difference between the apparent powers of the three phases is determined for each of the five measurements (1-min means) in the respective operating point.  
 The maximum of these five values is again determined.

**Assessment criterion:**  
 The test is passed if the maximum value from the above measurements does not exceed 5 %  $S_{E_{max}}$  and  $\leq 4600$  VA.

**Note:**  
 The maximum inductive and capacitive values are specified by the manufacturer.

<b>Setting values</b>	cos $\phi = 1$	--				
	cos $\phi$ over-excited	--				
	cos $\phi$ under-excited	--				
<b>Test:</b>						
1-min mean value	L1	L2	L3	L1 – L2	L2 – L3	L3 – L1
<b>a) cos <math>\phi = 1</math> at 100 % <math>P_{rE} \pm 5</math> % <math>P_{E_{max}}</math></b>						
$S_{E60}$ [VA]	--	--	--	--	--	--
	--	--	--	--	--	--
	--	--	--	--	--	--
	--	--	--	--	--	--
	--	--	--	--	--	--
COS $\phi_{E60}$	--					
max. asymmetry [VA]	--					
<b>b) maximum under-excited (i) at 100 % <math>P_{rE} \pm 5</math> % <math>P_{E_{max}}</math></b>						
$S_{E60}$ [VA]	--	--	--	--	--	--
	--	--	--	--	--	--
	--	--	--	--	--	--
	--	--	--	--	--	--
	--	--	--	--	--	--
COS $\phi_{E60}$	--					
max. asymmetry [VA]	--					

<b>c) maximum over-excited (c) at 100 % P<sub>rE</sub> ± 5 % P<sub>E<sub>max</sub></sub></b>						
S <sub>E60</sub> [VA]	--	--	--	--	--	--
	--	--	--	--	--	--
	--	--	--	--	--	--
	--	--	--	--	--	--
	--	--	--	--	--	--
COS φ <sub>E60</sub>		--				
max. asymmetry [VA]		--				
<b>d) cos φ = 1 at 50 % P<sub>rE</sub> ± 5 % P<sub>E<sub>max</sub></sub></b>						
S <sub>E60</sub> [VA]	--	--	--	--	--	--
	--	--	--	--	--	--
	--	--	--	--	--	--
	--	--	--	--	--	--
	--	--	--	--	--	--
COS φ <sub>E60</sub>		--				
max. asymmetry [VA]		--				
<b>e) maximum under-excited (i) at 50 % P<sub>rE</sub> ± 5 % P<sub>E<sub>max</sub></sub></b>						
S <sub>E60</sub> [VA]	--	--	--	--	--	--
	--	--	--	--	--	--
	--	--	--	--	--	--
	--	--	--	--	--	--
	--	--	--	--	--	--
COS φ <sub>E60</sub>		--				
max. asymmetry [VA]		--				
<b>f) maximum over-excited (c) at 50 % P<sub>rE</sub> ± 5 % P<sub>E<sub>max</sub></sub></b>						
S <sub>E60</sub> [VA]	--	--	--	--	--	--
	--	--	--	--	--	--
	--	--	--	--	--	--
	--	--	--	--	--	--
	--	--	--	--	--	--
COS φ <sub>E60</sub> :		--				
max. asymmetry [VA]		--				
<b>Limit:</b>		≤5% S <sub>E<sub>max</sub></sub> and ≤4600VA				

**5.4 Evidence of the behaviour of the generating unit on the network**

<p><b>5.4.1 General</b>          (these tests are designed to provide evidence that the requirements of VDE-AR-N 4105:2018-11, 5.7.2.2 are met and to determine the values for <math>S_{E_{max}}</math> and <math>P_{E_{max}}</math>)</p>	<p><b>P</b></p>
<p><b>Test Condition:</b>          The measurements were performed in the testing laboratory at the grid-simulator.          Test voltage between 0,9 Un and 1,09 Un with <math>\pm 2\%</math> Un until the test          Test frequency: 50Hz <math>\pm 0,5\%</math></p>	
<p><b>Note:</b>          If an examination is required for any other requirements, these apply to this test.</p>	

<b>5.4.2 Measurement of the active power and reactive power range</b> (These tests are designed to provide evidence that the requirements of VDE-AR-N 4105:2018-11, 5.7.2.2 are met)	<b>P</b>
---	----------

**Test:**  
 The setpoint signal must be reduced from 100% to 10% P<sub>RE</sub>:  
 For adjustable PGUs in increments of 10% P<sub>RE</sub> 1 minute must elapse after every change to the setpoint setting so that the PGU can settle at the new setpoint. Then the active power of the PGU must be measured as a 1-min mean value.

**Assessment criterion:**  
 a) for adjustable PGUs:  
 - no network disconnection  
 - the active power value does not exceed the setpoint by more than ±5% P<sub>RE</sub>  
 - the setting time determined this way is ≤1min

**Note:**  
 The setting time is ≤ 1min. See “Graph of the setting accuracy”.  
 The maximum inductive and capacitive values are specified by the manufacturer.

<b>Setting values</b>	cos φ = 1	1,0
	cos φ over-excited:	0,95
	cos φ under-excited:	0,95

<b>MST-BIE5-2500</b>				
600s mean value	U [V]	P <sub>E<sub>max</sub>600 c)</sub> [W]	S <sub>E<sub>max</sub>600 c)</sub> [VA]	COS φ <sub>E<sub>max</sub>600</sub> [-]
<b>0,90 U<sub>n</sub> at 100% P<sub>E<sub>max</sub></sub></b>				
cos φ = 1	206,72	2427	2428	0,999
cos φ max. over-excited	206,73	2343	2467	0,950
<b>0,95 U<sub>n</sub> at 100% P<sub>E<sub>max</sub></sub></b>				
cos φ max. under-excited	218,22	2399	2527	0,950
<b>1,0 U<sub>n</sub> at 100% P<sub>E<sub>max</sub></sub></b>				
cos φ = 1	229,70	2489	2490	0,999
cos φ max. under-excited	229,71	2369	2495	0,949
cos φ max. over-excited	229,71	2368	2493	0,950
<b>1,05 U<sub>n</sub> at 100% P<sub>E<sub>max</sub></sub></b>				
cos φ max. over-excited	241,19	2367	2492	0,950
<b>1,09 U<sub>n</sub> at 100% P<sub>E<sub>max</sub></sub></b>				
cos φ = 1	251,38	2485	2486	0,999
cos φ max. under-excited	251,38	2369	2496	0,949
<b>S<sub>E<sub>max</sub>600</sub> and P<sub>E<sub>max</sub>600</sub></b>				
S <sub>E<sub>max</sub>600</sub> = max (S <sub>E<sub>max</sub>600 a)</sub> , S <sub>E<sub>max</sub>600 b)</sub> , S <sub>E<sub>max</sub>600 c)</sub> [VA]		2527		
P <sub>E<sub>max</sub>600</sub> = max (P <sub>E<sub>max</sub>600 a)</sub> , P <sub>E<sub>max</sub>600 b)</sub> , P <sub>E<sub>max</sub>600 c)</sub> [W]		2489		

**Note:**  
 The test results of the **MST-BIE5-2500** can be applied to other units in the product series directly, since it is identical in hardware and just power derated by software.

**5.4.3 Measurement of setting accuracy** **P**

Test procedural:

The P setpoint was set by RS485 port.

(The active power can be set between 100%P<sub>n</sub> and 10%P<sub>n</sub> with a step size of 10%P<sub>n</sub>)

Assessment:

- no network disconnection occurs and
- the active power value does not deviate by more than 5% P<sub>rE</sub> from the target value.

Note:


The test results of the **MST-BIE5-2500** can be applied to other units in the product series directly, since it is identical in hardware and just power derated by software.

**MST-BIE5-2500**

% of rated capability	Setpoint		Measured value		Deviation (P <sub>meas</sub> - P <sub>set</sub> )		Limit ΔP <sub>E60</sub> in %
	[W]	[%P <sub>n</sub> ]	[W]	[%P <sub>n</sub> ]	[W]	[%P <sub>n</sub> ]	
100	2500	100,0	2494	99,74	-6	-0,26	≤ ±5% of P <sub>rE</sub>
90	2250	90,0	2243	89,71	-7	-0,29	
80	2000	80,0	1996	79,84	-4	-0,16	
70	1750	70,0	1746	69,83	-4	-0,17	
60	1500	60,0	1495	59,82	-5	-0,18	
50	1250	50,0	1246	49,82	-4	-0,18	
40	1000	40,0	995	39,79	-5	-0,21	
30	750	30,0	746	29,83	-4	-0,17	
20	500	20,0	497	19,87	-3	-0,13	
10	250	10,0	249	9,97	-1	-0,03	

Overall maximum active power deviation to set point [%P<sub>n</sub>]: 0,29

**Graph of the setting accuracy: MST-BIE5-2500**



<b>5.4.3.4 Measurement of the power gradient</b>	<b>P</b>
--	----------

Test procedural:  
 The P setpoint was set by RS485 port.  
 The measurement of the power gradient takes place:

- Via a setpoint change from 100% to 5% of the rated effective power  $P_{rE}$  at time  $t_0$ . If the technical performance is >5%, this should be specified.
- Via a setpoint change from 5% to 100% of the rated effective power  $P_{rE}$  at time  $t_0$ . Is the technical Performance >5%, this should be specified.

Assessment:


- no network disconnection occurs and
- the power gradients determined in accordance with 5.4.3.4 shall not fall below 0,33 %  $P_{rE}$  and shall not exceed 0,66 %  $P_{rE}$ .
- The first gradient is to be formed 30 s after setting the setpoint jump.
- The formation of gradients is terminated 30 s before reaching the stationary final value.

Note:  
 The test results of the **MST-BIE5-2500** can be applied to other units in the product series directly, since it is identical in hardware and just power derated by software.

**Verification the setting Power gradient change from 100% $P_{rE}$  to 5% $P_{rE}$  at MST-BIE5-2500**

P_setting point step	Setting value	Measured value
$P_{before\ power\ change} = 100\% P_{rE} \pm 5\% P_{rE}$	100,0% $P_{rE}$	99,72% $P_{rE}$
Power gradient (during power change):	0,5 % $P_{rE}$ / s	0,50% $P_{rE}$ / s
$P_{after\ power\ change} = 5\% P_{rE} \pm 5\% P_{rE}$	5,0% $P_{rE}$	4,44 % $P_{rE}$


**Graph of the gradient 100% to 5%  $P_{rE}$**



<b>5.4.3.4 Measurement of the power gradient</b>	<b>P</b>
--	----------

<b>Verification the setting Power gradient change from 5% to 100% at MST-BIE5-2500</b>		
P_setting point step	Setting value	Measured value
P <sub>before power change</sub> = 5% P <sub>rE</sub> ± 5% P <sub>rE</sub>	5,0% P <sub>rE</sub>	5,03% P <sub>rE</sub>
Power gradient (during power change):	0,5 %P <sub>rE</sub> / s	0,50%P <sub>rE</sub> / s
P <sub>after power change</sub> = 100% P <sub>rE</sub> ± 5% P <sub>rE</sub>	100,0 % P <sub>rE</sub>	99,72 % P <sub>rE</sub>
Limit of power gradient [%P <sub>rE</sub> / s]:	0,33 to 0,66	
Inverter remains in operation?	<input checked="" type="checkbox"/> yes	
	<input type="checkbox"/> no	

**Graph of the gradient 5% to 100% PrE**



**5.4.3.5 Measurement priority interfaces / energy management system** **P**

**Test procedural:**

**Test 1 (Measurement priority interfaces)**

**Test 2 (logical interface):**

- Test steps
- a) the PGU is operated with no less than 90%  $P_{rE}$ ;
  - b) the change of state of the logic signal.

**Assessment:**

- Test 1:
- a) The lowest setpoint is always given priority
  - b) the setpoint at the interface programmed for the NSM is never exceeded
- Test 2:
- c) during the examination of the logical interface (input port), the active power feed of the EZE was completely terminated within a maximum of 5 s after the state change of the logical signal.


**Note:**  
The test results of the **MST-BIE5-2500** can be applied to other units in the product series directly, since it is identical in hardware and just power derated by software.

**Test results:**


Test1: The unit provides two communication interfaces for active power reduction.

Interface NSM with Test condition		P/P <sub>rE</sub> (Setpoint)	P/P <sub>rE</sub> (Measured)
Test 1 (Interface low priority Interface WiFi)	Interface WiFi	70%	69,96%
	Interface RS485	90%	
Test 2 (Interface low priority Interface RS485)	Interface WiFi	90%	70,02%
	Interface RS485	70%	

Test 2: Use logical interface to test the result of stopping active power output.



**High level description of logic interface:**  
The PGU equipped with a logic interface for ceasing active power output within 5 s following an instruction being received. The following is a possible configuration (if another configuration is required, this can be agreed with the manufacturer):



where RRCR = Radio Ripple Control Receiver.

The signal from the Power Generating Module that is being switched can be either DC (Voltage value 5 V)

Function description of the terminal:

Pin	Pin name	Description	Connected to(RRCR)
3	GND	Ground	K1-Relay 1 output
6	L1	Relay contact 1 input	K1-Relay 1 output

Relay status: close is 1, open is 0

L1	Pn	Power drop rate	Cos( $\varphi$ )
1	0%	<5s	1
0	100%	--	1


<b>5.4.4 Active power feed-in for PGU's at overfrequency</b>								<b>N/A</b>	
(These tests are designed to provide evidence that the requirements of VDE-AR-N 4105:2018-11 5.7.4.3. and VDE-AR-N 4105:2018-11 8.3.1. are met)									
<b>Test cycle for adjustable PGUs:</b>									
<b>Test 1: MST-BIE5-2500</b>									
Test point:		Expected active power output [% of P <sub>Emax</sub> ]:	Frequency [Hz]:	P <sub>setpoint</sub> [W]:	P <sub>E60</sub> [W]:	P <sub>E60</sub> [% of P <sub>Emax</sub> ]:	ΔP <sub>E60</sub> [%]	Limit ΔP <sub>E60</sub> in %	Available DC-power [%]:
No.	[Hz]								
<b>Measurement: 100% P<sub>Emax</sub>; start frequency 50,20Hz; droop s setting = 5% (40% P<sub>ref</sub>/Hz)</b>									
a)	50,00	100	--	--	--	--	--	≤ ±10% of P <sub>Emax</sub>	--
b)	50,25	98	--	--	--	--	--		
c)	50,70	80	--	--	--	--	--		
d)	51,40	52	--	--	--	--	--		
e)	50,70	80	--	--	--	--	--		
f)	50,25	98	--	--	--	--	--		
g)	50,00	100	--	--	--	--	--		
h)	51,65	0	--	--	--	--	--		
i)	50,15	0	--	--	--	--	--		
j)	50,00	100	--	--	--	--	--		
<b>Frequency Step</b>			<b>Response time [s]</b>			<b>Settling time [s]</b>			
b) → c)			--			--			
c) → d)			--			--			
d) → e)			--			--			
e) → f)			--			--			
Initial time delay T <sub>v</sub> setting value [s]:					Initial time delay T <sub>v</sub> measured value (Determined during frequency step a) → b)) [s]:				
0					--				
<b>Test 2: MST-BIE5-2500</b>									
1-min mean value:		Expected active power output [% of P <sub>Emax</sub> ]:	Frequency [Hz]:	P <sub>setpoint</sub> [W]:	P <sub>E60</sub> [W]:	P <sub>E60</sub> [% of P <sub>Emax</sub> ]:	ΔP <sub>E60</sub> [%]	Limit ΔP <sub>E60</sub> in %	Available DC-power [%]:
No.	[Hz]								
<b>Measurement: 60% P<sub>Emax</sub>; start frequency 50,50Hz; droop s setting = 12% (16,67% P<sub>ref</sub>/Hz)</b>									
a)	50,00	60	--	--	--	--	--	≤ ±10% of P <sub>Emax</sub>	--
b)	50,40	60	--	--	--	--	--		
c)	50,70	58	--	--	--	--	--		
d)	51,40	51	--	--	--	--	--		
e)	50,70	58	--	--	--	--	--		
f)	50,40	60 – 100	--	--	--	--	--		
g)	50,00	100	--	--	--	--	--		

Frequency Step	Response time [s]	Settling time [s]
b) → c)	--	--
c) → d)	--	--
d) → e)	--	--
e) → f)	--	--
Initial time delay $T_V$ setting value [s]:		Initial time delay $T_V$ measured value (Determined during frequency step a) → b)) [s]:
0		--


**DC setting values:**

PV-curve simulated according to	
Voltage of defined MPP [V]	--
Current of defined MPP [A]	--
FFU of PV curve [1]	--
$P_{DC}$ [W]	--


**Graph Test 1@ 100%  $P_{E_{max}}$**



**Gradient Test 1**



**Graph Test2 @ 60% P<sub>E</sub>max**



**Assessment criterion:**

The test is regarded as passed:

**a) for controllable PGU if:**

- The active power reduces between measuring points 5.4.4.1 a) to g) and j), the expected active power output, after settling, adjusts with a deviation  $\leq \pm 10\% P_{E_{max}}$ .

**b) for conditionally adjustable PGU, if:**

- they behave as described in a) inside their control range and
- outside the control range, the power supplied when leaving the control range remains constant until it is switched off
- the connection time in j) and where appropriate in g) corresponds to the manufacturer's information on the random number generator;

NOTE: The Uniform distribution of the disconnection frequency in maximum increments of 0,1 Hz between the end of the control range (at least 50,2 Hz) and 51,5 Hz shall be proofed by a manufacturer's declaration.

**c) for non-adjustable PGU, if**

- a disconnection takes place between 50,2 Hz and 51,5 Hz;
- the connection time in j) and where appropriate in g) corresponds to the manufacturer's information on the random number generator;

NOTE The Uniform distribution of the disconnection frequency in maximum increments of 0,1 Hz between 50,2 Hz and 51,5 Hz shall no active power be given.

- The initial time delay  $T_v$  of the frequency-dependent adaptation of the active power output  $\leq 2$  s.
- The response time of the adaptation of the active power output is a maximum of 8 s (type 1 units and type 2 units with rotating machines) or 2 s (all other type 2 units)
- the settling time of the adaptation of the active power output is a maximum time of 30 s (for type 1 units and for type 2 units with rotating machines) or respectively a maximum time of 20 s (for all other generation units type 2) and
- The connection time at point j) is at least 60 s and the power is then increased with a gradient of  $\leq 10\% P_{E_{max}}/\text{min}$ .
- In the case of generating units with combustion engines or gas turbines, if the criteria for response time and settling time are not met, the test shall be passed, even if the adaptation of active power output occurs with a power gradient of at least  $66\% P_{E_{max}}$  per min (corresponding to  $1,11\% P_{E_{max}}$  per s).

Hz and 51,5 Hz shall be proofed by a manufacturer's declaration.

**d) for linear generators with  $S_{E_{max}} \leq 4,6$  kVA,**

- if they disconnect from the mains at a frequency  $\geq 50,2$  Hz and their maximum upper frequency limit (as specified by the manufacturer), but at the latest when they exceed 51,5 Hz.
- the connection time in j) and where appropriate in g) corresponds to the manufacturer's information on the random number generator;

Subsequently no more resynchronisation/active power feed-in is permitted, also while the frequency 5.4.4.1 i) is maintained (i.e., no running on the characteristic curve as previously tested in a) at g).

**Note:**

The test results of the **MST-BIE5-2500** can be applied to other units in the product series directly, since it is identical in hardware and just power derated by software.

<b>5.4.5 Active power feed-in of Storage systems for overfrequency</b> (These tests are designed to provide evidence that the requirements of VDE-AR-N 4105:2018-11 5.7.4.3. and VDE-AR-N 4105:2018-11 8.3.1. are met)	P
---	---

**Test cycle for adjustable PGUs:**

**Test 1: MST-BIE5-2500**

1-min mean value:		Expected active power output [% of P <sub>E<sub>max</sub></sub> ]:	Frequency [Hz]:	P <sub>setpoint</sub> [W]:	P <sub>E60</sub> [W]:	P <sub>E60</sub> [% of P <sub>E<sub>max</sub></sub> ]:	ΔP <sub>E60</sub> [%]:	Limit  ΔP <sub>E60</sub>   [%P <sub>E<sub>max</sub></sub> ]	SOC [%] *
No.	[Hz]								

**Measurement: 100% P<sub>E<sub>max</sub></sub>; start frequency 50,20Hz; droop s setting = 5% (40% P<sub>E<sub>max</sub></sub>/Hz)**

a)	50,00	100	50,00	2500	2488	99,52	-0,48	≤ 10	85
b)	50,25	98	50,25	2450	2439	97,55	-0,45		83
c)	50,70	80	50,70	2000	1993	79,72	-0,28		82
d)	51,40	52	51,40	1300	1297	51,88	-0,12		82
e)	50,70	80	50,70	2000	1989	79,58	-0,42		81
f)	50,25	98	50,25	2450	2437	97,48	-0,52		81
g)	50,00	100	50,00	2500	2488	99,52	-0,48		80
h)	51,65	0	51,65	0	-22	-0,88	-0,88		79
i)	50,15	0	50,15	0	-23	-0,94	-0,94		79
j)	50,00	100	50,00	2500	2488	99,52	-0,48		74

Frequency Step	Response time [s]	Settling time [s]
b) → c)	0,3	0,5
c) → d)	0,3	0,4
d) → e)	0,4	0,4
e) → f)	0,3	0,4

Initial time delay T <sub>V</sub> setting value [s]:	Initial time delay T <sub>V</sub> measured value (Determined during frequency step a) → b)) [s]:
0	0,2

**Test 2: MST-BIE5-2500**


1-min mean value:		Expected active power output [% of P <sub>E<sub>max</sub></sub> ]:	Frequency [Hz]:	P <sub>setpoint</sub> [W]:	P <sub>E60</sub> [W]:	P <sub>E60</sub> [% of P <sub>E<sub>max</sub></sub> ]:	ΔP <sub>E60</sub> [%]:	Limit  ΔP <sub>E60</sub>   [%P <sub>E<sub>max</sub></sub> ]	SOC [%] *
No.	[Hz]								

**Measurement: 60% P<sub>E<sub>max</sub></sub>; start frequency 50,50Hz; droop s setting = 5% (40% P<sub>E<sub>max</sub></sub>/Hz)**


a)	50,00	60	50,00	1500	1494	59,76	-0,24	≤ 10	95
b)	50,40	60	50,40	1500	1495	59,78	-0,22		94
c)	50,70	52	50,70	1300	1294	51,78	-0,22		93
d)	51,40	24	51,40	600	595	23,78	-0,22		93
e)	50,70	52	50,70	1300	1291	51,64	-0,36		93
f)	50,40	60 - 100	50,40	--	2488	99,53	-0,47		92
g)	50,00	100	50,00	2500	2488	99,52	-0,48		89

Frequency Step	Response time [s]	Settling time [s]
b) → c)	0,2	0,4
c) → d)	0,3	0,4
d) → e)	0,2	0,4
e) → f)	0,2	0,4
Initial time delay $T_V$ setting value [s]:	Initial time delay $T_V$ measured value (Determined during frequency step a) → b)) [s]:	
0	0,2	
<b>DC setting values:</b>		
DC Battery (Source) input current	55	
DC Battery (Source) input voltage	51,2	
$P_{DC-Sum}$ [W]	2816	


Graph Test 1@ 100% P<sub>E</sub>max



Gradient Test 1



**Graph Test2 @ 60% P<sub>Emax</sub>**



**Assessment criterion:**

The test is regarded as passed:

The active power reduces between measuring points in clause 5.4.5.1 a) to g) and j), the expected active power output, after settling, adjusts with a deviation  $\leq \pm 10\% P_{Emax}$ . Deviations arising from the fact that the maximum discharge capacity is less than  $P_{Emax}$  are permissible. In the measuring points h) and i) no active power may be delivered.

The initial time delay  $T_V$  of the frequency-dependent adaptation of the active power output  $\leq 2$  s.

The response time of the adaptation of the active power output is a maximum of 1s

the settling time of the adaptation of the active power output is a maximum time of 30 s (for type 1 units and for type 2 units with rotating machines) or respectively a maximum time of 20 s

- The connection time at point j) is at least 60 s and the power is then increased with a gradient of  $\leq 10\% P_{Emax}/min$ .

**Note:**

\* Results recorded at 1 minute after the transient process of power change completed.

The default LFSM-O curve setting of the **MST-BIE5-0800** to **MST-BIE5-2500** series complies with the requirements for storage units according to VDE-AR-N 4105.

The test results of the **MST-BIE5-2500** can be applied to other units in the product series directly, since it is identical in hardware and just power derated by software.

<b>5.4.6 Active power feed-in for PGUs at underfrequency</b> (These tests are designed to provide evidence that the requirements of VDE-AR-N 4105:2018-11 5.7.4.3. and VDE-AR-N 4105:2018-11 8.3.1. are met) (Not for DC-coupled Storage systems)	<b>N/A</b>
---	------------

**Test cycle for adjustable PGUs:**

**Test 1: MST-BIE5-2500**

1-min mean value:		Expected active power output [% of P <sub>E<sub>max</sub></sub> ]:	Frequency [Hz]:	P <sub>setpoint</sub> [W]:	P <sub>E60</sub> [W]:	P <sub>E60</sub> [% of P <sub>E<sub>max</sub></sub> ]:	ΔP <sub>E60</sub> [%]:	Limit ΔP <sub>E60</sub> in %	Available DC-power [%]:
No.	[Hz]								

**Measurement: 10% P<sub>E<sub>max</sub></sub>; start frequency 49,80Hz; droop s setting = 5% (40% P<sub>ref</sub>/Hz)**

a)	50,00	10	--	--	--	--	--	≤ ±10% of P <sub>E<sub>max</sub></sub>	--
b)	49,75	12	--	--	--	--	--		
c)	48,80	50	--	--	--	--	--		
d)	47,60	98	--	--	--	--	--		
e)	48,80	50	--	--	--	--	--		
f)	49,75	12	--	--	--	--	--		
g)	50,00	10	--	--	--	--	--		
h)	47,35	0	--	--	--	--	--		
i)	47,40	0	--	--	--	--	--		
j)	50,00	10	--	--	--	--	--		

Frequency Step	Response time [s]	Settling time [s]
b) → c)	--	--
c) → d)	--	--
d) → e)	--	--
e) → f)	--	--

Initial time delay T <sub>v</sub> setting value [s]:	Initial time delay T <sub>v</sub> measured value (Determined during frequency step a) → b)) [s]:
0	--

**Test 2: MST-BIE5-2500**

1-min mean value:		Expected active power output [% of P <sub>E<sub>max</sub></sub> ]:	Frequency [Hz]:	P <sub>setpoint</sub> [W]:	P <sub>E60</sub> [W]:	P <sub>E60</sub> [% of P <sub>E<sub>max</sub></sub> ]:	ΔP <sub>E60</sub> [%]:	Limit ΔP <sub>E60</sub> in %	Available DC-power [%]:
No.	[Hz]								


**Measurement: 60% P<sub>E<sub>max</sub></sub>; start frequency 49,80Hz; droop s setting = 5% (40% P<sub>ref</sub>/Hz)**

a)	50,00	60	--	--	--	--	--	≤ ±10% of P <sub>E<sub>max</sub></sub>	--
b)	49,75	62	--	--	--	--	--		
c)	49,20	84	--	--	--	--	--		
d)	48,80	100	--	--	--	--	--		
e)	49,20	84	--	--	--	--	--		
f)	49,85	60	--	--	--	--	--		
g)	50,00	60	--	--	--	--	--		


<b>5.4.6 Active power feed-in for PGUs at underfrequency</b> (These tests are designed to provide evidence that the requirements of VDE-AR-N 4105:2018-11 5.7.4.3. and VDE-AR-N 4105:2018-11 8.3.1. are met) (Not for DC-coupled Storage systems)		<b>N/A</b>
<b>Frequency Step</b>	<b>Response time [s]</b>	<b>Settling time [s]</b>
b) → c)	--	--
c) → d)	--	--
d) → e)	--	--
e) → f)	--	--
Initial time delay $T_V$ setting value [s]:	Initial time delay $T_V$ measured value (Determined during frequency step a) → b)) [s]:	
0	--	
<b>DC setting values:</b>		
PV-curve simulated according to		
Voltage of defined MPP [V]	--	
Current of defined MPP [A]	--	
FFU of PV curve [1]	--	
$P_{DC}$ [W]	--	

<p><b>5.4.6 Active power feed-in for PGUs at underfrequency</b>          (These tests are designed to provide evidence that the requirements of VDE-AR-N 4105:2018-11 5.7.4.3. and VDE-AR-N 4105:2018-11 8.3.1. are met)          (Not for DC-coupled Storage systems)</p>	<p><b>N/A</b></p>
--	-------------------

**Graph Test 1@ 10% P<sub>E</sub>max**




**Gradient Test 1**



<b>5.4.6 Active power feed-in for PGUs at underfrequency</b> (These tests are designed to provide evidence that the requirements of VDE-AR-N 4105:2018-11 5.7.4.3. and VDE-AR-N 4105:2018-11 8.3.1. are met) (Not for DC-coupled Storage systems)	<b>N/A</b>
---	------------

**Graph Test2 @ 60% P<sub>E</sub>max**



<p><b>5.4.6 Active power feed-in for PGUs at underfrequency</b>          (These tests are designed to provide evidence that the requirements of VDE-AR-N 4105:2018-11 5.7.4.3. and VDE-AR-N 4105:2018-11 8.3.1. are met)          (Not for DC-coupled Storage systems)</p>	<p><b>N/A</b></p>
<p><b>Assessment criterion:</b>          The test is regarded as passed:  <u>a) for controllable PGU if:</u></p> <ul style="list-style-type: none"> <li>- The active power reduces between measuring points 5.4.4.1 a) to g) and j), the expected active power output, after settling, adjusts with a deviation <math>\leq \pm 10\% P_{E_{max}}</math>. Deviations according to VDE-AR-N 4105: 2018-11, 5.7.4.3, Figure 13 and due to the technical restrictions described are permissible. In the measuring points h) and i) no active power may be delivered,</li> <li>- The initial time delay <math>T_V</math> of the frequency-dependent adaptation of the active power output <math>\leq 2</math> s.</li> <li>- The response time of the adaptation of the active power output is a maximum of 8 s (type 1 units and type 2 units with rotating machines) or 2 s (all other type 2 units)</li> <li>- the settling time of the adaptation of the active power output is a maximum time of 30 s (for type 1 units and for type 2 units with rotating machines) or respectively a maximum time of 20 s (for all other generation units type 2) and</li> <li>- The connection time at point j) is at least 60 s and the power is then increased with a gradient of <math>\leq 10\% P_{E_{max}} / \text{min}</math>.</li> <li>- In the case of generating units with combustion engines or gas turbines, if the criteria for response time and settling time are not met, the test shall be passed, even if the adaptation of active power output occurs with a power gradient of at least 66% <math>P_{E_{max}}</math> per min (corresponding to 1,11% <math>P_{E_{max}}</math> per s).</li> </ul> <p><u>b) for conditionally adjustable PGU, if:</u></p> <ul style="list-style-type: none"> <li>- they behave as described in a) inside their control range and</li> <li>- no disconnection takes place between 49,8 Hz and 47,5 Hz;</li> <li>- the connection time in j) corresponds to the manufacturer's information on the random number generator;</li> </ul> <p>NOTE: The Uniform distribution of the disconnection frequency in maximum increments of 0,1 Hz between the end of the control range (at least 50,2 Hz) and 51,5 Hz shall be proofed by a manufacturer's declaration.</p> <p><u>c) for non-adjustable PGU, if</u></p> <ul style="list-style-type: none"> <li>- no disconnection takes place between 49,8 Hz and 47,5 Hz;</li> <li>- the connection time in j) corresponds to the manufacturer's information on the random number generator;</li> </ul> <p>NOTE The Uniform distribution of the disconnection frequency in maximum increments of 0,1 Hz between 50,2 Hz and 51.5 Hz shall be proofed by a manufacturer's declaration.</p> <p><u>d) for linear generators with <math>S_{E_{max}} \leq 4,6</math> kVA,</u></p> <ul style="list-style-type: none"> <li>- if they disconnect from the mains at a frequency <math>\leq 49,8</math> Hz and their maximum upper frequency limit (as specified by the manufacturer), but at the latest when they exceed 47,5 Hz.</li> </ul> <p>The connection time in j) corresponds to the manufacturer's information on the random number generator;          Subsequently no more resynchronization/active power feed-in is permitted, also while the frequency 5.4.4.1 i) is maintained (i.e no running on the characteristic curve as previously tested in a) at g).</p> <p>Note:          The test results of the <b>MST-BIE5-2500</b> can be applied to other units in the product series directly, since it is identical in hardware and just power derated by software.</p>	

5.4.7 Active power feed-in for Storage systems at underfrequency										P
(These tests are designed to provide evidence that the requirements of VDE-AR-N: 4105:2018-11 5.7.4.3. and VDE-AR-N 4105:2018-11 8.3.1. are met)										
Test cycle for adjustable PGUs:										
Test 1: MST-BIE5-2500										
1-min mean value:		Expected active power output [% of P <sub>n</sub> ]:	Frequency [Hz]:	P <sub>setpoint</sub> [W]:	P <sub>E60</sub> [W]:	P <sub>E60</sub> [% of P <sub>n</sub> ]:	ΔP <sub>E60</sub> [%]:	Limit  ΔP <sub>E60</sub>   [%P <sub>n</sub> ]	SOC [%] *	Available active power in charging or discharging mode [%P <sub>n</sub> ]
No.	[Hz]									
<b>Measurement: -100% P<sub>Emax</sub>; start frequency 49,80Hz; droop s setting = 2% (100% P<sub>Emax</sub>/Hz)</b>										
a)	50,00	-100	50,00	-2500	-2541	-101,64	-1,64	≤ 10	70	-110
b)	49,75	-95	49,75	-2375	-2415	-96,60	-1,60		71	-110
c)	48,80	0	48,80	0	-33	-1,32	-1,32		72	+110
d)	47,60	100	47,60	2500	2487	99,48	-0,52		72	+110
e)	48,80	0	48,80	0	-15	-0,60	-0,60		71	+110
f)	49,85	-100	49,85	-2500	-2532	-101,28	-1,28		71	-110
g)	50,00	-100	50,00	-2500	-2542	-101,68	-1,68		73	-110
h)	47,35	0	47,35	0	-24	-0,96	-0,96		73	+110
i)	47,40	0	47,40	0	-24	-0,96	-0,96		73	+110
j)	50,00	-100	50,00	-2500	-2541	-101,64	-1,64		78	-110
Frequency Step				Response time [s]				Settling time [s]		
b) → c)				0,4				1,0		
c) → d)				0,4				1,6		
d) → e)				0,6				1,0		
e) → f)				0,4				1,0		
Initial time delay T <sub>V</sub> setting value [s]:						Initial time delay T <sub>V</sub> measured value (Determined during frequency step a) → b)) [s]:				
0						0,2				
Test 2: MST-BIE5-2500										
1-min mean value:		Expected active power output [% of P <sub>n</sub> ]:	Frequency [Hz]:	P <sub>setpoint</sub> [W]:	P <sub>E60</sub> [W]:	P <sub>E60</sub> [% of P <sub>n</sub> ]:	ΔP <sub>E60</sub> [%]:	Limit  ΔP <sub>E60</sub>   [%P <sub>n</sub> ]	SOC [%] *	Available active power in charging or discharging mode [%P <sub>n</sub> ]
No.	[Hz]									
<b>Measurement: 10% P<sub>Emax</sub>; start frequency 49,80Hz; droop s setting = 2% (100% P<sub>Emax</sub>/Hz)</b>										
a)	50,00	10	50,00	250	250	10,00	0,00	≤ 10	77	+110
b)	49,75	15	49,75	375	374	14,96	-0,04		76	+110
c)	48,80	100	48,80	2500	2488	99,52	-0,48		76	+110
d)	47,60	100	47,60	2500	2495	99,80	-0,20		75	+110


5.4.7 Active power feed-in for Storage systems at underfrequency (These tests are designed to provide evidence that the requirements of VDE-AR-N: 4105:2018-11 5.7.4.3. and VDE-AR-N 4105:2018-11 8.3.1. are met)									P		
e)	48,80	100	48,80	2500	2496	99,84	-0,16		74	+110	
f)	49,85	10	49,85	250	259	10,36	0,36		73	+110	
g)	50,00	10	50,00	250	249	9,96	-0,04		73	+110	
Frequency Step				Response time [s]				Settling time [s]			
b) → c)				0,4				1,0			
c) → d)				0,2				0,4			
d) → e)				0,2				0,4			
e) → f)				0,6				1,0			
Initial time delay $T_V$ setting value [s]:						Initial time delay $T_V$ measured value (Determined during frequency step a) → b)) [s]:					
0						0,2					
DC setting values:											
DC Battery (Source) input current						55					
DC Battery (Source) input voltage						51,2					
$P_{DC-Sum}$ [W]						2816					

**5.4.7 Active power feed-in for Storage systems at underfrequency**


(These tests are designed to provide evidence that the requirements of VDE-AR-N: 4105:2018-11 5.7.4.3. and VDE-AR-N 4105:2018-11 8.3.1. are met)

**P**

**Graph Test 1@ -100% P<sub>Emax</sub>**




**Gradient Test 1**



<p><b>5.4.7 Active power feed-in for Storage systems at underfrequency</b>          (These tests are designed to provide evidence that the requirements of VDE-AR-N: 4105:2018-11 5.7.4.3. and VDE-AR-N 4105:2018-11 8.3.1. are met)</p>	<b>P</b>
--	----------

**Graph Test2 @ 10% P<sub>E<sub>max</sub></sub>**



**Assessment criterion:**  
 The test is regarded as passed if the Storage system:


- The active power reduces between measuring points 5.4.7.1 a) and j), the expected active power output, after settling, adjusts with a deviation  $\leq \pm 10\% P_{E_{max}}$ . Deviations arising from the fact that the maximum discharge capacity is less than  $P_{E_{max}}$  are permissible. In the measuring points h) and i) no active power may be delivered.
- The initial time delay  $T_V$  of the frequency-dependent adaptation of the active power output  $\leq 2s$ .
- The response time of the adaptation of the active power output /-consumption is a maximum of 1s and;
- the settling time of the adaptation of the active power output /-consumption is a maximum time of 20s
- The connection time at point j) is at least 60s and the power is then increased with a gradient of  $\leq \pm 10\% P_{E_{max}}/min$ .

**Note:**  
 \* Results recorded at 1 minute after the transient process of power change completed.  
 The default LFSM-U curve setting of the **MST-BIE5-0800** to **MST-BIE5-2500** series complies with the requirements for storage units according to VDE-AR-N 4105.  
 The test results of the **MST-BIE5-2500** can be applied to other units in the product series directly, since it is identical in hardware and just power derated by software.

<b>5.4.8 Static voltage stability / reactive power supply</b>						
The test serves as verification of the reactive power mode according to VD-AR-N 4105: 2018-11, 5.7.2 of the PGU in normal operation.						
<b>5.4.8.2 Tests of the Reactive power / cos <math>\phi</math> setting accuracy</b>						<b>P</b>
<b>Setting values</b>	cos $\phi$ under-excited			0,95	0,98	
	cos $\phi$ over-excited			0,95	0,98	
<b>Test: MST-BIE5-2500</b>						
60 s mean value	0,9 U <sub>n</sub>		U <sub>n</sub>		1,1 U <sub>n</sub>	
Active power	40 – 60% P <sub>E60</sub>	S <sub>E60</sub>	40 – 60% P <sub>E60</sub>	S <sub>E60</sub>	40 – 60% P <sub>E60</sub>	S <sub>E60</sub>
<b>cos <math>\phi</math> 0,95 over-excited</b>						
U [V]	206,64	206,52	229,66	229,54	252,66	252,58
P <sub>E60</sub> [W]	1257	2363	1251	2368	1251	2370
Q <sub>E60</sub> [Var]	414	779	413	788	414	784
S <sub>E60</sub> [VA]	1324	2488	1317	2496	1317	2497
COS $\phi$ <sub>E60</sub> over-excited	0,950	0,950	0,949	0,949	0,949	0,949
Q <sub>expected</sub> [Var]	413	777	411	779	411	780
$\Delta$ Q <sub>E60</sub> [%]	0,01	0,06	0,09	0,36	0,09	0,19
<b>cos <math>\phi</math> 0,95 under-excited</b>						
U [V]	206,62	206,51	229,64	229,53	252,66	252,56
P <sub>E60</sub> [W]	1255	2374	1246	2372	1247	2373
Q <sub>E60</sub> [Var]	-415	-781	-414	-784	-412	-784
S <sub>E60</sub> [VA]	1322	2499	1313	2498	1314	2499
COS $\phi$ <sub>E60</sub> under-excited	0,950	0,950	0,949	0,950	0,950	0,950
Q <sub>expected</sub> [Var]	-413	-780	-410	-780	-410	-780
$\Delta$ Q <sub>E60</sub> [%]	0,08	0,04	0,16	0,14	0,06	0,15
<b>cos <math>\phi</math> 0,98 over-excited</b>						
U [V]	206,64	206,52	229,66	229,55	252,67	252,59
P <sub>E60</sub> [W]	1256	2443	1247	2445	1250	2448
Q <sub>E60</sub> [Var]	256	500	258	508	258	502
S <sub>E60</sub> [VA]	1282	2494	1273	2497	1276	2499
COS $\phi$ <sub>E60</sub> over-excited	0,980	0,980	0,979	0,979	0,979	0,980
Q <sub>expected</sub> [Var]	255	496	253	497	254	497
$\Delta$ Q <sub>E60</sub> [%]	0,05	0,14	0,20	0,44	0,15	0,18

cos φ 0,98 under-excited						
U [V]	206,64	206,52	229,65	229,54	252,66	252,57
P <sub>E60</sub> [W]	1255	2444	1245	2445	1248	2447
Q <sub>E60</sub> [Var]	-258	-500	-258	-502	-254	-501
S <sub>E60</sub> [VA]	1281	2495	1271	2496	1274	2498
cos φ <sub>E60</sub> under-excited	0,979	0,980	0,979	0,980	0,980	0,980
Q <sub>expected</sub> [Var]	-255	-496	-253	-497	-253	-497
ΔQ <sub>E60</sub> [%]	0,14	0,14	0,20	0,19	0,04	0,14

**Graph: Q/P diagram**



**Test:**

applies for PGUs Type 2 - only inverter  $\Sigma S_{E_{max}} \leq 4,6$  kVA

a) and b) For cos φ 0,95 over-excited and φ 0,95 under-excited, the active power will be measured at value between 40% P<sub>E<sub>max</sub></sub> and 60% and S<sub>E<sub>max</sub></sub> and a second time,

for cos φ 0,98 over-excited and φ 0,98 under-excited, the active power will be measured at a value between 40% P<sub>E<sub>max</sub></sub> and 60% and S<sub>E<sub>max</sub></sub>

applies for PGUs Type 2 - only inverter  $\Sigma S_{E_{max}} \geq 4,6$  kVA

c) and d) For cos φ 0,90 over-excited and φ 0,90 under-excited, the active power will be measured at value between 40% P<sub>E<sub>max</sub></sub> and 60% and S<sub>E<sub>max</sub></sub> and a second time,

for cos φ 0,95 over-excited and φ 0,95 under-excited, the active power will be measured at a value between 40% P<sub>E<sub>max</sub></sub> and 60% and S<sub>E<sub>max</sub></sub>

applies PGUs Type 1 as well as for type 2 plants with Stirling generators and fuel cells  $\Sigma S_{E_{max}} \leq 4,6$  kVA

e) without specification of the cos φ the active power will be measured at value between 40% P<sub>E<sub>max</sub></sub> and 60% and S<sub>E<sub>max</sub></sub>.

applies for PGUs Type 1 as well as for type 2 plants with Stirling generators and fuel cells  $\Sigma S_{E_{max}} > 4,6$  kVA

f) and g) For  $\cos \varphi$  0,95 over-excited and  $\cos \varphi$  0,95 under-excited, the active power will be measured at value between 40%  $P_{E_{max}}$  and 60% and  $S_{E_{max}}$  and a second time,  
for  $\cos \varphi$  0,98 over-excited and  $\varphi$  0,98 under-excited, the active power will be measured at a value between 40%  $P_{E_{max}}$  and 60% and  $S_{E_{max}}$

applies for PGUs Type 2 Asynchronous generators:

h) without specification of the  $\cos \varphi$  the active power will be measured at value  $S_{E_{max}}$ . The test is performed only at  $U_n$ .

**Assessment criterion:**

applies for PGUs Type 2 - only inverter  $\Sigma S_{E_{max}} \leq 4,6$  kVA

The Q setpoint is calculated by using the required  $\cos \varphi$  setpoint one time at 0.95 and one time at 0,98 and the measured apparent power of the fundamental. The test is passed if all the Q 60 s mean values of the fundamental component for a) are in the range of Q set point  $\pm 4\%$   $P_{E_{max}}$  overexcited and for b) in the range of Q set point  $\pm 4\%$   $P_{E_{max}}$  under-excited. In addition, a setting of the  $\cos \varphi$  must be possible within a step size of at least 0.01.

applies for PGUs Type 2 - only inverter  $\Sigma S_{E_{max}} \geq 4,6$  kVA

The Q setpoint is calculated by using the required  $\cos \varphi$  setpoint one time at 0.90 and one time at 0,95 and the measured apparent power of the fundamental. The test is passed if all the Q 60 s mean values of the fundamental component for a) are in the range of Q set point  $\pm 4\%$   $P_{E_{max}}$  overexcited and for c) in the range of Q set point  $\pm 4\%$   $P_{E_{max}}$  under-excited. In addition, a setting of the  $\cos \varphi$  must be possible within a step size of at least 0.01.

applies for PGUs Type 1 as well as for type 2 plants with Stirling generators and fuel cells  $\Sigma S_{E_{max}} \leq 4,6$  kVA

The Q setpoint is calculated by using the required  $\cos \varphi$  setpoint one time at 0.95 and one time at 0,98 and the measured apparent power of the fundamental. The test is passed if all the Q 60 s mean values of the fundamental from e) are in the range Q maximal overexcited till Q minimal under-excited.

applies for PGUs Type 1 as well as for type 2 plants with Stirling generators and fuel cells  $\Sigma S_{E_{max}} \geq 4.6$  kVA

The Q setpoint is calculated by using the required  $\cos \varphi$  setpoint one time at 0.95 and one time at 0,98 and the measured apparent power of the fundamental. The test is passed if all the Q 60 s mean values of the fundamental component for a) are in the range of Q set point  $\pm 4\%$   $P_{E_{max}}$  overexcited and for f) in the range of Q set point  $\pm 4\%$   $P_{E_{max}}$  under-excited. In addition, a setting of the  $\cos \varphi$  must be possible within a step size of at least 0.01.

applies for PGUs Type 1 Asynchronous generators:

The test is passed if the  $\cos \varphi$  Q 60 s mean values of h) is in the range  $\cos \varphi = 0,95$  under excited  $\pm 0,02$ .


**Note:**

$\cos \varphi$  Minimum step size: 0,01.

The test results of the **MST-BIE5-2500** can be applied to other units in the product series directly, since it is identical in hardware and just power derated by software.

<b>The regulating and control behavior of the reactive power</b>	<b>P</b>
--	----------

The regulating or control behaviour of the reactive power is based on the PT-1 behaviour shown in Figure 10. Each reactive power value, which results from the control behaviour specified by the network operator, can be set between 6s and 60s (for Type 1 between 10s and 60s). The signal runtime includes the detection of the mains voltage or the active and reactive power.



**Figure 10 - Illustration at 3 tau = 10 s**

**Comment:**

The regulation and control behaviour according to PT-1 is implemented and checked for all reactive power control modes.

<b>5.4.8.3 Test of the displacement factor/active power characteristic curve <math>\cos \phi</math> (P)</b> The test serves as verification of the standard $\cos \phi$ (P) curve according to VDE-AR-N 4105:2018-11, 5.7.2.4.	<b>P</b>
---	----------

**MST-BIE5-2500**

**Test 1) for conducted PGUs (Battery) - Accuracy (characteristic)**

**Measurement: 20-100-20% P<sub>n</sub>**

P <sub>E</sub> /P [%]	20	100	20
U [V]	229,90	229,81	229,86
P <sub>E30</sub> [W]	484	2367	524
P <sub>E30</sub> of P <sub>E</sub> [%]	19,37	94,69	20,98
Q <sub>E30</sub> [VAr]	25	-730	29
Q <sub>expected</sub>	0	-733	0
$\Delta Q_{E30}$ [%]	1,01	0,09	1,15
$\cos \phi_{E30}$	0,998	0,956	0,998
$\cos \phi_{\text{setpoint of } P_{E30}}$	1,000	0,955	1,000


**Limit**

$\Delta Q_{E30}$ in %	$\leq \pm 4,0\%$ relative to P <sub>E<sub>max</sub></sub>	P
-----------------------	---	---


**DC setting values:**

DC Battery (Source) input current	55
DC Battery (Source) input voltage	51,2
P <sub>DC-Sum</sub> [W]	2816

**Graph of Test 1)**



**Graph of Test 1)**



**Assessment criterion:**


Test 5.4.8.3 (1) and (3) are passed if, for all calculated reactive power values, the maximum deviation between the reactive power setpoint (calculated from the characteristic curve to be verified) and the reactive power actual value at the generator terminals is a maximum of  $\pm 4,0\%$  based on  $P_{E_{max}}$ .

<b>Test 3) supply-dependent PGUs - Accuracy (characteristic curve)</b>									
<b>MST-BIE5-2500</b>									
<b>Measurement: 20-100% P<sub>n</sub></b>									
P <sub>E<sub>max</sub></sub> /P [%]	U [V]	P <sub>E30</sub> [W]	P <sub>E30</sub> of P <sub>n</sub> [%]	Q <sub>E30</sub> [VAr]	Q <sub>expected</sub>	ΔQ <sub>E30</sub> [%]	cos φ <sub>E30</sub>	cos φ <sub>setpoint</sub> of P <sub>E30</sub>	P <sub>DC</sub> [W]
20	229,88	494	19,77	27	0	1,07	0,999	1,000	527
30	229,88	742	29,68	28	0	1,11	0,999	1,000	794
40	229,87	996	39,84	22	0	0,86	0,999	1,000	1061
50	229,86	1249	49,97	-45	0	-1,81	0,999	1,000	1312
60	229,83	1482	59,27	-183	-204	0,85	0,992	0,991	1560
70	229,82	1736	69,42	-343	-347	0,16	0,981	0,981	1813
80	229,80	1991	79,64	-496	-496	-0,01	0,970	0,970	2092
90	229,79	2236	89,42	-643	-647	0,16	0,961	0,961	2341
100	229,80	2367	94,66	-730	-732	0,07	0,956	0,955	2481
<b>Measurement: 100-20% P<sub>n</sub></b>									
P <sub>E<sub>max</sub></sub> /P [%]	U [V]	P <sub>E30</sub> [W]	P <sub>E30</sub> of P <sub>n</sub> [%]	Q <sub>E30</sub> [VAr]	Q <sub>expected</sub>	ΔQ <sub>E30</sub> [%]	cos φ <sub>E30</sub>	cos φ <sub>setpoint</sub> of P <sub>E30</sub>	P <sub>DC</sub> [W]
100	229,81	2366	94,64	-731	-732	0,05	0,955	0,955	2481
90	229,82	2235	89,38	-644	-647	0,10	0,961	0,961	2342
80	229,83	1990	79,59	-499	-496	-0,13	0,970	0,970	2093
70	229,85	1734	69,37	-346	-347	0,06	0,981	0,981	1814
60	229,85	1481	59,23	-186	-203	0,68	0,992	0,991	1560
50	229,87	1249	49,95	-47	0	-1,86	0,999	1,000	1313
40	229,87	996	39,84	21	0	0,84	0,999	1,000	1039
30	229,88	742	29,68	27	0	1,10	0,999	1,000	795
20	229,88	494	19,78	27	0	1,06	0,999	1,000	527
<b>Limit</b>									
ΔQ <sub>E30</sub> in %	≤ ±4,0% relative to P <sub>E<sub>max</sub></sub>							P	


<b>Test 4): supply-dependent PGUs - Dynamic</b>				
<b>MST-BIE5-2500</b>				
P <sub>E<sub>max</sub></sub> /P <sub>n</sub> [%]	100	40	100	75
U [V]	229,81	229,87	229,81	229,83
P <sub>E30</sub> [W]	2367	983	2367	1850
P <sub>E30</sub> of P <sub>n</sub> [%]	94,68	39,32	94,68	74,00
Q <sub>E30</sub> [Var]	-731	22	-730	-414
Q <sub>expected</sub>	-732	0	-732	-413
ΔQ <sub>E30</sub> [%]	0,06	0,88	0,09	-0,05

cos $\varphi_{E30}$	0,956	1,000	0,956	0,976
cos $\varphi_{\text{setpoint of } P_{E30}}$	0,955	1,000	0,955	0,976
T [s]	--	9,6	9,2	9,8
<b>Limit</b>				
$\Delta Q_{E30}$ in %	$\leq \pm 4,0\%$ relative to $P_{E\text{max}}$			P
<b>DC setting values:</b>				
DC Battery (Source) input current	55			
DC Battery (Source) input voltage	51,2			
$P_{\text{DC-sum}}$ [W]	2816			


Graph of Test 3)




Graph of Test 3): 20% to 100% to 20%




Graph of Test 4): 100% to 40%



Graph of Test 4): 40% to 100%



Graph of Test d): 100% to 75%



**Assessment criterion:**

Test 5.4.8.3 (2) is considered to have been passed if the PGU meets the requirements for the performance gradient in VDE AR-N 4105: 2018-11, 5.7.4.2.

Test 5.4.8.3 (4) is passed if the step response of the reactive power in test steps c) and e) shows PT1 behaviour according to VDE-AR-N 4105: 2018-11, 5.7.2.5 and for test step d) optionally the power gradient lies between the limits defined in VDE AR-N 4105: 2018-11, 5.7.4.1 or the step response of the reactive power also has PT1 behaviour according to VDE-AR-N 4105: 2018-11, 5.7.2.5.

**Note:**

The test results of the **MST-BIE5-2500** can be applied to other units in the product series directly, since it is identical in hardware and just power derated by software.

<b>5.4.8.4 Test the reactive power-voltage characteristic Q(U)</b>							
The validation of the Q (U) regulation according to VDE-AR-N 4105: 2018-05, 5.7.2.4 is divided into two partial tests, so that on the one hand the accuracy and on the other hand the dynamics of the Q (U) control is checked. For all inverter-coupled systems, only the inverter must be tested.							
<b>5.4.8.4.1 Test of the reactive power-voltage characteristic Q(U)</b>							<b>N/A</b>
<b>Voltage steps</b>	<b>[Vac] L1</b>	<b>[Vac] L2</b>	<b>[Vac] L3</b>	<b>P<sub>start</sub> [W]</b>	<b>Q<sub>measured</sub> [VAr]</b>	<b>Q<sub>setting</sub> [VAr]</b>	<b>ΔQ [%Pn]</b>
100	--	--	--	--	--	--	--
99	--	--	--	--	--	--	--
98	--	--	--	--	--	--	--
97	--	--	--	--	--	--	--
96	--	--	--	--	--	--	--
95	--	--	--	--	--	--	--
94	--	--	--	--	--	--	--
93	--	--	--	--	--	--	--
92	--	--	--	--	--	--	--
91	--	--	--	--	--	--	--
90	--	--	--	--	--	--	--
91	--	--	--	--	--	--	--
92	--	--	--	--	--	--	--
93	--	--	--	--	--	--	--
94	--	--	--	--	--	--	--
95	--	--	--	--	--	--	--
96	--	--	--	--	--	--	--
97	--	--	--	--	--	--	--
98	--	--	--	--	--	--	--
99	--	--	--	--	--	--	--
100	--	--	--	--	--	--	--
101	--	--	--	--	--	--	--
102	--	--	--	--	--	--	--
103	--	--	--	--	--	--	--
104	--	--	--	--	--	--	--
105	--	--	--	--	--	--	--
106	--	--	--	--	--	--	--
107	--	--	--	--	--	--	--
108	--	--	--	--	--	--	--
109	--	--	--	--	--	--	--


110	--	--	--	--	--	--	--
109	--	--	--	--	--	--	--
108	--	--	--	--	--	--	--
107	--	--	--	--	--	--	--
106	--	--	--	--	--	--	--
105	--	--	--	--	--	--	--
104	--	--	--	--	--	--	--
103	--	--	--	--	--	--	--
102	--	--	--	--	--	--	--
101	--	--	--	--	--	--	--
100	--	--	--	--	--	--	--

**Assessment criterion:**

To pass the Q (U) accuracy test, the measured stationary value pairs  $U_{PGU}$  and  $Q_{PGU}$ , taking account to the correct sign in the consumer metering system, must be within VDE-AR-N 4105: 2018-11, in 5.7.2.4, Figure 7 Q (U) shown characteristic. The stationary value pairs  $U_{PGU}$  and  $Q_{PGU}$  are determined by averaging over 30 seconds at the end of the respective measuring section analogously to Chapter 5.4.3.2. The permissible deviations are with the maximum measuring error of the voltage of 1%  $U_n$  stated in VDE-AR-N 4105: 2018-11 and a setting accuracy of 4%  $P_{EMax}$ .

$$Q_{EZE,tol} = \pm(0.01 \cdot U_{N,Y} \cdot k_{QU} + 0.04 \cdot P_{EMax}) = \pm 0,25 \cdot P_{EMax} \cdot (\sin(\arccos(\varphi_{min})) + 0.16).$$

Graph of Q(U) curve



5.4.8.4.2 Test of the dynamics of the Q(U) regulation									N/A
Setting values	Qmax [var]	kQU			X <sub>Netz</sub>	ΔU <sub>ind,Y</sub> [V]	ΔU <sub>kap,Y</sub> [V]	Tau	
	--	--	--	--	--	--	--	3Tau = 10s	
Voltage steps	U <sub>start</sub> [V] L1	U <sub>start</sub> [V] L2	U <sub>start</sub> [V] L3	U <sub>end</sub> [V] L1	U <sub>end</sub> [V] L2	U <sub>end</sub> [V] L3	Q <sub>start</sub> [Var]	Q <sub>end</sub> [Var]	Settling time[s]
Test1:100→106,4	--	--	--	--	--	--	--	--	--
Test2:100→106,4	--	--	--	--	--	--	--	--	--
Test3:100→106,4	--	--	--	--	--	--	--	--	--
Test1:100→93,6	--	--	--	--	--	--	--	--	--
Test2:100→93,6	--	--	--	--	--	--	--	--	--
Test3:100→93,6	--	--	--	--	--	--	--	--	--
PV-curve simulated according to									
Voltage of defined MPP [V]					--				
Current of defined MPP [A]					--				
FFU of PV curve [1]					--				
P <sub>DC</sub> [W]					--				
<b>Assessment criterion:</b>									
<p>For passing the test on the dynamics of the Q (U) control, the measured, time profiles of the reactive power have to be determined in the “positive sequence” Q<sub>PGU</sub> during the entire measuring period in the PT1-like tolerances according to VDE-AR-N 4105: 2018-11, 5.7.2.5. For this purpose, the tolerance bands are entered into the diagram of the respective measurement according to the formulas below. It should be distinguished according to the expected PGU behavior (inductive, capacitive). An exemplary representation of the tolerance bands for the capacitive case is shown in Figure 6. Physically caused compensation processes (for example with type 1 PGU) are to be excluded from the evaluation, if they decay in a time range smaller than one third of the Q (U) - set time. The variable T corresponds to the set - up time of the generating plant and three times the parameterized PT1 time constant Tau (T = 3Tau). The measurement of the time starts at the time of the excitation in 5. 4.8.3.2a) or the manipulation in 5.4.8.3.2 b).</p> <p>Since the increase or decrease of the voltage according to the formula given in 5.4.8.3.2 represents only an approximation to the real behavior of the closed control loop, the steady-state final value Q<sub>set</sub> is determined from the measurement. For this purpose, a 10 - second mean value is formed at the end of the one - minute measurement period via the three - phase reactive power in the positive sequence system. Likewise, the starting value of the reactive power (positive sequence) Q<sub>start</sub> (= offset) before the respective voltage change is determined over a 10-second averaging.</p> <p>The response time of the overall system to be evaluated is measured starting from the excitation according to 5.4.8.3.2 a) or the manipulation according to 5.4.8.3.2 b) until reaching 95% of the steady end value in the positive sequence Q<sub>sol</sub> and is with the factor 5/3 to multiply. This factor takes into account the effect of the feedback on the control dynamics of the Q (U) control and is strongly related to the formula of the net replacement reactance.</p>									

<b>5.5 Testing of NS protection</b>								
<b>5.5.2 NS protection</b>								<b>P</b>
The test for error detection with subsequent shutdown is carried out by means of error simulation, if necessary, with additional error tests (see VDE-AR-N 4105: 2018-11, 6.1).								
<b>5.5.2.1 Functional safety</b>								<b>P</b>
<p><b>Test procedural:</b></p> <ul style="list-style-type: none"> <li>- It should be checked that a single error does not result in the loss of the security function.</li> <li>- Typical errors must be checked, where applicable:             <ul style="list-style-type: none"> <li>a) Error of an AD converter or measuring card for voltage measurement;</li> <li>b) malfunction or freezing of a microprocessor or PLC;</li> <li>c) merging or clamping the contacts of the switching output;</li> <li>d) Overvoltage of the supply voltage;</li> <li>e) Breakage of the line in connecting lines between the measuring input and the control output to the dome switch;</li> <li>f) Failure of the supply voltage (auxiliary voltage).</li> </ul> </li> </ul>								
<p><b>Assessment criterion:</b></p> <ul style="list-style-type: none"> <li>- The NS protection must send a shutdown command to the coupling switch.</li> <li>- If the error is detected, the device is switched off within 10 s after error detection.</li> </ul> <p>If the auxiliary voltage fails with the central NS protection or if the control fails with the integrated NS protection, the switch-off command must be given immediately</p>								
<p><b>Note:</b></p> <p>The errors in the control circuit simulate that the safety is even ensured during a single fault.</p>								
Component No.	Fault	Test condition:		Test time: [min]	Fuse no.[A]	Fault condition:		Result:
		AC	DC			AC	DC	
<b>HAME-PWR-BI2500W V34</b>								
Relay Fault K3B Pin6 and Pin7	short before start-up	Vac 230V	Vdc 51,2V	10min	FU1	Vac 230V	Vdc 51,2V	The inverter cannot start-up. Error message: Relay Sticking. R234/R236, D83 damage. No hazard.
Relay Fault K3B Pin2 and Pin3	short before start-up	Vac 230V	Vdc 51,2V	10min	FU1	Vac 230V	Vdc 51,2V	The inverter cannot start-up. Error message: Relay Sticking. R234/R236, D83 damage. No hazard.
Relay Fault K1B Pin5 and Pin4	short before start-up	Vac 230V	Vdc 51,2V	10min	FU1	Vac 230V	Vdc 51,2V	The inverter cannot start-up. Error message: Relay Sticking No damage. No hazard.
Relay Fault K1B Pin2 and Pin3	short before start-up	Vac 230V	Vdc 51,2V	10min	FU1	Vac 230V	Vdc 51,2V	The inverter cannot start-up. Error message: Relay Sticking No damage. No hazard.
BUS voltage detection circuit R31	Open	Vac 230V	Vdc 51,2V	10min	FU1	Vac 230V	Vdc 51,2V	The inverter immediately disconnection from grid. Error message: the warn light is on, Abnormal Bus Voltage Sampling: No damage. No hazards.
BUS voltage	Short	Vac	Vdc	10min	FU1	Vac	Vdc	The inverter immediately

Component No.	Fault	Test condition:		Test time: [min]	Fuse no.[A]	Fault condition:		Result:
		AC	DC			AC	DC	
<b>HAME-PWR-BI2500W V34</b>								
detection circuit R35		230V	51,2V			230V	51,2V	disconnection from grid. Error message: the warn light is on, Abnormal Bus Voltage Sampling: No damage. No hazards.
BUS voltage detection circuit R37	Short	Vac 230V	Vdc 51,2V	10min	FU1	Vac 230V	Vdc 51,2V	The inverter immediately disconnection from grid. Error message: the warn light is on, Abnormal Bus Voltage Sampling: No damage. No hazards.
BUS voltage detection circuit R39	Open	Vac 230V	Vdc 51,2V	10min	FU1	Vac 230V	Vdc 51,2V	The inverter immediately disconnection from grid. Error message: the warn light is on, Abnormal Bus Voltage Sampling: No damage. No hazards.
GRID voltage detection circuit R106	Short	Vac 230V	Vdc 51,2V	10min	FU1	Vac 230V	Vdc 51,2V	The inverter immediately disconnection from grid. Error message: the warn light is on, Abnormal grid voltage sampling No damage. No hazards.
GRID voltage detection circuit R118	Open	Vac 230V	Vdc 51,2V	10min	FU1	Vac 230V	Vdc 51,2V	The inverter immediately disconnection from grid. Error message: the warn light is on, Abnormal grid voltage sampling No damage. No hazards.
GRID voltage detection circuit R123	Short	Vac 230V	Vdc 51,2V	10min	FU1	Vac 230V	Vdc 51,2V	The inverter immediately disconnection from grid. Error message: the warn light is on, Abnormal grid voltage sampling No damage. No hazards.
GRID voltage detection circuit R123	Open	Vac 230V	Vdc 51,2V	10min	FU1	Vac 230V	Vdc 51,2V	The inverter immediately disconnection from grid. Error message: the warn light is on, Abnormal grid voltage sampling No damage. No hazards.
GRID voltage detection circuit R199	Short	Vac 230V	Vdc 51,2V	10min	FU1	Vac 230V	Vdc 51,2V	The inverter immediately disconnection from grid. Error message: the warn light is on, Abnormal Inverter voltage sampling No damage. No hazards.

Component No.	Fault	Test condition:		Test time: [min]	Fuse no.[A]	Fault condition:		Result:
		AC	DC			AC	DC	
<b>HAME-PWR-BI2500W V34</b>								
GRID voltage detection circuit R199	Open	Vac 230V	Vdc 51,2V	10min	FU1	Vac 230V	Vdc 51,2V	The inverter immediately disconnection from grid. Error message: the warn light is on, Abnormal Inverter voltage sampling No damage. No hazards.
GRID voltage detection circuit R450	Short	Vac 230V	Vdc 51,2V	10min	FU1	Vac 230V	Vdc 51,2V	The inverter immediately disconnection from grid. Error message: the warn light is on, Abnormal Inverter voltage sampling No damage. No hazards.
GRID voltage detection circuit R450	Open	Vac 230V	Vdc 51,2V	10min	FU1	Vac 230V	Vdc 51,2V	The inverter immediately disconnection from grid. Error message: the warn light is on, Abnormal Inverter voltage sampling No damage. No hazards.
BAT voltage detection circuit R30	Short	Vac 230V	Vdc 51,2V	10min	FU1	Vac 230V	Vdc 51,2V	The inverter immediately disconnection from grid. Error message: the warn light is on, Abnormal battery voltage sampling No damage. No hazards.
BAT voltage detection circuit R416	Open	Vac 230V	Vdc 51,2V	10min	FU1	Vac 230V	Vdc 51,2V	The inverter immediately disconnection from grid. Error message: the warn light is on, Abnormal battery voltage sampling No damage. No hazards.
<b>HAME-CTR-BI2500W V35</b>								
Communication fault U45 pin3 to pin2 (VCC5V to VCC3V)	Short	Vac 230V	Vdc 51,2V	10min	FU1	Vac 230V	Vdc 51,2V	The inverter immediately disconnection from grid. Error message: Communication exception No damage. No hazards.
Communication fault Y1 Pin1 and Pin2	Short	Vac 230V	Vdc 51,2V	10min	FU1	Vac 230V	Vdc 51,2V	The inverter immediately disconnection from grid. Error message: Communication exception No damage. No hazards.
Communication fault Y2 Pin1 and Pin2	Short	Vac 230V	Vdc 51,2V	10min	FU1	Vac 230V	Vdc 51,2V	The inverter immediately disconnection from grid. Error message: Communication exception No damage. No hazards.

Component No.	Fault	Test condition:		Test time: [min]	Fuse no.[A]	Fault condition:		Result:
		AC	DC			AC	DC	
<b>HAME-PWR-BI2500W V34</b>								
Communication fault Y2 Pin1 and Pin3	Short	Vac 230V	Vdc 51,2V	10min	FU1	Vac 230V	Vdc 51,2V	The inverter immediately disconnection from grid. Error message: Communication exception No damage. No hazards.
Communication of main CPU U28A Pin93	Open	Vac 230V	Vdc 51,2V	10min	FU1	Vac 230V	Vdc 51,2V	The inverter immediately disconnection from grid. Error message: Communication exception No damage. No hazards.
Communication of slave CPU U9B Pin82	Open	Vac 230V	Vdc 51,2V	10min	FU1	Vac 230V	Vdc 51,2V	The inverter immediately disconnection from grid. Error message: Communication exception No damage. No hazards.
Communication of main CPU U28A CC_GND and CC_MCU_3.3V	Short	Vac 230V	Vdc 51,2V	10min	FU1	Vac 230V	Vdc 51,2V	The inverter immediately disconnection from grid. Error message: Communication exception No damage. No hazards.
Communication of main CPU and slave CPU R399	Open	Vac 230V	Vdc 51,2V	10min	FU1	Vac 230V	Vdc 51,2V	The inverter immediately disconnection from grid. Error message: Communication exception No damage. No hazards.
Communication fault Y3 Pin1 and Pin2	Short	Vac 230V	Vdc 51,2V	10min	FU1	Vac 230V	Vdc 51,2V	The inverter immediately disconnection from grid. Error message: Communication exception No damage. No hazards.
Communication fault Y4 Pin1 and Pin3	Short	Vac 230V	Vdc 51,2V	10min	FU1	Vac 230V	Vdc 51,2V	The inverter immediately disconnection from grid. Error message: Communication exception No damage. No hazards.
Communication fault Y4 Pin1 and Pin2	Short	Vac 230V	Vdc 51,2V	10min	FU1	Vac 230V	Vdc 51,2V	The inverter immediately disconnection from grid. Error message: Communication exception No damage. No hazards.
GRID voltage detection circuit R247	Short	Vac 230V	Vdc 51,2V	10min	FU1	Vac 230V	Vdc 51,2V	The inverter immediately disconnection from grid. Error message: the warn light is on, Abnormal grid voltage sampling

Component No.	Fault	Test condition:		Test time: [min]	Fuse no.[A]	Fault condition:		Result:
		AC	DC			AC	DC	
<b>HAME-PWR-BI2500W V34</b>								
								No damage. No hazards.
GRID voltage detection circuit U21A Pin3 and Pin1	Short	Vac 230V	Vdc 51,2V	10min	FU1	Vac 230V	Vdc 51,2V	The inverter immediately disconnection from grid. Error message: the warn light is on, Abnormal grid voltage sampling No damage. No hazards.
GRID voltage detection circuit R237	Open	Vac 230V	Vdc 51,2V	10min	FU1	Vac 230V	Vdc 51,2V	The inverter immediately disconnection from grid. Error message: the warn light is on, Abnormal grid voltage sampling No damage. No hazards.
GRID voltage detection circuit D58	Short	Vac 230V	Vdc 51,2V	10min	FU1	Vac 230V	Vdc 51,2V	The inverter immediately disconnection from grid. Error message: the warn light is on, Abnormal grid voltage sampling No damage. No hazards.
Inverter voltage detection circuit D65	Short	Vac 230V	Vdc 51,2V	10min	FU1	Vac 230V	Vdc 51,2V	The inverter immediately disconnection from grid. Error message: the warn light is on, Abnormal Inverter voltage sampling No damage. No hazards.
Inverter voltage detection circuit R271	Open	Vac 230V	Vdc 51,2V	10min	FU1	Vac 230V	Vdc 51,2V	The inverter immediately disconnection from grid. Error message: the warn light is on, Abnormal Inverter voltage sampling No damage. No hazards.
Inverter voltage detection circuit U21D Pin12 and Pin14	Short	Vac 230V	Vdc 51,2V	10min	FU1	Vac 230V	Vdc 51,2V	The inverter immediately disconnection from grid. Error message: the warn light is on, Abnormal Inverter voltage sampling No damage. No hazards.
Inverter voltage detection circuit R262	Open	Vac 230V	Vdc 51,2V	10min	FU1	Vac 230V	Vdc 51,2V	The inverter immediately disconnection from grid. Error message: the warn light is on, Abnormal Inverter voltage sampling No damage. No hazards.
DCI detection circuit R250	Open	Vac 230V	Vdc 51,2V	10min	FU1	Vac 230V	Vdc 51,2V	The inverter immediately disconnection from grid. Error message: the warn light is on, Abnormal Inverter DC

Component No.	Fault	Test condition:		Test time: [min]	Fuse no.[A]	Fault condition:		Result:
		AC	DC			AC	DC	
<b>HAME-PWR-BI2500W V34</b>								
								Component Sampling No damage. No hazards.
DCI detection circuit U21C Pin10 and Pin8	Short	Vac 230V	Vdc 51,2V	10min	FU1	Vac 230V	Vdc 51,2V	The inverter immediately disconnection from grid. Error message: the warn light is on, Abnormal Inverter DC Component Sampling No damage. No hazards.
DCI detection circuit R261	Open	Vac 230V	Vdc 51,2V	10min	FU1	Vac 230V	Vdc 51,2V	The inverter immediately disconnection from grid. Error message: the warn light is on, Abnormal Inverter DC Component Sampling No damage. No hazards.
GRID current detection circuit R278	Open	Vac 230V	Vdc 51,2V	10min	FU1	Vac 230V	Vdc 51,2V	The inverter immediately disconnection from grid. Error message: the buzzer will sound an alarm, the warn light is on, Abnormal Output Current Sampling No damage. No hazards.
GRID current detection circuit U22A Pin3 and Pin1	Short	Vac 230V	Vdc 51,2V	10min	FU1	Vac 230V	Vdc 51,2V	The inverter immediately disconnection from grid. Error message: the buzzer will sound an alarm, the warn light is on, Abnormal Output Current Sampling No damage. No hazards.
GRID current detection circuit R280	Open	Vac 230V	Vdc 51,2V	10min	FU1	Vac 230V	Vdc 51,2V	The inverter immediately disconnection from grid. Error message: the buzzer will sound an alarm, the warn light is on, Abnormal Output Current Sampling No damage. No hazards.
BUS voltage detection circuit R40	Open	Vac 230V	Vdc 51,2V	10min	FU1	Vac 230V	Vdc 51,2V	The inverter immediately disconnection from grid. Error message: the warn light is on, Abnormal Bus Voltage Sampling: No damage. No hazards.
BUS voltage detection circuit U22D Pin13 and Pin14	Short	Vac 230V	Vdc 51,2V	10min	FU1	Vac 230V	Vdc 51,2V	The inverter immediately disconnection from grid. Error message: the warn light is on, Abnormal Bus Voltage Sampling: No damage. No hazards.

Component No.	Fault	Test condition:		Test time: [min]	Fuse no.[A]	Fault condition:		Result:
		AC	DC			AC	DC	
<b>HAME-PWR-BI2500W V34</b>								
BUS voltage detection circuit R41	Open	Vac 230V	Vdc 51,2V	10min	FU1	Vac 230V	Vdc 51,2V	The inverter immediately disconnection from grid. Error message: the warn light is on, Abnormal Bus Voltage Sampling: No damage. No hazards.
BAT current detection circuit R48	Open	Vac 230V	Vdc 51,2V	10min	FU1	Vac 230V	Vdc 51,2V	The inverter immediately disconnection from grid. Error message: the warn light is on, Abnormal battery current sampling No damage. No hazards.
BAT current detection circuit U3B Pin6 and Pin7	Short	Vac 230V	Vdc 51,2V	10min	FU1	Vac 230V	Vdc 51,2V	The inverter immediately disconnection from grid. Error message: the warn light is on, Abnormal battery current sampling No damage. No hazards.
BAT current detection circuit R49	Open	Vac 230V	Vdc 51,2V	10min	FU1	Vac 230V	Vdc 51,2V	The inverter immediately disconnection from grid. Error message: the warn light is on, Abnormal battery current sampling No damage. No hazards.
BAT current detection circuit C131	Short	Vac 230V	Vdc 51,2V	10min	FU1	Vac 230V	Vdc 51,2V	The inverter immediately disconnection from grid. Error message: the warn light is on, Abnormal battery current sampling No damage. No hazards.

**Note:**

The errors in the control circuit simulate that the safety is even ensured during a single fault.

The test results of the **MST-BIE5-2500** can be applied to other units in the product series directly, since it is identical in hardware and just power derated by software.

<b>5.5.3 Central NS-protection</b>	<b>N/A</b>
<b>5.5.3.1 Test</b>	<b>N/A</b>
- The auxiliary voltage of the NS protection is switched off	<b>N/A</b>
- The test facility on the NS protection is actuated	<b>N/A</b>
<b>Assessment criterion:</b> The test is considered to have been passed if a signal for the immediate shutdown is generated.	

<p><b>5.5.4 Integrated NS protection</b></p>	<p>P</p>
<p>The integrated NS protection is tested in 5.5.7 and in connection with the examination of the entire NS protection chain and switch.</p>	
<p><b>Note:</b> For test results see 5.5.2.1 Functional safety.</p>	

<b>5.5.6 Interface switch</b>	
<b>5.5.6.1 General</b>	<b>P</b>
These tests serve to demonstrate the requirements of VDE-AR-N 4105: 2018-11, 6.4	
<b>5.5.6.2 Documentation for the design of the central interface switch</b>	<b>N/A</b>
<b>Some details of the central NS protection and the PGU are necessary for the design of a central interface switch. The manufacturer's documentation must therefore contain the following information.</b>	
- maximum operating time of the central interface switch (manufacturer NS protection)	<b>N/A</b>
- Operating time of the protective device (manufacturer NA protection)	<b>N/A</b>
- maximum initial short-circuit alternating current (manufacturer PGU)	<b>N/A</b>
- maximum AC circuit breaker / grid fuse for the PGU (manufacturer PGU)	<b>N/A</b>
- circuit diagram / connection diagram (NS protection / coupling switch) contains the required control and feedback signals (manufacturer NS protection)	<b>N/A</b>
<b>Assessment criterion:</b> The test is considered as pass when the documentation of the manufacturer included the necessary information.	
<b>Note:</b> Information checked in the manual and datasheet for the external NS protection and coupling switch used in the PGU.	

<b>5.5.6.3 Integrated interface switch</b>	<b>P</b>
<b>5.5.6.3.1 Test (functional chain integrated NS-protection and integrated interface switch)</b>	<b>P</b>
<b>Following monitoring options of an interface switch are valid (a) or (b) or (c):</b>	
<b>(a) Use of a interface switch in which a control voltage must be constantly applied when switched on and which switches off automatically when this voltage is not present. The operational switch-on and switch-off processes is monitored</b>	
The disconnection of the control voltage leads to the instantaneous disconnection of the interface switch.	P
A simulated defect during the closing and opening of the interface switch leads to an instantaneous shutdown of the PGU. A restart is not possible.	P
A simulated defect of the interface switch after the NS protection as operated leads to an instantaneous shutdown of the PGU. A restart is not possible.	P
The switch-off time of the whole reaction chain is within 0,2s.	P
<b>(b) The interface switch is switched on and off at least once a day by the NS protection and the proper functioning of the coupling switch is monitored.</b>	
A simulated defect of the interface switch during the daily test leads to an instantaneous shutdown of the PGU. A restart is not possible.	N/A
A simulated defect of the interface switch after the NS protection has operated leads to an instantaneous shutdown of the PGU. A restart is not possible.	N/A
A function for daily switching on and off is available and explained by a manufacturer's declaration.	N/A
<b>(c) Use of the integrated coupling switch and the integrated NA protection for PV and battery converters according to DIN EN 62109 (VDE 0126-14-1).</b>	
The integrated interface switch and NS protection is complied with DIN EN 62109 (VDE 0126-14-1).	N/A
<b>Note:</b> See test results 5.5.2.1 functional safety.	
<b>Relay model: HF140FF-G</b>	
The inverter has a galvanic separating break device. The interface switch is short-circuit proof for the maximum short-circuit current of the power generation unit.	
Max. initial short-circuit current of the PGU (power generation unit)	= 10,9 A, 230 Vac
Max. switching current relay	= 16 A, 250 Vac
Response time of interface switch for integrated NS protection	≤ 15 ms

**Datasheet of the relay (Interface switch):**

Test Relay model: **HF140FF-G**

**HF140FF-G MINIATURE INTERMEDIATE POWER RELAY**

File No.:E134517  
File No.:R50149131  
File No.:CQC10002048173

**Features**

- 16A switching capability
- 5kV dielectric strength (between coil and contacts)
- 2.0mm contact gap available
- Plastic sealed and flux proofed types available
- Sockets available
- UL insulation system:Class F

RoHS compliant

**CONTACT DATA**

Contact arrangement	2A, 2C
Contact resistance	100mΩ max.(at 1A 6VDC)
Contact material	AgSnO <sub>2</sub>
Contact rating (Res. load)	16A 250VAC
Max. switching voltage	250VAC
Max. switching current	16A
Max. switching power	4000VA
Mechanical endurance	W type: 1 x10 <sup>6</sup> ops
Electrical endurance	W type(1.5mm)-2ZWTF: NO 3 x 10 <sup>4</sup> ops, NC 1 x 10 <sup>4</sup> ops (Resistive load, 1s on 9s off)
	W type(2.0mm)-2ZWTF(456): NO 3 x 10 <sup>4</sup> ops, NC 6 x 10 <sup>3</sup> ops (Resistive load, 1s on 9s off)

Notes: 1) The data shown above are initial values.  
2) For plastic sealed type, the venting-hole should be excised in electrical endurance test.  
3) Large gap (W type) products: the ambient temperature of the relay is -40°C - 75°C; (When used at 75°C - 85°C, step-down maintenance is required: applying rated voltage for 200ms firstly to ensure stable connection, then reduce to and maintain 45-65% of rated voltage.)

**CHARACTERISTICS**

Insulation resistance	1000MΩ (at 500VDC)	
Dielectric strength	Between coil & contacts	5000VAC 1min
	Between contacts sets	3000VAC 1min
	Between open contacts	W type:2500VAC 1min
Surge voltage (between coil & contacts)	10kV (1.2/50 μs)	
Operate time (at nomi. volt.)	20ms max.	
Release time (at nomi. volt.)	15ms max.	
Humidity	5% to 85% RH	
Ambient temperature	-40°C to 85°C	
Shock resistance	Functional	98m/s <sup>2</sup>
	Destructive	980m/s <sup>2</sup>
Vibration resistance	10Hz to 55Hz 1.5mmDA	
Termination	PCB	
Unit weight	Approx. 19g	
Construction	Plastic sealed, Flux proofed	

Notes: 1) The data shown above are initial values.

HONGFA RELAY  
ISO9001, IATF16949, ISO14001, ISO45001, IECQ QC 080000, ISO/IEC 27001 CERTIFIED

2024 Rev. 1.00

**SAFETY APPROVAL RATINGS**

UL	16A 250VAC Resistive at 85°C
	1/3HP 125VAC NO/NC, 40°C
	3/4HP 250/240VAC, NO, 40°C TV-5, 125VAC, 40°C
TÜV	16A 250VAC Resistive at 85°C
CQC	16A 250VAC Resistive at 85°C

Notes: 1) All values unspecified are at room temperature.  
2) Only typical loads are listed above. Other load specifications can be available upon request.

**COIL**

Coil power	W type(1.5mm): Approx. 800mW W type(2.0mm): Approx. 1.4W
------------	---

COIL DATA					at 23°C				
W Type (1.5mm)					W Type (2.0mm)				
Nominal Voltage VDC	Pick-up Voltage VDC max.	Drop-out Voltage VDC min.	Max. Allowable Voltage VDC	Coil Resistance Ω	Nominal Voltage VDC	Pick-up Voltage VDC max.	Drop-out Voltage VDC min.	Max. Allowable Voltage VDC	Coil Resistance Ω
3	≤2.40	≥0.15	3.3	11.3 x (1±10%)	3	≤2.40	≥0.15	3.3	6x (1±10%)
5	≤4.00	≥0.25	5.5	31 x (1±10%)	5	≤4.00	≥0.25	5.5	18 x (1±10%)
6	≤4.80	≥0.30	6.6	45 x (1±10%)	6	≤4.80	≥0.30	6.6	26 x (1±10%)
9	≤7.20	≥0.45	9.9	101 x (1±10%)	9	≤7.20	≥0.45	9.9	58 x (1±10%)
12	≤9.60	≥0.60	13.2	180 x (1±10%)	12	≤9.60	≥0.60	13.2	102 x (1±10%)
15	≤12.0	≥0.75	16.5	280 x (1±10%)	15	≤12.0	≥0.75	16.5	160 x (1±10%)
18	≤14.4	≥0.90	19.8	405 x (1±10%)	18	≤14.4	≥0.90	19.8	230 x (1±10%)
24	≤19.2	≥1.20	26.4	720 x (1±10%)	24	≤19.2	≥1.20	26.4	410 x (1±10%)
36	≤28.8	≥1.80	39.6	1620x (1±10%)	36	≤28.8	≥1.80	39.6	925x (1±10%)
48	≤38.4	≥2.40	52.8	2880 x (1±10%)	48	≤38.4	≥2.40	52.8	1650 x (1±10%)
60	≤48.0	≥3.00	66.0	4500 x (1±10%)	60	≤48.0	≥3.00	66.0	2570 x (1±10%)
110	≤88.0	≥5.50	121.0	15100 x (1±10%)	110	≤88.0	≥5.50	121.0	8068 x (1±10%)

- Notes: 1) The data shown above are initial values.  
 2) Maximum voltage refers to the maximum voltage which relay coil could endure in a short period of time.  
 3) In order to meet the stated product performance, please apply rated voltage to coil.  
 4) For the CO version whose contact gap is 1.5 mm/2.0mm, the operation voltage ≤85% of rated voltage, the coil resistance tolerance is (1±15%).


ORDERING INFORMATION	
Type	HF140FF-G/ 024 -2Z S W T G F (XXX)
Coil voltage	3,5,6,9,12,15,18,24,36,48,60,110VDC
Contact arrangement	2H: 2 Form A    2Z: 2 Form C
Construction	S: Plastic sealed    Nil: Flux proofed
Contact Gap	W: Large contact gap
Contact material	T: AgSnO <sub>2</sub>
Contact plating	G: Gold plated    Nil: No gold plated
Insulation standard	F: Class F    Nil: Class F
Special code	XXX: Customer special requirement    Nil: Standard

- Notes: 1) We recommend flux proofed types for a clean environment (free from contaminations like H<sub>2</sub>S, SO<sub>2</sub>, NO<sub>2</sub>, dust, etc.). We suggest to choose plastic sealed types and validate it in real application for an unclean environment (with contaminations like H<sub>2</sub>S, SO<sub>2</sub>, NO<sub>2</sub>, dust, etc.).  
 2) Contact is recommended for suitable condition and specifications if water cleaning or surface process is involved in assembling relays on PCB. SO<sub>2</sub>, NO<sub>2</sub>, dust, etc).  
 3) There are two specifications to W type: 1.5mm contact gap and 2.0mm contact gap. The default W type is 1.5mm. So please add the special code "(456)" when releasing order, if 2.0mm contact gap is required.  
 4) The customer special requirement express as special code after evaluating by Hongfa. e.g.(456) means contact gap can reach 2.0mm.

OUTLINE DIMENSIONS, WIRING DIAGRAM AND PC BOARD LAYOUT

Unit: mm


Outline Dimensions



Wiring Diagram (Bottom view)




PCB Layout (Bottom view)




- Remark: 1) In case of no tolerance shown in outline dimension: outline dimension  $\leq 1\text{mm}$ , tolerance should be  $\pm 0.2\text{mm}$ ; outline dimension  $> 1\text{mm}$  and  $\leq 5\text{mm}$ , tolerance should be  $\pm 0.3\text{mm}$ ; outline dimension  $> 5\text{mm}$ , tolerance should be  $\pm 0.4\text{mm}$ .  
 2) The tolerance without indicating for PCB layout is always  $\pm 0.1\text{mm}$ .  
 3) The width of the gridding is 2.5mm.

**ELECTRICAL DURABILITY WIRING DIAGRAM**



**CHARACTERISTIC CURVES**

**ENDURANCE CURVE**



**Disclaimer**

The specification is for reference only. See to "Terminology and Guidelines" for more information. Specifications subject to change without notice. We could not evaluate all the performance and all the parameters for every possible application. Thus the user should be in a right position to choose the suitable product for their own application. If there is any query, please contact Hongfa for the technical service. However, it is the user's responsibility to determine which product should be used only.

© Xiamen Hongfa Electroacoustic Co., Ltd. All rights of Hongfa are reserved.

<b>5.5.7.2 Check of setting values</b>	<b>P</b>
--	----------

<b>5.5.7.2.1 Test</b>	<b>P</b>
-----------------------	----------

**Test procedural:**

- Before the further tests begin, the factory setting values of the test object must be checked.
- The test object must be reset to factory settings.
- The test object must be put into operation according to the user manual. If an operator input is required, the setting for VDE-ARN 4105:2018 must be selected.

**Assessment criterion:**

- The exam is passed if the following points are met:
- The factory setting values correspond
  - a) With integrated NA protection of VDE-AR-N 4105: 2018-11, 6.5.2 Table 2 (see also Table 36).
  - b) With central NA protection, either the factory settings of VDE-AR-N 4105: 2018-11, 6.5.2, Table 2 (see also Table 36) or these values can be set.
- In the event of an operator input, the test object only goes into operation after settings have been selected.
- The setting values that can be changed according to 4105: 2018-11, 6.5.1 and 6.5.2 can be set within the specified limits and are protected against unauthorized access.
- The setting values that cannot be changed according to VDE-AR-N 4105: 2018-11, 6.5.1 and 6.5.2 cannot be changed or are protected from unauthorized access by an additional separate protection system

**Setting values:**

PGU type	Description	Parameter name	Set value in p.u.	Set value L-N	Set value L-L *2)
	nominal voltage	$U_n$	1	230,0V	400V
	Nominal frequency	$f_n$	1	50Hz	50Hz
a) name set of parameters (Parameter setup name in manual or software)					
<input type="checkbox"/> Stirling generators, fuel cells, coupled directly or via a converter Synchronous and asynchronous generators with $P_n \leq 50$ kW	Excitation threshold $U_{>>}$	N/A	N/A	N/A	N/A
	Delay time $U_{>>}$	N/A	N/A	N/A	N/A
	Excitation threshold $U_{>}$	N/A	N/A	N/A	N/A
	Delay time $U_{>} * 1)$	N/A	N/A	N/A	N/A
	Excitation threshold $U_{<}$	N/A	N/A	N/A	N/A
	Delay time $U_{<}$	N/A	N/A	N/A	N/A
	Excitation threshold $U_{<<}$	N/A	N/A	N/A	N/A
	Delay time $U_{<<}$	N/A	N/A	N/A	N/A
	Excitation threshold $f_{>}$	N/A	N/A	N/A	N/A
	Delay time $f_{>}$	N/A	N/A	N/A	N/A
	Excitation threshold $f_{<}$	N/A	N/A	N/A	N/A
	Delay time $f_{<}$	N/A	N/A	N/A	N/A
b) name set of parameters (Parameter setup name in manual or software)					
<input type="checkbox"/> directly coupled synchronous and asynchronous generators with $P_n > 50$ kW	Excitation threshold $U_{>>}$	N/A	N/A	N/A	N/A
	Delay time $U_{>>}$	N/A	N/A	N/A	N/A
	Excitation threshold $U_{>}$	N/A	N/A	N/A	N/A
	Delay time $U_{>} * 1)$	N/A	N/A	N/A	N/A
	Excitation threshold $U_{<}$	N/A	N/A	N/A	N/A
	Delay time $U_{<}$	N/A	N/A	N/A	N/A

	Excitation threshold U<<	N/A	N/A	N/A	N/A
	Delay time U<<	N/A	N/A	N/A	N/A
	Excitation threshold f>	N/A	N/A	N/A	N/A
	Delay time f>	N/A	N/A	N/A	N/A
	Excitation threshold f<	N/A	N/A	N/A	N/A
	Delay time f<	N/A	N/A	N/A	N/A
c) name set of parameters (Parameter setup name in manual or software)					
☒ Inverter	Excitation threshold U>>	Over Volt 2 [V]	--	287,5	--
	Delay time U>>	OV2 Delay Time [ms]	--	100	--
	Excitation threshold U>	Over Volt 1 [V]	--	253,0	--
	Delay time U> * 1)	OV1 Delay Time [ms] *1)	--	100 *1)	--
	Excitation threshold U<	Under Volt 1 [V]	--	184,0	--
	Delay time U<	UV1 Delay Time [ms]	--	3000	--
	Excitation threshold U<<	Under Volt 2 [V]	--	103,5	--
	Delay time U<<	UV2 Delay Time [ms]	--	300	--
	Excitation threshold f>	Under Freq 1 [Hz]	--	51,5	--
	Delay time f>	UF1 Delay Time [ms]	--	100	--
	Excitation threshold f<	Over Freq 1 [Hz]	--	47,5	--
	Delay time f<	OF1 Delay Time [ms]	--	100	--
*1) 10-min mean value					
*2) testing of external NS-protection					

Factory settings correspond to the values according the Inverter of Table 36 of VDE 0124	P
There are no factory settings. The information on the setting values in the instruction manual correspond to those in Inverter of Table 36 of VDE 0124.	N/A
External NS protection: settings and delay times are password protected settable	N/A
External NS protection: It is possible to read the setting values without a tool	N/A
Integrated NS protection: the setting values are visible via a data interface or display	P
The limit values for U> can be set between 110% and 115% and, in the case of directly coupled synchronous and asynchronous generators with P <sub>rE</sub> >50kW, the time delay for U< and U<< can be set. All other limit values are protected against unauthorized access.	P

<b>5.5.7.3 Wiring check</b>				<b>N/A</b>
<b>5.5.7.3.1 Test</b>				<b>N/A</b>
<b>Test procedural:</b>				
<ul style="list-style-type: none"> <li>- The wiring of the test object must be checked by applying the test voltages.</li> <li>- For single-phase EZE, the wiring test is adapted, only the feed-in phase is to be evaluated.</li> <li>- It must be checked that the test object correctly evaluates line to line voltages and line to neutral conductor voltages. This test step is not applicable for single-phase EZE.</li> </ul>				
<b>Assessment criterion:</b>				
This check is not evaluated. If a phase rotation is detected, it shall be corrected and the test repeated.				
<b>Note:</b>				
<b>Wiring Test Voltage Monitoring and Frequency Monitoring</b>				
<b>Setting values:</b>				
Phase	Voltage [Vac]	Phase angle [°]	Frequency [Hz]	
U L1-E	219,4	0	50,00	
U L2-E	230,9	-120	50,00	
U L3-E	242,5	120	50,00	
<b>Measured values:</b>				
Phase	Voltage [Vac]	Phase angle [°]	Frequency [Hz]	
U L1-E	--	--	--	
U L2-E	--	--	--	
U L3-E	--	--	--	
<b>Checking Voltage Reference Voltage Monitoring and Frequency Monitoring</b>				
<b>Setting values:</b>				
Phase	Voltage [Vac]	Phase angle [°]	Frequency [Hz]	
U L1-E	0	0	50,00	
U L2-E	230,9	150	50,00	
U L3-E	230,9	-150	50,00	
<b>Measured values:</b>				
Phase	Voltage [Vac]	Phase angle [°]	Frequency [Hz]	
U L1-E	--	--	--	
U L2-E	--	--	--	
U L3-E	--	--	--	

<b>5.5.7.4 Voltage and frequency control</b>	<b>P</b>
--	----------

<b>5.5.7.4.1 Voltage and frequency control – Multi Phase</b>	<b>P</b>
--	----------

**Test procedural:**

- For a single-phase EZE, only the feed-in phase needs to be checked.
- Before each test step, the EZE must be operated symmetrically with rated voltage and rated frequency for at least 10 s in feed-in mode.
- The P setpoint was set by RS485 port.

**Assessment criterion:**

- The permitted tolerance between setting value and trip value of the voltage may not exceed  $\pm 1\%$  of  $U_n$ .
- The disconnection time includes disconnect time + operate time of the integrated relay. Therefore, limit is given with +0,100s according to Table 2 set values of the NS-protection according to VDE AR-N 4105:2018.

**Note:**

The test results of the **MST-BIE5-2500** can be applied to other units in the product series directly, since it is identical in hardware and just power derated by software.

**Integrated NS protection multi-phase  $\leq 30\text{kVA}$**

	Setting	Value [V]	Time [ms]	Setting	Value [V]	Time [ms]
Setting values of the NS protection:	U>>	287,5	100			
	U<	184,0	3000	U<<	103,5	300

**Operating time of the monitoring device:**

**MST-BIE5-2500**

<b>L to N:</b>	<b>Under voltage AU&lt; (4.4):</b>			<b>Over voltage AU&gt;&gt; (1.4):</b>		
Ramp [start V to stop V]	>188,6 → <179,4			<282,9 → >292,1		
Step size [V]	<1,15			<1,15		
Step length [s]	>3,200			>0,400		
Limit [V]	$184,0 \pm 1\% U_n$			$287,5 \pm 1\% U_n$		
Measurement [V]	183,2	183,2	183,4	288,2	288,3	288,6

<b>L to N:</b>	<b>Under voltage tU&lt; (5.4):</b>			<b>Over voltage tU&gt;&gt; (2.4):</b>		
Jump [start V to stop V]	>200,1 → <179,4			<282,9 → >292,1		
Step size [V]	>9,2			>9,2		
Step length [s]	>3,200			>0,400		
Limit [s]	$3,000 \leq t \leq 3,100$			$0,100 \leq t \leq 0,200$		
Measurement [s]	3,035	3,039	3,036	0,120	0,142	0,141

<b>L to N:</b>	<b>Under voltage AU&lt;&lt; (6.4):</b>		
Ramp [start V to stop V]	>108,1 → <98,9		
Step size [V]	<1,15		
Step length [s]	>0,500		
Limit [V]	$103,5 \pm 1\% U_n$		
Measurement [V]	103,3	103,2	103,4

<b>L to N:</b>	<b>Under voltage tU&lt;&lt; (7.4):</b>		
Jump [start V to stop V]	>108,1 → <98,9		
Step size [V]	>9,2		
Step length [s]	>0,500		

<b>5.5.7.4 Voltage and frequency control</b>	<b>P</b>
--	----------

<b>5.5.7.4.1 Voltage and frequency control – Multi Phase</b>	<b>P</b>
--	----------

**Test procedural:**

- For a single-phase EZE, only the feed-in phase needs to be checked.
- Before each test step, the EZE must be operated symmetrically with rated voltage and rated frequency for at least 10 s in feed-in mode.
- The P setpoint was set by RS485 port.

**Assessment criterion:**

- The permitted tolerance between setting value and trip value of the voltage may not exceed  $\pm 1\%$  of  $U_n$ .
- The disconnection time includes disconnect time + operate time of the integrated relay. Therefore, limit is given with +0,100s according to Table 2 set values of the NS-protection according to VDE AR-N 4105:2018.

**Note:**

The test results of the **MST-BIE5-2500** can be applied to other units in the product series directly, since it is identical in hardware and just power derated by software.

**Integrated NS protection multi-phase  $\leq 30kVA$**


	Setting	Value [V]	Time [ms]	Setting	Value [V]	Time [ms]
Setting values of the NS protection:	U>>	287,5	100			
	U<<	184,0	3000	U<<	103,5	300

**Operating time of the monitoring device:**


**MST-BIE5-2500**

Limit [s]	$0,300 \leq t \leq 0,400$		
Measurement [s]	0,302	0,335	0,323

**Under voltage AU<: L to N:**




Under voltage AU<<: L to N:



时间 [s]	A	B	间隔
AI 1/U3@TRIONet3_1169 [V]	0:26.95915	0:27.29391	0.33477
AI 1/I3@TRIONet3_1169 [A]	129.0798	61.99932	-67.08050
AI 1/U1@TRIONet3_1169 [V]	7.874859	-0.278700	-8.153558
	0.197887	0.195026	-2.861e-3


Over voltage AU>>: L to N:




时间 [s]	A	B	间隔
AI 1/U1@TRIONet_854 [V]	0:13.7563071	0:13.8979293	0.1416222
AI 1/I2@TRIONet_854 [A]	401.7217	377.9483	-23.77343
AI 1/U2@TRIONet_854 [V]	9.364486	0.597239	-8.767248
	24.60456	0.655665	-23.93890

<b>5.5.7.4 Voltage and frequency control</b>		<b>P</b>
<b>5.5.7.4.1 Measuring the rise-in voltage protection as a running 10-minute mean value</b>		<b>P</b>
Setting values of the NS protection:	Setting U> [V]	253,0
	Setting T <sub>disconnection U&gt;</sub> [s]	600
<p>Note:                  The test results of the <b>MST-BIE5-2500</b> can be applied to other units in the product series directly, since it is identical in hardware and just power derated by software.</p>		
<b>Operating time of the monitoring device:</b>		
L-N:	<b>Over voltage 10-minute mean value (3.1):</b>	
Ramp [start V to stop V]	230,0 → 257,6	
Step size [V]	27,6	
Step length [s]	>600,2	
Limit for disconnection [s]	450 to 550	
Measurement [s]	465s	
L-N:	<b>Over voltage 10-minute mean value (3.2):</b>	
Ramp [start V to stop V]	230,0 → >248,4	
Step size [V]	18,4	
Step length [s]	>600,2	
Limit for reconnection [s]	no disconnection (also after 600s)	
Measurement [s]	No disconnection	
L-N:	<b>Over voltage 10-minute mean value (3.3):</b>	
Ramp [start V to stop V]	243,8 → >262,2	
Step size [V]	18,4	
Step length [s]	>600,2	
Limit for disconnection[s]	225s to 375	
Measurement [s]	248s	


Over voltage 10-minute mean value (3.1):



Over voltage 10-minute mean value (3.2):




Over voltage 10-minute mean value (3.3):




<b>5.5.7.4 Voltage and frequency control</b>				<b>P</b>		
<b>5.5.7.4.1 Voltage and frequency control – Frequency measurement</b>				<b>P</b>		
<b>Test procedural:</b>						
<ul style="list-style-type: none"> <li>- For a single-phase EZE, only the feed-in phase needs to be checked.</li> <li>- Before each test step, the EZE must be operated symmetrically with rated voltage and rated frequency for at least 10 s in feed-in mode.</li> <li>- The P setpoint was set by RS485 port.</li> </ul>						
<b>Assessment criterion:</b>						
<ul style="list-style-type: none"> <li>- The permitted tolerance between setting value and trip value of the voltage may not exceed <math>\pm 1\%</math> of <math>f_n</math>.</li> <li>- The disconnection time includes disconnect time + operate time of the integrated relay. Therefore, limit is given with +0,100s according to Table 2 set values of the NS-protection according to VDE AR-N 4105:2018.</li> </ul>						
Note:						
The test results of the <b>MST-BIE5-2500</b> can be applied to other units in the product series directly, since it is identical in hardware and just power derated by software.						
Setting values of the NS protection:	Setting		Value [Hz]		Time [ms]	
	f<		47,5		100	
	f>		51,5		100	
<b>Operating time of the monitoring device:</b>						
	<b>Under frequency Af&lt; (10.1):</b>			<b>Over frequency Af&gt; (8.1):</b>		
Ramp [start Hz to stop Hz]	47,60 → 47,40			51,40 → 51,60		
Step size [Hz]	<0,025			<0,025		
Step length [s]	>0,4			>0,4		
Limit [Hz]	47,50 $\pm 0,1\% f_n$			51,50 $\pm 0,1\% f_n$		
Measurement [Hz]	47,47	47,48	47,47	51,50	51,50	51,50
	<b>Under frequency Tf&lt; (11.1):</b>			<b>Over frequency Tf&gt; (9.1):</b>		
Jump [start Hz to stop Hz]	47,60 → 47,40			51,40 → 51,60		
Step size [Hz]	>0,2			>0,2		
Step length [s]	>0,4			>0,4		
Limit [s]	0,100 $\leq t \leq 0,200$			0,100 $\leq t \leq 0,200$		
Disconnection time [s]	0,117	0,121	0,117	0,111	0,116	0,112

Under frequency  $A_f < (11.1)$ :



Over frequency  $A_f > (9.1)$ :



**5.5.7.5 Reporting NS protection** **P**

**Test procedural:**

- At least the last 5 error messages can be read at the EZE or the external NA protection.
- The supply voltage must then be interrupted for 3 s.
- The error messages must then be read out again.

**Assessment criterion:**

At least the last 5 error messages including time stamps that were recorded before the voltage interruption and at least 5 error messages including time stamps that were recorded after the voltage interruption must be documented.

**Note:**

The test results of the **MST-BIE5-2500** can be applied to other units in the product series directly, since it is identical in hardware and just power derated by software.

**Picture of 5 last dated failure:**

The screenshot shows a 'Device Fault List' interface. At the top, there is a search bar with 'Host' selected and the value '347004b'. A 'Search' button is next to it. Below the search bar, there is a 'Fault Info' section with a table of fault details:

addr	Host	version	1404	soc	0
reg43	0	reg44	0	reg45	0
add time	2024-11-17,10:25				

Below the 'Fault Info' section, there is a 'Fault List' section with a table of fault events:

No.	Data	Error	Time
1	2530-2575	over voltage fault	2024-11-17,10:38
2	1840-1811	under voltage fault	2024-11-17,10:43
3	5150-5171	over Freq fault	2024-11-17,10:45
4	4750-4733	under Freq fault	2024-11-17,10:49
5	5150-5159	over Freq fault	2024-11-17,10:54
6	5150-5160	over Freq fault	2024-11-17,10:58


<b>5.5.9 Constructional characteristics of NS protection</b>	<b>P</b>
<b>5.5.9.1 General</b>	<b>P</b>
These tests serve to demonstrate the requirements of VDE-AR-N 4105: 2018-11, 6.5.2.	
<b>5.5.9.2 Test</b>	<b>P</b>
Type of NS protection: <input checked="" type="checkbox"/> Internal / <input type="checkbox"/> external	
NS-protection is sealed or a password protection is used (or both)	P
adjustability of U> and the time delays for U< and U<< is given	P
All other protective functions are either permanently protected or protected from unauthorized access by additional, separate protection (example password)	P

<p><b>5.5.10 Islanding detection</b></p>	<p><b>P</b></p>
<p>For power generation systems, islanding detection must be carried out using one of the following processes:</p> <ul style="list-style-type: none"> <li>a) active method, e.g., by means of frequency – shift process (oscillating circuit)</li> <li>b) passive method by means of the three-phase voltage monitoring (possible only for power generation systems without inverters or for single-phase power generation units with inverters). (see 5.4.5.3 3-phase voltage control)</li> </ul> <p>With the passive process, it is important to provide evidence that the power generation unit can be set not equal to 120°.</p>	
<p><b>5.5.10.1 General</b></p>	<p><b>P</b></p>
<p>These tests serve as proof of the requirements of VDE-AR-N 4105: 2018-11, 6.5.3. The maximum switch-off time is 9 s.</p>	

<p><b>5.5.10.2 Passive Islanding detection</b></p>	<p><b>N/A</b></p>
<p>The passive procedure is implemented by the voltage increase and voltage decrease protection of the NS protection.</p>	
<p><b>Note:</b>                  A passive procedure is possible with the help of three-phase voltage monitoring (only for generating units without converter or for single-phase generating units with converter)                  The three-phase voltage monitoring is also permissible with the structural integration of several single-phase generating units that feed into different external conductors, as long as the currents of these generating units are regulated independently of each other so that any phase positions can be set.</p>	


5.5.10.3 Islanding protection according to table 6 - Load imbalance (real, reactive load) for test condition A (PGU output = 100%)									P
Test conditions			Frequency: $50 \pm 1\% f_n$ $U_n = 230 \pm 1\% U_n$ Distortion factor of chokes $\leq 2\%$						
Disconnection limit			2s (IEC 62116)						
No	P <sub>PGU</sub> <sup>1)</sup> [% of PGU rating]	Reactive load [% of QL in 6.1.d) 1]	P <sub>AC</sub> <sup>2)</sup> [% of nominal]	Q <sub>AC</sub> <sup>3)</sup> [% of nominal]	P <sub>PGU</sub> [W]	V <sub>DC</sub> [V]	Q <sub>f</sub> [1]	Run on Time [ms]	Re-marks <sup>5)</sup>
1	100	100	0	0	2500	51,2	1,01	<b>784</b>	Test A at BL
8	100	100	-5	-5	2500	51,2	1,02	324	Test A at IB
9	100	100	-5	0	2500	51,2	1,05	562	Test A at IB
10	100	100	-5	+5	2500	51,2	1,08	194	Test A at IB
13	100	100	0	-5	2500	51,2	0,99	182	Test A at IB
14	100	100	0	+5	2500	51,2	1,03	303	Test A at IB
17	100	100	+5	-5	2500	51,2	0,95	295	Test A at IB
18	100	100	+5	0	2500	51,2	0,96	280	Test A at IB
19	100	100	+5	+5	2500	51,2	0,98	217	Test A at IB
Parameter at 0%			L= 67,39 mH		R= 21,16 Ω		C= 150,51 μF		
I <sub>AC</sub> <sup>4)</sup> [A]			0,078						
<p><b>Note:</b>                      RLC is adjusted to min. +/-1% of the inverter rated output power                      1) P<sub>PGU</sub>: PGU output power                      2) P<sub>AC</sub>: Real power flow at S1 in Figure 1. Positive means power from PGU to utility. Nominal is the 0 % test condition value.                      3) Q<sub>AC</sub>: Reactive power flow at S1 in Figure 1. Positive means power from PGU to utility. Nominal is the 0 % test condition value.                      4) Fundamental of I<sub>AC</sub> when RLC is adjusted                      5) BL: Balance condition, IB: Imbalance condition.                      Condition A:                      PGU output power P<sub>PGU</sub> = Maximum <sup>6)</sup>                      PGU input voltage <sup>6)</sup> ≥ 75% of rated input voltage range  <sup>6)</sup> Maximum PGU output power condition should be achieved using the maximum allowable input power. Actual output power may exceed nominal rated output.  <sup>7)</sup> Based on PGU rated input operating range. For example, If range is between X volts and Y volts, 75 % of range = X + 0,75 × (Y – X). Y shall not exceed 0,8 × PGU maximum system voltage (i.e., maximum allowable array open circuit voltage). In any case, the PGU should not be operated outside of its allowable input voltage range.                      (The energy storage system is tested according to the battery's rated input voltage of 51.2V.)                      The test results of the <b>MST-BIE5-2500</b> can be applied to other units in the product series directly, since it is identical in hardware and just power derated by software.</p>									

Disconnection at P<sub>AC</sub> 0% & Q<sub>AC</sub> 0%




5.5.10.3 Islanding protection according Table 7 – Load imbalance (reactive load) for test condition B (PGU output = 50 % – 66 %)									P
Test conditions			Frequency: 50 ±1% f <sub>n</sub> U <sub>n</sub> = 230 ±1%U <sub>n</sub> Distortion factor of chokes ≤2%						
Disconnection limit			2s (IEC 62116)						
No	P <sub>PGU</sub> <sup>1)</sup> [% of PGU rating]	Reactive load [% of Q <sub>L</sub> in 6.1. <sup>d)1)</sup>	P <sub>AC</sub> <sup>2)</sup> [% of nominal ]	Q <sub>AC</sub> <sup>3)</sup> [% of nominal]	P <sub>PGU</sub> [W]	V <sub>DC</sub> [V]	Q <sub>f</sub> [1]	Run on Time [ms]	Re-marks <sup>5)</sup>
26	66	66	0	-5	1600	51,2	0,96	107	Test B at IB
27	66	66	0	-4	1600	51,2	0,97	116	Test B at IB
28	66	66	0	-3	1600	51,2	0,98	126	Test B at IB
29	66	66	0	-2	1600	51,2	0,98	130	Test B at IB
30	66	66	0	-1	1600	51,2	0,99	157	Test B at IB
31	66	66	0	0	1600	51,2	1,00	548	Test B at BL
32	66	66	0	1	1600	51,2	1,01	169	Test B at IB
33	66	66	0	2	1600	51,2	1,02	156	Test B at IB
34	66	66	0	3	1600	51,2	1,03	139	Test B at IB
35	66	66	0	4	1600	51,2	1,03	138	Test B at IB
36	66	66	0	5	1600	51,2	1,04	127	Test B at IB
Parameter at 0%			L= 105,29mH		R= 33,06 Ω			C= 96,32 μF	
I <sub>AC</sub> <sup>4)</sup> [A]			0,020						
<p><b>Note:</b>                      RLC is adjusted to min. +/-1% of the inverter rated output power                      1) P<sub>PGU</sub>: PGU output power                      2) P<sub>AC</sub>: Real power flow at S1 in Figure 1. Positive means power from PGU to utility. Nominal is the 0 % test condition value.                      3) Q<sub>AC</sub>: Reactive power flow at S1 in Figure 1. Positive means power from PGU to utility. Nominal is the 0 % test condition value.                      4) Fundamental of I<sub>AC</sub> when RLC is adjusted                      5) BL: Balance condition, IB: Imbalance condition.                      Condition B:                      PGU output power P<sub>PGU</sub> = 50 % – 66 % of maximum                      PGU input voltage<sup>6)</sup> = 50 % of rated input voltage range, ±10 %                      6) Based on PGU rated input operating range. For example, If range is between X volts and Y volts, 50 % of range =X + 0,5 × (Y – X). Y shall not exceed 0,8 × PGU maximum system voltage (i.e., maximum allowable array open circuit voltage). In any case, the PGU should not be operated outside of its allowable input voltage range.                      (The energy storage system is tested according to the battery's rated input voltage of 51.2V.)                      The test results of the <b>MST-BIE5-2500</b> can be applied to other units in the product series directly, since it is identical in hardware and just power derated by software.</p>									

Disconnection time at P<sub>AC</sub> 0% and Q<sub>AC</sub> 0%




5.5.10.3 Islanding protection according Table 8 – Load imbalance (reactive load) for test condition C (PGU output = 25 % – 33 %)									P
Test conditions			Frequency: 50 ±1% f <sub>n</sub> U <sub>n</sub> = 230 ±1%U <sub>n</sub> Distortion factor of chokes ≤2%						
Disconnection limit			2s (IEC 62116)						
No	P <sub>PGU</sub> <sup>1)</sup> [% of PGU rating]	Reactive load [% of Q <sub>L</sub> in 6.1.d) <sup>1)</sup>	P <sub>AC</sub> <sup>2)</sup> [% of nominal]	Q <sub>AC</sub> <sup>3)</sup> [% of nominal]	P <sub>PGU</sub> [W]	V <sub>DC</sub> [V]	Q <sub>f</sub> [1]	Run on Time [ms]	Re-remarks <sup>5)</sup>
22	33	33	0	-5	800	51,2	0,96	79	Test C at IB
23	33	33	0	-4	800	51,2	0,96	89	Test C at IB
24	33	33	0	-3	800	51,2	0,97	100	Test C at IB
25	33	33	0	-2	800	51,2	0,98	113	Test C at IB
26	33	33	0	-1	800	51,2	0,99	134	Test C at IB
3	33	33	0	0	800	51,2	1,00	224	Test C at BL
27	33	33	0	1	800	51,2	1,01	141	Test C at IB
28	33	33	0	2	800	51,2	1,02	125	Test C at IB
29	33	33	0	3	800	51,2	1,02	125	Test C at IB
30	33	33	0	4	800	51,2	1,03	117	Test C at IB
31	33	33	0	5	800	51,2	1,00	98	Test C at IB
Parameter at 0%			L= 210,59 mH		R= 66,13 Ω			C= 48,16 μF	
I <sub>AC</sub> <sup>4)</sup> [A]			0,096						
<b>Note:</b>									
RLC is adjusted to min. +/-1% of the inverter rated output power									
1) P <sub>PGU</sub> : PGU output power									
2) P <sub>AC</sub> : Real power flow at S1 in Figure 1. Positive means power from PGU to utility. Nominal is the 0 % test condition value.									
3) Q <sub>AC</sub> : Reactive power flow at S1 in Figure 1. Positive means power from PGU to utility. Nominal is the 0 % test condition value.									
4) Fundamental of I <sub>AC</sub> when RLC is adjusted									
5) BL: Balance condition, IB: Imbalance condition.									
Condition C:									
PGU output power P <sub>PGU</sub> = 25 % – 33 % <sup>6)</sup> of maximum									
PGU input voltage <sup>7)</sup> < 20 % of rated input voltage range									
<sup>6)</sup> Or minimum allowable PGU output level if greater than 33 %.									
<sup>7)</sup> Based on PGU rated input operating range. For example, If range is between X volts and Y volts, 20 % of range =X + 0,2 × (Y – X). Y shall not exceed 0,8 × PGU maximum system voltage (i.e., maximum allowable array open circuit voltage). In any case, the PGU should not be operated outside of its allowable input voltage range.									
(The energy storage system is tested according to the battery's rated input voltage of 51.2V.)									
The test results of the <b>MST-BIE5-2500</b> can be applied to other units in the product series directly, since it is identical in hardware and just power derated by software.									

Disconnection time at  $P_{AC}$  0% and  $Q_{AC}$  0%




5.6.2. Connecting conditions and synchronisation			P
<b>Test: MST-BIE5-2500</b>			
	$f_{ist}$	<b>Reset time:</b>	<b>Limit:</b>
<b>Connecting conditions for frequencies:</b>			
a)	<47,45Hz	No reconnection	No resetting allowed
	Switch to:		
b)	≥47,55Hz	61s	≥60s
c)	>50,15Hz	No reconnection	No resetting allowed
	Switch to:		
d)	≤50,05Hz	61s	≥60s
<b>Connecting conditions for voltages:</b>			
e)	84%	No reconnection	No resetting allowed
	Switch to:		
f)	≥86%	61s	≥60s
g)	111%	No reconnection	No resetting allowed
	Switch to:		
h)	≤109%	64s	≥60s
<b>Test:</b>			
see points a) to h) for the test process.			
The measurement was carried out with a programmable AC source.			
e.g. connecting conditions for frequencies: Point a) and b). The AC source was programmed in such a way that the first step of 230V/50Hz to 230V/47,0Hz resulted in a faulty disconnection. Thereafter the voltage and frequency for 100s is set to 230V/47,45Hz. Switching on again is not permitted. After a lapse of 100s the voltage is set to 230V/47,55Hz. Setting again after 60s is permitted.			
<b>Assessment criterion:</b>			
After actuating the NS protection, it should be checked that the system can only be switched within the tolerance ranges ((80% $U_n \leq U \leq 110\% U_n$ ) and (47,50Hz $\leq f \leq 50,10$ Hz)) at the earliest after 60s after voltage and frequency has remained within the tolerance ranges.			
<b>Note:</b>			
The test results of the <b>MST-BIE5-2500</b> can be applied to other units in the product series directly, since it is identical in hardware and just power derated by software.			


Connecting conditions for frequencies: 47,55Hz




Connecting conditions for frequencies: 50,05Hz



**Connecting conditions for voltages: 86%Un**



**Connecting conditions for voltages: 109%Un**



5.7 Evidence of P<sub>AV,E</sub> -Control

5.7.1 General

N/A

The test serves to prove the requirements of VDE-AR-N 4105: 2018 - 11, 5.5.2. The P<sub>AV,E</sub>-monitoring may, but does not have to be integrated into the PGU. If the P<sub>AV,E</sub>-monitoring is not as a unit built, but distributed over several devices, the entire impact chain is analogous to the examination of NA protection including the communicative Check coupling.




Bild 8 – Skizze des Prüfaufbaus zur Prüfung der Regeldynamik




Bild 1 – Wirkleistungs-Grenzkurve für Erzeugungsanlagen

The PGU with any necessary additional components is installed according to the manufacturer's instructions and parameterized so that the feed limitation P<sub>AV,E</sub> is activated at  $\geq 60\% P_{rE}$ . The power jump can be simulated either by a jump in the primary energy supply or by the fall of a load become:

**a) Primary energy supply jump:** The primary energy supply is adjusted so that the PGU supplies the power  $P_{AV,E} = 60\% P_{rE}$  with a tolerance of -2%. At the time  $t_0$ , the primary energy supply is to be suddenly increased so that the PGU can provide the rated output.

**b) Loss of load:** The PGU is operated at nominal power. Via a load which is to be connected symmetrically to all feeding phases parallel to the PGU, the power at the grid connection point is set to  $P_{AV,E}$  with a tolerance of -2%. At time  $t_0$ , the load is switched off. The elimination of the load can also be simulated by an appropriate offset on the power measurement signal.

The closed loop must not be disconnected. Here, the sum of the effective active values of all 3 phases at the grid connection point must be recorded for at least 15s from the power jump.

**5.7.2.1 Test of control the dynamic**

Parameter setting for testing

The  $P_{AV, E}$  -control power was setting to 60%PrE through the parameter settling limitation feed power of maximum total system power of smart power meter.

For step described of testing

Test a): Primary energy supply jump

- a) The primary energy supply is set so that the EZE feeds the power  $P_{AV, E} = 60\% P_{rE}$  with a tolerance of  $-2\%$ .
- b) At time  $t_0$ , the primary energy supply has to be increased by leaps and bounds so that the EZE can provide the nominal output.
- c) Waiting for the output power were stabilizing (keep at lease 60s) then sudden added the primary supply to nominal power of EZE.

Test b): Loss of load setting:

- d) Adjust load with 40%PrE at least with a tolerance of  $+2\%$  to make the active power at the meter position to be  $P_{AV, E} = 60\%PrE$  with a tolerance of  $-2\%$ .
- e) e) Waiting for the output power were stabilizing (keep at lease 60s) then sudden disconnected the load.

**Assessment criterion:**

The test in accordance with 5.7.2.1 is considered passed if the active power measured at the grid connection point does not exceed the limit curve in VDE-AR-N 4105:2018-11, 5.5.2, Figure 1.

Note:

The test results of the **MST-BIE5-2500** can be applied to other units in the product series directly, since it is identical in hardware and just power derated by software.

5.7.2.1 Test a): Primary energy supply jump				N/A
The primary energy supply is set so that the EZE feeds the power $P_{AV, E} = 60\% PrE$ with a tolerance of $-2\%$ .		Setting the primary supply allows the EZE to reach nominal power		response time [s]
$P_{DC}$ [W]	$P_{SUM}$ [W]	$P_{DC}$ [W]	$P_{SUM}$ [W]	
--	--	--	--	--


5.7.2.1 Test b): Loss of load				N/A
$P_{load}$ [W]	$P_{SUM}$ before disconnect the load [W]	$P_{SUM}$ after disconnect the load [W]	response time [s]	
--	--	--	--	

Note:


$P_{DC}$ : setting value of the primary supply power

$P_{SUM}$ : active power at the meter position

$P_{load}$ : setting value of the load power



5.7.2.2 Test disconnection function				N/A
Test:	P <sub>SUM</sub> before energy jump [W]	Required energy jump [W]	Disconnection time [s]	
a)	--	--	--	
b)	--	--	--	
c)	--	--	--	
d)	--	--	--	



**Assessment criterion:**  
 The test according to 5.7.2.2 shall be deemed to have been passed if, in the case of a), there were no shutdowns and, in the case of b), c) and d), a shutdown after the time t defined in Table 16.


**Table 16**

Test	Rated Power	Limit Disconnect time t
a)	0,98*P <sub>AV,E</sub>	No disconnection
b)	1,02*P <sub>AV,E</sub> – 1,067*P <sub>AV,E</sub>	t < 10s + 0,2s
c)	1,067*P <sub>AV,E</sub> – 1,670*P <sub>AV,E</sub>	t < 3s + 0,2s
d)	1,690*P <sub>AV,E</sub>	t < 0,2s

**Note:**  
 The EUT evaluated and tested the examination of regular dynamics used the P calculation check with a real EZE according to requirement of VDE-AR-N 4105, 5.5.2.  
 The nominal output power of EZE declared by manufacture.

<b>5.8 Evidence dynamic grid support</b>			
<b>5.8.1</b>	General		<b>P</b>
<b>5.8.3</b>	Testing of the dynamic grid support PGU Type 1		<b>N/A</b>
<b>5.8.3</b>	Testing of the dynamic grid support PGU Type 2		<b>P</b>


**FRT test for three-phase symmetrical (Test ref no. x.1.x)**



Typ-A

**LVRT test for two-phase asymmetrical fault (Test ref no. 1.3.x to 4.3.x)**

Test No.	V/V <sub>nom</sub>	Phase-to-earth voltages			Phase angles		
		u <sub>1</sub> /u <sub>1,nom</sub>	u <sub>2</sub> /u <sub>2,nom</sub>	u <sub>3</sub> /u <sub>3,nom</sub>	φ <sub>u1</sub>	φ <sub>u2</sub>	φ <sub>u3</sub>
1.3, 1.4, 1.5	0,15 ± 0,05	0,62 ± 0,05	0,15 ± 0,05	0,62 ± 0,05	-143°	120°	23°
2.3, 2.4, 3.3, 3.4	0,50 ± 0,05	0,76 ± 0,05	0,50 ± 0,05	0,76 ± 0,05	-131°	120°	11°
4.3, 4.4	0,50 ± 0,05	0,93 ± 0,05	0,85 ± 0,05	0,93 ± 0,05	-123°	120°	3°
Normal condition	1	1	1	1	-120°	120°	0°



Typ-D


**FRT test for two-phase asymmetrical fault (Test ref no. 5.3.x to 7.3.x)**

Test No.	V/V <sub>nom</sub>	Phase-to-earth voltages			Phase angles		
		u <sub>1</sub> /u <sub>1,nom</sub>	u <sub>2</sub> /u <sub>2,nom</sub>	u <sub>3</sub> /u <sub>3,nom</sub>	φ <sub>u1</sub>	φ <sub>u2</sub>	φ <sub>u3</sub>
5.3, 5.4	1,25 ± 0,05	1,08 ± 0,05	1,25 ± 0,05	1,06 ± 0,05	-115°	-120°	6°
6.3,6.4	1,20 ± 0,05	1,06 ± 0,05	1,20 ± 0,05	1,05 ± 0,05	-116°	-120°	5°
7.3,7.4	1,15 ± 0,05	1,04 ± 0,05	1,15 ± 0,05	1,04 ± 0,05	-117°	-120°	4°
Normal condition	1	1	1	1	-120°	120°	0°


**FRT test for two-phase asymmetrical fault (Test ref no. x.3.x)**

5.8.1 General

P



Typ-B



Legende

- & — FRT-Kurve für 1-, 2- und 3-polige Netzfehler
- UG Effektivwert der aktuellen Spannung an den Generatorklemmen

**Bild 12 – Fault-Ride-Through-Grenzkurve für den Spannungsverlauf an den Generatorklemmen für eine Erzeugungseinheit vom Typ 2 und für Speicher**

Figure 12 - Fault ride-through limit curve for the voltage curve at the generator terminals for a **type 2** generation unit and for storage

5.8.3 Testing of the dynamic grid support									P
For PGUs Type 2 and storage systems									P
1-phase systems									
MST-BIE5-2500									
Test	Voltage dip to [p.u.]	Dip type	duration [s]	P set point [p.u.]	Q set point [p.u.]	Comment	Recovery response time [s]		Test ref. No.*
							P	Q	
1	0,15 to 0,25	A	for 0,15 ≥0,150 / for 0,25 ≥0,500	1	0 to ± 0,1	Symmetric	0,391	--	1.1
				0,2 to 0,6			0,629	--	1.2
		D1 <sup>1)</sup>	1	Asymmetric (ph-ph + Dy5-transformer)		0,714	--	1.3	
			0,2 to 0,6			0,641	--	1.4	
		D2 <sup>2)</sup>	1			0,707	--	1.5	
2	0,50 to 0,60	A	for 0,50 ≥1,5 / for 0,60 ≥2,000	1	Max. over excited**	Symmetric	0,782	9,960	2.1
				0,2 to 0,6			0,837	9,985	2.2
		D1 <sup>1)</sup>	1	Asymmetric (ph-ph + Dy5-transformer)		0,861	9,935	2.3	
			0,2 to 0,6			0,729	9,925	2.4	
3	0,50 to 0,60	A	for 0,50 ≥1,500 / for 0,60 ≥2,000	1	Max. under excited**	Symmetric	0,850	9,952	3.1
				0,2 to 0,6			0,929	9,869	3.2
		D1 <sup>1)</sup>	1	Asymmetric (ph-ph + Dy5-transformer)		0,820	9,913	3.3	
			0,2 to 0,6			0,940	9,904	3.4	
4	0,85 to 0,90	A	≥60,000	1	0 to ± 0,1	Symmetric	0,067	--	4.1
				0,2 to 0,6			0,060	--	4.2
		D1 <sup>1)</sup>		1		Asymmetric (ph-ph + Dy5-transformer)	0,049	--	4.3
				0,2 to 0,6			0,049	--	4.4
5	1,20 to 1,25	A	≥0,100	1	0 to ± 0,1	Symmetric	0,771	--	5.1
				0,2 to 0,6			0,881	--	5.2
		D1 <sup>1)</sup>		1		Asymmetric (ph-ph + Dy5-transformer)	0,069	--	5.3
				0,2 to 0,6			0,119	--	5.4
		D2 <sup>2)</sup>		1			0,785	--	5.5
6	1,15 to 1,20	A	≥5,000	1	0 to ± 0,1	Symmetric	0,889	--	6.1
				0,2 to 0,6			0,733	--	6.2
		D1 <sup>1)</sup>		1		Asymmetric (ph-ph + Dy5-transformer)	0,063	--	6.3
				0,2 to 0,6			0,060	--	6.4
7	1,10 to 1,15	A	≥60,000	1	0 to ± 0,1	Symmetric	0,064	--	7.1
				0,2 to 0,6			0,064	--	7.2
		D1 <sup>1)</sup>		1		Asymmetric (ph-ph + Dy5-transformer)	0,049	--	7.3
				0,2 to 0,6			0,048	--	7.4

<b>5.8.3 Testing of the dynamic grid support</b>	<b>P</b>
--	----------

**Note:**

At least the recording must begin at least 10s before the error occurs. After a faulty declaration (Voltage in the range  $0,85 U_n \leq U \leq 1,1U_n$ ), the recording must continue for at least another 60s.

Behaviour during the network error:

No disconnection of the PGU during the voltage drops the grid. If the PGU disconnects from the grid, the time of disconnection must be documented.

- Type 2 units and storage systems are not allowed to inject either active or reactive current during a line voltage at the PGUs terminals below  $0,8 U_n$  and above  $1,15 U_n$ . This requirement is met if, in the event of an under-/ under voltage dip, the injected current of the generating unit and / or the storage systems does not exceed 20% of the rated current  $I_r$  and no more than 10%  $I_r$  after 0,06s after the occurrence of this under-/ under voltage dip in any phase.

Behaviour after the end of the error:

- Not disconnection of the PGU within 60s after the end of the fault.
- Type 2 units and storage systems: Reaction time of active power up to 1s, Reaction time of reactive power according to PT1 behaviour with  $3\tau = 10s$  in accordance with VDE-AR-N 4105: 2018-11, 5.7.2.5

Table above shows test sequences for single-phase unit.

- <sup>1)</sup> One-phase EZE are connected to the phase W and N for error pattern D1
- <sup>2)</sup> One-phase EZE are connected to the phase V and N for error pattern D2

“\*\*” The test has been performed twice and only show one times tested result in the test report.


The test results of the **MST-BIE5-2500** can be applied to other units in the product series directly, since it is identical in hardware and just power derated by software.

5.8.3 For PGUs Type 2 and storage systems – no load


P

MST-BIE5-2500

1.1



1.3




5.8.3 For PGUs Type 2 and storage systems – no load


P

MST-BIE5-2500

1.5



2.1




5.8.3 For PGUs Type 2 and storage systems – no load


P

MST-BIE5-2500

2.3



3.1




5.8.3 For PGUs Type 2 and storage systems – no load


P

MST-BIE5-2500

3.3



4.1




5.8.3 For PGUs Type 2 and storage systems – no load


P

MST-BIE5-2500

4.3



5.1




5.8.3 For PGUs Type 2 and storage systems – no load


P

MST-BIE5-2500

5.3



5.5




5.8.3 For PGUs Type 2 and storage systems – no load


P

MST-BIE5-2500

6.1



6.3




5.8.3 For PGUs Type 2 and storage systems – no load


P

MST-BIE5-2500

7.1



7.3



**5.8.3 For PGUs Type 2 and storage systems P**

**MST-BIE5-2500**

**1.1**



Condition						Measured value	
Item	No.	Parameter	Phase ref.	Time ref.	unit		
General Info.	0	Test number	--	--	--	1,1	
	1	Date	--	--	yyyy.mm.dd	2025/9/13	
	2	Time (start of test)	--	--	hh:mm:ss.f	18:12:07	
	3	Fault type (phase)	--	--	--	A	
	4	Setting voltage depth	Line to line	--	--	p.u.	0,15
	5	Setting dip duration	--	--	--	--	150
	6	Point of fault entry	Total	--	--	ms	19769
	7	Point of fault clearance	Total	--	--	ms	19921
	8	Fault duration in empty load test	Total	--	--	ms	152
	9	Voltage depth/height in empty load test	Total (Phase 1)	t1+100ms to t2 and t1-10s to t1	p.u.	0,149	
	10		Total (Phase 2)			0,149	
	11		Total (Phase 3)			0,150	
12	Positive sequence		0,149				
Before dip <t1	13	Voltage	Phase 1	t1-10s to t1	p.u.	0,999	
	14		Phase 2			0,998	
	15		Phase 3			0,999	
	16	Current	Pos.	t1-500ms to t1-100ms	p.u.	0,995	
	17	Active power	Total	t1-10s to t1	p.u.	0,994	
	18		Pos.			0,994	
	19	Reactive power	Total	t1-10s to t1	p.u.	0,015	
	20		Pos.			0,002	
21	Cosφ	Total	t1-10s to t1	--	0,999		
During dip t1 to t2	22	Voltage	Phase 1	t1+100ms to t2-20ms	p.u.	0,149	
	23		Phase 2			0,149	
	24		Phase 3			0,150	
	25	Line current	Phase 1	t1+60ms	p.u.	--	
	26		Phase 2			--	
	27		Phase 3			0,014	
	28	Line current	Phase 1	t1+100ms	p.u.	--	
	29		Phase 2			--	
	30		Phase 3			0,013	
	31	Active power	Total	t1+100ms to t2-20ms	p.u.	0,000	
	32		Pos.			0,000	
After dip > t2	33	Voltage	Phase 1	t2+3s to t2+10s	p.u.	0,999	
	34		Phase 2			0,998	
	35		Phase 3			0,999	
	36	Active power	Total	t2+3s to t2+10s	p.u.	0,994	
	37		Pos.			0,994	
	38	Active power rising time	Total	--	s	0,391	
	39	Reactive power	Total	t2+3s to t2+10s	p.u.	0,016	
	40		Pos.			0,002	
	41	Reactive power rising time	total	--	s	--	
42	PGU does not disconnect from grid till 60s after fault	--	t2 to t2+60s	Yes / No	Yes		

**5.8.3**

**For PGUs Type 2 and storage systems**


**P**

**MST-BIE5-2500**



**5.8.3 For PGUs Type 2 and storage systems P**

**MST-BIE5-2500**




5.8.3		For PGUs Type 2 and storage systems				P	
MST-BIE5-2500							
1.2							
Condition						Measured value	
Item	No.	Parameter	Phase ref.	Time ref.	unit		
General Info.	0	Test number	--	--	--	1,2	
	1	Date	--	--	yyyy.mm.dd	2025/9/13	
	2	Time (start of test)	--	--	hh:mm:ss.f	18:21:41	
	3	Fault type (phase)	--	--	--	A	
	4	Setting voltage depth	Line to line	--	--	p.u.	0,15
	5	Setting dip duration		--	--	--	150
	6	Point of fault entry	Total	--	--	ms	27949
	7	Point of fault clearance	Total	--	--	ms	28100
	8	Fault duration in empty load test	Total	--	--	ms	151
	9	Voltage depth/height in empty load test	Total (Phase 1)	t1+100ms to t2 and t1-10s to t1	p.u.	0,149	
	10		Total (Phase 2)			0,149	
	11		Total (Phase 3)			0,150	
12	Positive sequence		0,149				
Before dip <t1	13	Voltage	Phase 1	t1-10s to t1	p.u.	0,999	
	14		Phase 2			0,998	
	15		Phase 3			1,000	
	16	Current	Pos.	t1-500ms to t1-100ms	p.u.	0,298	
	17	Active power	Total	t1-10s to t1	p.u.	0,298	
	18		Pos.			0,298	
	19	Reactive power	Total	t1-10s to t1	p.u.	0,010	
	20		Pos.			0,003	
21	Cosφ	Total	t1-10s to t1	--	0,999		
During dip t1 to t2	22	Voltage	Phase 1	t1+100ms to t2-20ms	p.u.	0,149	
	23		Phase 2			0,149	
	24		Phase 3			0,150	
	25	Line current	Phase 1	t1+60ms	p.u.	--	
	26		Phase 2			--	
	27		Phase 3			0,013	
	28	Line current	Phase 1	t1+100ms	p.u.	--	
	29		Phase 2			--	
	30		Phase 3			0,013	
	31	Active power	Total	t1+100ms to t2-20ms	p.u.	0,000	
	32		Pos.			0,000	
After dip > t2	33	Voltage	Phase 1	t2+3s to t2+10s	p.u.	0,999	
	34		Phase 2			0,998	
	35		Phase 3			1,000	
	36	Active power	Total	t2+3s to t2+10s	p.u.	0,298	
	37		Pos.			0,298	
	38	Active power rising time	Total	--	s	0,629	
	39	Reactive power	Total	t2+3s to t2+10s	p.u.	0,010	
	40		Pos.			0,003	
	41	Reactive power rising time	total	--	s	--	
	42	PGU does not disconnect from grid till 60s after fault	--	t2 to t2+60s	Yes / No	Yes	

5.8.3

For PGUs Type 2 and storage systems

P

MST-BIE5-2500




**5.8.3**

**For PGUs Type 2 and storage systems**

**P**

**MST-BIE5-2500**




5.8.3		For PGUs Type 2 and storage systems				P	
MST-BIE5-2500							
1.3							
Condition						Measured value	
Item	No.	Parameter	Phase ref.	Time ref.	unit		
General Info.	0	Test number	--	--	--	1,3	
	1	Date	--	--	yyyy.mm.dd	2025/9/13	
	2	Time (start of test)	--	--	hh:mm:ss.f	10:51:53	
	3	Fault type (phase)	--	--	--	D1	
	4	Setting voltage depth	Line to line	--	--	p.u.	0,15
	5	Setting dip duration		--	--	--	150
	6	Point of fault entry	Total	--	--	ms	16120
	7	Point of fault clearance	Total	--	--	ms	16270
	8	Fault duration in empty load test	Total	--	--	ms	150
	9	Voltage depth/height in empty load test	Total (Phase 1)	t1+100ms to t2 and t1-10s to t1	p.u.	0,619	
	10		Total (Phase 2)			0,149	
	11		Total (Phase 3)			0,619	
12	Positive sequence		0,427				
Before dip <t1	13	Voltage	Phase 1	t1-10s to t1	p.u.	0,999	
	14		Phase 2			0,998	
	15		Phase 3			0,999	
	16	Current	Pos.	t1-500ms to t1-100ms	p.u.	1,001	
	17	Active power	Total	t1-10s to t1	p.u.	1,000	
	18		Pos.			1,000	
	19	Reactive power	Total	t1-10s to t1	p.u.	0,041	
	20		Pos.			0,008	
21	Cosφ	Total	t1-10s to t1	--	0,999		
During dip t1 to t2	22	Voltage	Phase 1	t1+100ms to t2-20ms	p.u.	0,619	
	23		Phase 2			0,149	
	24		Phase 3			0,619	
	25	Line current	Phase 1	t1+60ms	p.u.	--	
	26		Phase 2			--	
	27		Phase 3			0,041	
	28	Line current	Phase 1	t1+100ms	p.u.	--	
	29		Phase 2			--	
	30		Phase 3			0,040	
	31	Active power	Total	t1+100ms to t2-20ms	p.u.	0,002	
	32		Pos.			0,002	
After dip > t2	33	Voltage	Phase 1	t2+3s to t2+10s	p.u.	0,999	
	34		Phase 2			0,998	
	35		Phase 3			0,999	
	36	Active power	Total	t2+3s to t2+10s	p.u.	1,000	
	37		Pos.			1,000	
	38	Active power rising time	Total	--	s	0,714	
	39	Reactive power	Total	t2+3s to t2+10s	p.u.	0,042	
	40		Pos.			0,009	
	41	Reactive power rising time	total	--	s	--	
	42	PGU does not disconnect from grid till 60s after fault	--	t2 to t2+60s	Yes / No	Yes	

5.8.3

For PGUs Type 2 and storage systems

P



MST-BIE5-2500



5.8.3 For PGUs Type 2 and storage systems

P

MST-BIE5-2500




5.8.3		For PGUs Type 2 and storage systems				P	
MST-BIE5-2500							
1.4							
Condition						Measured value	
Item	No.	Parameter	Phase ref.	Time ref.	unit		
General Info.	0	Test number	--	--	--	1,4	
	1	Date	--	--	yyyy.mm.dd	2025/9/13	
	2	Time (start of test)	--	--	hh:mm:ss.f	10:56:23	
	3	Fault type (phase)	--	--	--	D1	
	4	Setting voltage depth	Line to line	--	--	p.u.	0,15
	5	Setting dip duration	--	--	--	--	150
	6	Point of fault entry	Total	--	--	ms	36693
	7	Point of fault clearance	Total	--	--	ms	36843
	8	Fault duration in empty load test	Total	--	--	ms	150
	9	Voltage depth/height in empty load test	Total (Phase 1)	t1+100ms to t2 and t1-10s to t1	p.u.	0,619	
	10		Total (Phase 2)			0,149	
	11		Total (Phase 3)			0,620	
12	Positive sequence		0,356				
Before dip <t1	13	Voltage	Phase 1	t1-10s to t1	p.u.	0,999	
	14		Phase 2			0,998	
	15		Phase 3			0,999	
	16	Current	Pos.	t1-500ms to t1-100ms	p.u.	0,299	
	17	Active power	Total	t1-10s to t1	p.u.	0,299	
	18		Pos.			0,299	
	19	Reactive power	Total	t1-10s to t1	p.u.	0,013	
	20		Pos.			0,002	
21	Cosφ	Total	t1-10s to t1	--	0,999		
During dip t1 to t2	22	Voltage	Phase 1	t1+100ms to t2-20ms	p.u.	0,619	
	23		Phase 2			0,149	
	24		Phase 3			0,620	
	25	Line current	Phase 1	t1+60ms	p.u.	--	
	26		Phase 2			--	
	27		Phase 3			0,039	
	28	Line current	Phase 1	t1+100ms	p.u.	--	
	29		Phase 2			--	
	30		Phase 3			0,040	
	31	Active power	Total	t1+100ms to t2-20ms	p.u.	0,002	
32	Pos.		0,002				
	33	Voltage	Phase 1	t2+3s to t2+10s	p.u.	0,999	
	34		Phase 2			0,998	
	35		Phase 3			0,999	
	36	Active power	Total	t2+3s to t2+10s	p.u.	0,299	
	37		Pos.			0,299	
	38	Active power rising time	Total	--	s	0,641	
	39	Reactive power	Total	t2+3s to t2+10s	p.u.	0,013	
	40		Pos.			0,002	
	41	Reactive power rising time	total	--	s	--	
	42	PGU does not disconnect from grid till 60s after fault	--	t2 to t2+60s	Yes / No	Yes	

5.8.3

For PGUs Type 2 and storage systems



P

MST-BIE5-2500



5.8.3 For PGUs Type 2 and storage systems P

MST-BIE5-2500




5.8.3		For PGUs Type 2 and storage systems				P	
MST-BIE5-2500							
1.5							
Condition						Measured value	
Item	No.	Parameter	Phase ref.	Time ref.	unit		
General Info.	0	Test number	--	--	--	1,5	
	1	Date	--	--	yyyy.mm.dd	2025/9/13	
	2	Time (start of test)	--	--	hh:mm:ss.f	14:56:47	
	3	Fault type (phase)	--	--	--	D2	
	4	Setting voltage depth	Line to line	--	--	p.u.	0,15
	5	Setting dip duration	--	--	--	--	150
	6	Point of fault entry	Total	--	--	ms	14873
	7	Point of fault clearance	Total	--	--	ms	15024
	8	Fault duration in empty load test	Total	--	--	ms	151
	9	Voltage depth/height in empty load test	Total (Phase 1)	t1+100ms to t2 and t1-10s to t1	p.u.	0,619	
	10		Total (Phase 2)			0,147	
	11		Total (Phase 3)			0,620	
12	Positive sequence		0,427				
Before dip <t1	13	Voltage	Phase 1	t1-10s to t1	p.u.	0,999	
	14		Phase 2			0,997	
	15		Phase 3			1,000	
	16	Current	Pos.	t1-500ms to t1-100ms	p.u.	1,003	
	17	Active power	Total	t1-10s to t1	p.u.	1,000	
	18		Pos.			1,000	
	19	Reactive power	Total	t1-10s to t1	p.u.	0,058	
	20		Pos.			0,009	
21	Cosφ	Total	t1-10s to t1	--	0,999		
During dip t1 to t2	22	Voltage	Phase 1	t1+100ms to t2-20ms	p.u.	0,619	
	23		Phase 2			0,147	
	24		Phase 3			0,620	
	25	Line current	Phase 1	t1+60ms	p.u.	--	
	26		Phase 2			0,015	
	27		Phase 3			--	
	28	Line current	Phase 1	t1+100ms	p.u.	--	
	29		Phase 2			0,043	
	30		Phase 3			--	
	31	Active power	Total	t1+100ms to t2-20ms	p.u.	0,000	
	32		Pos.			0,000	
	33	Voltage	Phase 1	t2+3s to t2+10s	p.u.	0,999	
	34		Phase 2			0,997	
	35		Phase 3			1,000	
	36	Active power	Total	t2+3s to t2+10s	p.u.	1,000	
	37		Pos.			1,000	
	38	Active power rising time	Total	--	s	0,707	
	39	Reactive power	Total	t2+3s to t2+10s	p.u.	0,058	
	40		Pos.			0,009	
	41	Reactive power rising time	total	--	s	--	
	42	PGU does not disconnect from grid till 60s after fault	--	t2 to t2+60s	Yes / No	Yes	

5.8.3

For PGUs Type 2 and storage systems

P

MST-BIE5-2500





5.8.3

For PGUs Type 2 and storage systems

P

MST-BIE5-2500



**5.8.3 For PGUs Type 2 and storage systems P**

**MST-BIE5-2500**

**2.1**



Condition						Measured value	
Item	No.	Parameter	Phase ref.	Time ref.	unit		
General Info.	0	Test number	--	--	--	2,1	
	1	Date	--	--	yyyy.mm.dd	2025/11/22	
	2	Time (start of test)	--	--	hh:mm:ss.f	15:21:36	
	3	Fault type (phase)	--	--	--	A	
	4	Setting voltage depth	Line to line	--	--	p.u.	0,5
	5	Setting dip duration	--	--	--	--	1600
	6	Point of fault entry	Total	--	--	ms	10065
	7	Point of fault clearance	Total	--	--	ms	11665
	8	Fault duration in empty load test	Total	--	--	ms	1600
	9	Voltage depth/height in empty load test	Total (Phase 1)	t1+100ms to t2 and t1-10s to t1	p.u.	0,496	
	10		Total (Phase 2)			0,496	
	11		Total (Phase 3)			0,496	
12	Positive sequence		0,496				
Before dip <t1	13	Voltage	Phase 1	t1-10s to t1	p.u.	0,999	
	14		Phase 2			1,000	
	15		Phase 3			1,003	
	16	Current	Pos.	t1-500ms to t1-100ms	p.u.	0,993	
	17	Active power	Total	t1-10s to t1	p.u.	0,946	
	18		Pos.			0,944	
	19	Reactive power	Total	t1-10s to t1	p.u.	0,316	
	20		Pos.			0,315	
21	Cosφ	Total	t1-10s to t1	--	0,949		
During dip t1 to t2	22	Voltage	Phase 1	t1+100ms to t2-20ms	p.u.	0,496	
	23		Phase 2			0,496	
	24		Phase 3			0,496	
	25	Line current	Phase 1	t1+60ms	p.u.	0,008	
	26		Phase 2			--	
	27		Phase 3			--	
	28	Line current	Phase 1	t1+100ms	p.u.	0,009	
	29		Phase 2			--	
	30		Phase 3			--	
	31	Active power	Total	t1+100ms to t2-20ms	p.u.	0,004	
	32		Pos.			0,004	
After dip > t2	33	Voltage	Phase 1	t2+3s to t2+10s	p.u.	0,999	
	34		Phase 2			1,000	
	35		Phase 3			1,003	
	36	Active power	Total	t2+3s to t2+10s	p.u.	0,960	
	37		Pos.			0,955	
	38	Active power rising time	Total	--	s	0,782	
	39	Reactive power	Total	t2+3s to t2+10s	p.u.	0,262	
	40		Pos.			0,261	
	41	Reactive power rising time	total	--	s	9,960	
	42	PGU does not disconnect from grid till 60s after fault	--	t2 to t2+60s	Yes / No	Yes	

5.8.3

For PGUs Type 2 and storage systems



P

MST-BIE5-2500




5.8.3 For PGUs Type 2 and storage systems P

MST-BIE5-2500



5.8.3 For PGUs Type 2 and storage systems P

MST-BIE5-2500




5.8.3		For PGUs Type 2 and storage systems				P	
MST-BIE5-2500							
2.2							
Condition						Measured value	
Item	No.	Parameter	Phase ref.	Time ref.	unit		
General Info.	0	Test number	--	--	--	2,2	
	1	Date	--	--	yyyy.mm.dd	2025/11/22	
	2	Time (start of test)	--	--	hh:mm:ss.f	15:29:35	
	3	Fault type (phase)	--	--	--	A	
	4	Setting voltage depth	Line to line	--	--	p.u.	0,5
	5	Setting dip duration		--	--		1600
	6	Point of fault entry	Total	--	--	ms	14068
	7	Point of fault clearance	Total	--	--	ms	15667
	8	Fault duration in empty load test	Total	--	--	ms	1599
	9	Voltage depth/height in empty load test	Total (Phase 1)	t1+100ms to t2 and t1-10s to t1	p.u.	0,500	
	10		Total (Phase 2)			0,500	
	11		Total (Phase 3)			0,500	
12	Positive sequence		0,500				
Before dip <t1	13	Voltage	Phase 1	t1-10s to t1	p.u.	1,003	
	14		Phase 2			1,000	
	15		Phase 3			0,998	
	16	Current	Pos.	t1-500ms to t1-100ms	p.u.	0,296	
	17	Active power	Total	t1-10s to t1	p.u.	0,294	
	18		Pos.			0,294	
	19	Reactive power	Total	t1-10s to t1	p.u.	0,316	
	20		Pos.			0,316	
21	Cosφ	Total	t1-10s to t1	--	0,680		
During dip t1 to t2	22	Voltage	Phase 1	t1+100ms to t2-20ms	p.u.	0,500	
	23		Phase 2			0,500	
	24		Phase 3			0,500	
	25	Line current	Phase 1	t1+60ms	p.u.	0,008	
	26		Phase 2			--	
	27		Phase 3			--	
	28	Line current	Phase 1	t1+100ms	p.u.	0,027	
	29		Phase 2			--	
	30		Phase 3			--	
	31	Active power	Total	t1+100ms to t2-20ms	p.u.	0,004	
32	Pos.		0,004				
After dip > t2	33	Voltage	Phase 1	t2+3s to t2+10s	p.u.	1,004	
	34		Phase 2			1,002	
	35		Phase 3			1,000	
	36	Active power	Total	t2+3s to t2+10s	p.u.	0,293	
	37		Pos.			0,293	
	38	Active power rising time	Total	--	s	0,837	
	39	Reactive power	Total	t2+3s to t2+10s	p.u.	0,282	
	40		Pos.			0,282	
	41	Reactive power rising time	total	--	s	9,985	
	42	PGU does not disconnect from grid till 60s after fault	--	t2 to t2+60s	Yes / No	Yes	

5.8.3

For PGUs Type 2 and storage systems


P

MST-BIE5-2500




5.8.3 For PGUs Type 2 and storage systems P

MST-BIE5-2500




	A	B	间隔
时间 [s]	0:19.65746	0:19.73092	0.07346
U1_trms_rc@AC_GRID [V]	230.2661	230.2605	-5.585e-3
U2_trms_rc@AC_GRID [V]	229.9430	229.9431	6.104e-5
U3_trms_rc@AC_GRID [V]	229.9484	229.9430	-5.447e-3
P1_t_rc@AC_GRID [W]	730.3315	730.8500	0.518555
Q1_fund_rc@AC_GRID [var]	564.2968	569.0309	4.734131



	A	B	间隔
时间 [s]	0:15.688482	0:16.525249	0.836767
U1_trms_rc@AC_GRID [V]	224.6107	230.2640	5.653336
U2_trms_rc@AC_GRID [V]	225.0931	229.9430	4.849884
U3_trms_rc@AC_GRID [V]	224.6685	229.9602	5.291763
P1_t_rc@AC_GRID [W]	-54.15802	707.8103	761.9683
Q1_fund_rc@AC_GRID [var]	-2.313698	164.4992	166.8129

5.8.3 For PGUs Type 2 and storage systems P

MST-BIE5-2500




5.8.3		For PGUs Type 2 and storage systems				P	
MST-BIE5-2500							
2.3							
Condition						Measured value	
Item	No.	Parameter	Phase ref.	Time ref.	unit		
General Info.	0	Test number	--	--	--	2,3	
	1	Date	--	--	yyyy.mm.dd	2025/11/22	
	2	Time (start of test)	--	--	hh:mm:ss.f	15:59:35	
	3	Fault type (phase)	--	--	--	D1	
	4	Setting voltage depth	Line to line	--	--	p.u.	0,5
	5	Setting dip duration	--	--	--	--	1600
	6	Point of fault entry	Total	--	--	ms	13073
	7	Point of fault clearance	Total	--	--	ms	14671
	8	Fault duration in empty load test	Total	--	--	ms	1598
	9	Voltage depth/height in empty load test	Total (Phase 1)	t1+100ms to t2 and t1-10s to t1	p.u.	0,757	
	10		Total (Phase 2)			0,496	
	11		Total (Phase 3)			0,757	
12	Positive sequence		0,667				
Before dip <t1	13	Voltage	Phase 1	t1-10s to t1	p.u.	1,004	
	14		Phase 2			1,000	
	15		Phase 3			1,000	
	16	Current	Pos.	t1-500ms to t1-100ms	p.u.	0,992	
	17	Active power	Total	t1-10s to t1	p.u.	0,944	
	18		Pos.			0,944	
	19	Reactive power	Total	t1-10s to t1	p.u.	0,329	
	20		Pos.			0,327	
21	Cosφ	Total	t1-10s to t1	--	0,944		
During dip t1 to t2	22	Voltage	Phase 1	t1+100ms to t2-20ms	p.u.	0,757	
	23		Phase 2			0,496	
	24		Phase 3			0,757	
	25	Line current	Phase 1	t1+60ms	p.u.	--	
	26		Phase 2			--	
	27		Phase 3			0,017	
	28	Line current	Phase 1	t1+100ms	p.u.	--	
	29		Phase 2			--	
	30		Phase 3			0,015	
	31	Active power	Total	t1+100ms to t2-20ms	p.u.	0,009	
32	Pos.		0,008				
After dip > t2	33	Voltage	Phase 1	t2+3s to t2+10s	p.u.	1,004	
	34		Phase 2			1,000	
	35		Phase 3			0,999	
	36	Active power	Total	t2+3s to t2+10s	p.u.	0,960	
	37		Pos.			0,958	
	38	Active power rising time	Total	--	s	0,861	
	39	Reactive power	Total	t2+3s to t2+10s	p.u.	0,276	
	40		Pos.			0,274	
	41	Reactive power rising time	total	--	s	9,935	
	42	PGU does not disconnect from grid till 60s after fault	--	t2 to t2+60s	Yes / No	Yes	

5.8.3

For PGUs Type 2 and storage systems



P

MST-BIE5-2500




5.8.3 For PGUs Type 2 and storage systems P

MST-BIE5-2500



5.8.3 For PGUs Type 2 and storage systems P

MST-BIE5-2500



5.8.3 For PGUs Type 2 and storage systems P

MST-BIE5-2500

2.4


Condition						Measured value	
Item	No.	Parameter	Phase ref.	Time ref.	unit		
General Info.	0	Test number	--	--	--	2,4	
	1	Date	--	--	yyyy.mm.dd	2025/11/22	
	2	Time (start of test)	--	--	hh:mm:ss.f	16:51:30	
	3	Fault type (phase)	--	--	--	D1	
	4	Setting voltage depth	Line to line	--	--	p.u.	0,5
	5	Setting dip duration		--	--	--	1600
	6	Point of fault entry	Total	--	--	ms	13123
	7	Point of fault clearance	Total	--	--	ms	14719
	8	Fault duration in empty load test	Total	--	--	ms	1596
	9	Voltage depth/height in empty load test	Total (Phase 1)	t1+100ms to t2 and t1-10s to t1	p.u.	0,760	
	10		Total (Phase 2)			0,500	
	11		Total (Phase 3)			0,760	
12	Positive sequence		0,668				
Before dip <t1	13	Voltage	Phase 1	t1-10s to t1	p.u.	0,998	
	14		Phase 2			1,002	
	15		Phase 3			0,999	
	16	Current	Pos.	t1-500ms to t1-100ms	p.u.	0,296	
	17	Active power	Total	t1-10s to t1	p.u.	0,294	
	18		Pos.			0,294	
	19	Reactive power	Total	t1-10s to t1	p.u.	0,316	
	20		Pos.			0,316	
21	Cosφ	Total	t1-10s to t1	--	0,681		
During dip t1 to t2	22	Voltage	Phase 1	t1+100ms to t2-20ms	p.u.	0,760	
	23		Phase 2			0,500	
	24		Phase 3			0,760	
	25	Line current	Phase 1	t1+60ms	p.u.	--	
	26		Phase 2			--	
	27		Phase 3			0,028	
	28	Line current	Phase 1	t1+100ms	p.u.	--	
	29		Phase 2			--	
	30		Phase 3			0,015	
	31	Active power	Total	t1+100ms to t2-20ms	p.u.	0,009	
	32		Pos.			0,009	
After dip > t2	33	Voltage	Phase 1	t2+3s to t2+10s	p.u.	1,004	
	34		Phase 2			1,001	
	35		Phase 3			1,000	
	36	Active power	Total	t2+3s to t2+10s	p.u.	0,294	
	37		Pos.			0,294	
	38	Active power rising time	Total	--	s	0,729	
	39	Reactive power	Total	t2+3s to t2+10s	p.u.	0,294	
	40		Pos.			0,294	
	41	Reactive power rising time	total	--	s	9,925	
	42	PGU does not disconnect from grid till 60s after fault	--	t2 to t2+60s	Yes / No	Yes	

5.8.3

For PGUs Type 2 and storage systems



P

MST-BIE5-2500




5.8.3 For PGUs Type 2 and storage systems P

MST-BIE5-2500



5.8.3 For PGUs Type 2 and storage systems P

MST-BIE5-2500



	A	B	间隔
时间 [s]	0:14.75065	0:24.67564	9.92499
U1_trms_rc@AC_GRID [V]	231.7862	230.2517	-1.534515
U2_trms_rc@AC_GRID [V]	213.2728	229.9352	16.66243
U3_trms_rc@AC_GRID [V]	231.8409	229.9318	-1.909180
P3_t_rc@AC_GRID [W]	-43.49359	734.6260	778.1196
Q3_fund_rc@AC_GRID [var]	-6.972074	750.9955	757.9675


5.8.3		For PGUs Type 2 and storage systems				P	
MST-BIE5-2500							
3.1							
Condition						Measured value	
Item	No.	Parameter	Phase ref.	Time ref.	unit		
General Info.	0	Test number	--	--	--	3,1	
	1	Date	--	--	yyyy.mm.dd	2025/11/22	
	2	Time (start of test)	--	--	hh:mm:ss.f	16:11:30	
	3	Fault type (phase)	--	--	--	A	
	4	Setting voltage depth	Line to line	--	--	p.u.	0,5
	5	Setting dip duration	--	--	--	--	1600
	6	Point of fault entry	Total	--	--	ms	7467
	7	Point of fault clearance	Total	--	--	ms	9067
	8	Fault duration in empty load test	Total	--	--	ms	1600
	9	Voltage depth/height in empty load test	Total (Phase 1)	t1+100ms to t2 and t1-10s to t1	p.u.	0,496	
	10		Total (Phase 2)			0,496	
	11		Total (Phase 3)			0,496	
12	Positive sequence		0,496				
Before dip <t1	13	Voltage	Phase 1	t1-10s to t1	p.u.	1,004	
	14		Phase 2			1,000	
	15		Phase 3			0,999	
	16	Current	Pos.	t1-500ms to t1-100ms	p.u.	0,993	
	17	Active power	Total	t1-10s to t1	p.u.	0,946	
	18		Pos.			0,946	
	19	Reactive power	Total	t1-10s to t1	p.u.	-0,312	
	20		Pos.			-0,312	
21	Cosφ	Total	t1-10s to t1	--	0,950		
During dip t1 to t2	22	Voltage	Phase 1	t1+100ms to t2-20ms	p.u.	0,496	
	23		Phase 2			0,496	
	24		Phase 3			0,496	
	25	Line current	Phase 1	t1+60ms	p.u.	0,008	
	26		Phase 2			--	
	27		Phase 3			--	
	28	Line current	Phase 1	t1+100ms	p.u.	0,009	
	29		Phase 2			--	
	30		Phase 3			--	
	31	Active power	Total	t1+100ms to t2-20ms	p.u.	0,004	
32	Pos.		0,004				
After dip > t2	33	Voltage	Phase 1	t2+3s to t2+10s	p.u.	1,004	
	34		Phase 2			1,000	
	35		Phase 3			0,999	
	36	Active power	Total	t2+3s to t2+10s	p.u.	0,961	
	37		Pos.			0,961	
	38	Active power rising time	Total	--	s	0,850	
	39	Reactive power	Total	t2+3s to t2+10s	p.u.	-0,258	
	40		Pos.			-0,256	
	41	Reactive power rising time	total	--	s	9,952	
	42	PGU does not disconnect from grid till 60s after fault	--	t2 to t2+60s	Yes / No	Yes	

5.8.3

For PGUs Type 2 and storage systems



P

MST-BIE5-2500




5.8.3 For PGUs Type 2 and storage systems P

MST-BIE5-2500



5.8.3 For PGUs Type 2 and storage systems P

MST-BIE5-2500




	A	B	间隔
时间 [s]	9.087427	0:19.039380	9.951953
U1_tRMS_rc@AC_GRID [V]	217.7807	230.9819	13.20114
U2_tRMS_rc@AC_GRID [V]	221.9017	229.9356	8.033890
U3_tRMS_rc@AC_GRID [V]	217.8390	229.8826	12.04353
P1_t_rc@AC_GRID [W]	-54.16672	2376.561	2430.728
Q1_fund_rc@AC_GRID [var]	-11.86715	-736.1383	-724.2712

5.8.3		For PGUs Type 2 and storage systems				P	
MST-BIE5-2500							
3.2							
Condition						Measured value	
Item	No.	Parameter	Phase ref.	Time ref.	unit		
General Info.	0	Test number	--	--	--	3,2	
	1	Date	--	--	yyyy.mm.dd	2025/11/22	
	2	Time (start of test)	--	--	hh:mm:ss.f	17:11:35	
	3	Fault type (phase)	--	--	--	A	
	4	Setting voltage depth	Line to line	--	--	p.u.	0,5
	5	Setting dip duration		--	--	--	1600
	6	Point of fault entry	Total	--	--	ms	91712
	7	Point of fault clearance	Total	--	--	ms	93312
	8	Fault duration in empty load test	Total	--	--	ms	1600
	9	Voltage depth/height in empty load test	Total (Phase 1)	t1+100ms to t2 and t1-10s to t1	p.u.	0,500	
	10		Total (Phase 2)			0,500	
	11		Total (Phase 3)			0,500	
12	Positive sequence		0,500				
Before dip <t1	13	Voltage	Phase 1	t1-10s to t1	p.u.	0,998	
	14		Phase 2			0,999	
	15		Phase 3			1,000	
	16	Current	Pos.	t1-500ms to t1-100ms	p.u.	0,286	
	17	Active power	Total	t1-10s to t1	p.u.	0,286	
	18		Pos.			0,286	
	19	Reactive power	Total	t1-10s to t1	p.u.	-0,319	
	20		Pos.			-0,318	
21	Cosφ	Total	t1-10s to t1	--	0,666		
During dip t1 to t2	22	Voltage	Phase 1	t1+100ms to t2-20ms	p.u.	0,500	
	23		Phase 2			0,500	
	24		Phase 3			0,500	
	25	Line current	Phase 1	t1+60ms	p.u.	0,020	
	26		Phase 2			--	
	27		Phase 3			--	
	28	Line current	Phase 1	t1+100ms	p.u.	0,009	
	29		Phase 2			--	
	30		Phase 3			--	
	31	Active power	Total	t1+100ms to t2-20ms	p.u.	0,002	
32	Pos.		0,002				
After dip > t2	33	Voltage	Phase 1	t2+3s to t2+10s	p.u.	1,002	
	34		Phase 2			0,996	
	35		Phase 3			1,000	
	36	Active power	Total	t2+3s to t2+10s	p.u.	0,286	
	37		Pos.			0,286	
	38	Active power rising time	Total	--	s	0,929	
	39	Reactive power	Total	t2+3s to t2+10s	p.u.	-0,264	
	40		Pos.			-0,263	
	41	Reactive power rising time	total	--	s	9,869	
	42	PGU does not disconnect from grid till 60s after fault	--	t2 to t2+60s	Yes / No	Yes	

5.8.3 For PGUs Type 2 and storage systems P



MST-BIE5-2500



5.8.3 For PGUs Type 2 and storage systems


P

MST-BIE5-2500



5.8.3 For PGUs Type 2 and storage systems P

MST-BIE5-2500




5.8.3		For PGUs Type 2 and storage systems				P	
MST-BIE5-2500							
3.3							
Condition						Measured value	
Item	No.	Parameter	Phase ref.	Time ref.	unit		
General Info.	0	Test number	--	--	--	3,3	
	1	Date	--	--	yyyy.mm.dd	2025/11/22	
	2	Time (start of test)	--	--	hh:mm:ss.f	18:11:31	
	3	Fault type (phase)	--	--	--	D1	
	4	Setting voltage depth	Line to line	--	--	p.u.	0,5
	5	Setting dip duration		--	--	--	1600
	6	Point of fault entry	Total	--	--	ms	18555
	7	Point of fault clearance	Total	--	--	ms	20147
	8	Fault duration in empty load test	Total	--	--	ms	1592
	9	Voltage depth/height in empty load test	Total (Phase 1)	t1+100ms to t2 and t1-10s to t1	p.u.	0,757	
	10		Total (Phase 2)			0,500	
	11		Total (Phase 3)			0,757	
12	Positive sequence		0,669				
Before dip <t1	13	Voltage	Phase 1	t1-10s to t1	p.u.	1,004	
	14		Phase 2			1,000	
	15		Phase 3			1,000	
	16	Current	Pos.	t1-500ms to t1-100ms	p.u.	0,993	
	17	Active power	Total	t1-10s to t1	p.u.	0,949	
	18		Pos.			0,949	
	19	Reactive power	Total	t1-10s to t1	p.u.	-0,314	
	20		Pos.			-0,312	
21	Cosφ	Total	t1-10s to t1	--	0,950		
During dip t1 to t2	22	Voltage	Phase 1	t1+100ms to t2-20ms	p.u.	0,757	
	23		Phase 2			0,500	
	24		Phase 3			0,757	
	25	Line current	Phase 1	t1+60ms	p.u.	--	
	26		Phase 2			--	
	27		Phase 3			0,038	
	28	Line current	Phase 1	t1+100ms	p.u.	--	
	29		Phase 2			--	
	30		Phase 3			0,014	
	31	Active power	Total	t1+100ms to t2-20ms	p.u.	0,004	
32	Pos.		0,004				
After dip > t2	33	Voltage	Phase 1	t2+3s to t2+10s	p.u.	1,004	
	34		Phase 2			1,000	
	35		Phase 3			1,000	
	36	Active power	Total	t2+3s to t2+10s	p.u.	0,961	
	37		Pos.			0,960	
	38	Active power rising time	Total	--	s	0,820	
	39	Reactive power	Total	t2+3s to t2+10s	p.u.	-0,264	
	40		Pos.			-0,262	
	41	Reactive power rising time	total	--	s	9,913	
	42	PGU does not disconnect from grid till 60s after fault	--	t2 to t2+60s	Yes / No	Yes	

5.8.3

For PGUs Type 2 and storage systems



P

MST-BIE5-2500




5.8.3 For PGUs Type 2 and storage systems P

MST-BIE5-2500



5.8.3 For PGUs Type 2 and storage systems P

MST-BIE5-2500



5.8.3 For PGUs Type 2 and storage systems P

MST-BIE5-2500

3.4


Condition						Measured value	
Item	No.	Parameter	Phase ref.	Time ref.	unit		
General Info.	0	Test number	--	--	--	3,4	
	1	Date	--	--	yyyy.mm.dd	2025/11/22	
	2	Time (start of test)	--	--	hh:mm:ss.f	18:31:32	
	3	Fault type (phase)	--	--	--	D1	
	4	Setting voltage depth	Line to line	--	--	p.u.	0,5
	5	Setting dip duration		--	--		1500
	6	Point of fault entry	Total	--	--	ms	22212
	7	Point of fault clearance	Total	--	--	ms	23802
	8	Fault duration in empty load test	Total	--	--	ms	1590
	9	Voltage depth/height in empty load test	Total (Phase 1)	t1+100ms to t2 and t1-10s to t1	p.u.	0,760	
	10		Total (Phase 2)			0,500	
	11		Total (Phase 3)			0,759	
12	Positive sequence		0,669				
Before dip <t1	13	Voltage	Phase 1	t1-10s to t1	p.u.	0,999	
	14		Phase 2			1,000	
	15		Phase 3			1,003	
	16	Current	Pos.	t1-500ms to t1-100ms	p.u.	0,286	
	17	Active power	Total	t1-10s to t1	p.u.	0,285	
	18		Pos.			0,285	
	19	Reactive power	Total	t1-10s to t1	p.u.	-0,315	
	20		Pos.			-0,314	
21	Cosφ	Total	t1-10s to t1	--	0,670		
During dip t1 to t2	22	Voltage	Phase 1	t1+100ms to t2-20ms	p.u.	0,760	
	23		Phase 2			0,500	
	24		Phase 3			0,759	
	25	Line current	Phase 1	t1+60ms	p.u.	--	
	26		Phase 2			--	
	27		Phase 3			0,044	
	28	Line current	Phase 1	t1+100ms	p.u.	--	
	29		Phase 2			--	
	30		Phase 3			0,014	
	31	Active power	Total	t1+100ms to t2-20ms	p.u.	0,010	
32	Pos.		0,010				
After dip > t2	33	Voltage	Phase 1	t2+3s to t2+10s	p.u.	1,000	
	34		Phase 2			1,000	
	35		Phase 3			1,003	
	36	Active power	Total	t2+3s to t2+10s	p.u.	0,286	
	37		Pos.			0,286	
	38	Active power rising time	Total	--	s	0,940	
	39	Reactive power	Total	t2+3s to t2+10s	p.u.	-0,269	
	40		Pos.			-0,268	
	41	Reactive power rising time	total	--	s	9,904	
42	PGU does not disconnect from grid till 60s after fault	--	t2 to t2+60s	Yes / No	Yes		

5.8.3

For PGUs Type 2 and storage systems



P

MST-BIE5-2500




5.8.3 For PGUs Type 2 and storage systems P

MST-BIE5-2500



5.8.3 For PGUs Type 2 and storage systems P

MST-BIE5-2500



	A	B	间隔
时间 [s]	0:23.83501	0:33.73883	9.90382
U1_trms_rc@AC_GRID [V]	228.3910	230.2274	1.836411
U2_trms_rc@AC_GRID [V]	197.4587	229.9318	32.47305
U3_trms_rc@AC_GRID [V]	228.4507	229.9240	1.473267
P3_t_rc@AC_GRID [W]	-49.48650	714.9790	764.4655
Q3_fund_rc@AC_GRID [var]	-72.37278	-736.5353	-664.1626


5.8.3		For PGUs Type 2 and storage systems				P	
MST-BIE5-2500							
4.1							
Condition						Measured value	
Item	No.	Parameter	Phase ref.	Time ref.	unit		
General Info.	0	Test number	--	--	--	4,1	
	1	Date	--	--	yyyy.mm.dd	2025/9/13	
	2	Time (start of test)	--	--	hh:mm:ss.f	19:42:32	
	3	Fault type (phase)	--	--	--	A	
	4	Setting voltage depth	Line to line	--	--	p.u.	0,85
	5	Setting dip duration		--	--	--	60000
	6	Point of fault entry	Total	--	--	ms	16048
	7	Point of fault clearance	Total	--	--	ms	76050
	8	Fault duration in empty load test	Total	--	--	ms	60002
	9	Voltage depth/height in empty load test	Total (Phase 1)	t1+100ms to t2 and t1-10s to t1	p.u.	0,849	
	10		Total (Phase 2)			0,848	
	11		Total (Phase 3)			0,848	
12	Positive sequence		0,848				
Before dip <t1	13	Voltage	Phase 1	t1-10s to t1	p.u.	0,999	
	14		Phase 2			0,998	
	15		Phase 3			0,999	
	16	Current	Pos.	t1-500ms to t1-100ms	p.u.	1,008	
	17	Active power	Total	t1-10s to t1	p.u.	1,006	
	18		Pos.			1,006	
	19	Reactive power	Total	t1-10s to t1	p.u.	0,037	
	20		Pos.			0,007	
21	Cosφ	Total	t1-10s to t1	--	0,999		
During dip t1 to t2	22	Voltage	Phase 1	t1+100ms to t2-20ms	p.u.	0,849	
	23		Phase 2			0,848	
	24		Phase 3			0,848	
	25	Line current	Phase 1	t1+60ms	p.u.	--	
	26		Phase 2			--	
	27		Phase 3			1,127	
	28	Line current	Phase 1	t1+100ms	p.u.	--	
	29		Phase 2			--	
	30		Phase 3			1,127	
	31	Active power	Total	t1+100ms to t2-20ms	p.u.	0,955	
32	Pos.		0,955				
After dip > t2	33	Voltage	Phase 1	t2+3s to t2+10s	p.u.	0,999	
	34		Phase 2			0,998	
	35		Phase 3			0,999	
	36	Active power	Total	t2+3s to t2+10s	p.u.	1,007	
	37		Pos.			1,007	
	38	Active power rising time	Total	--	s	0,067	
	39	Reactive power	Total	t2+3s to t2+10s	p.u.	0,033	
	40		Pos.			0,007	
	41	Reactive power rising time	total	--	s	--	
	42	PGU does not disconnect from grid till 60s after fault	--	t2 to t2+60s	Yes / No	Yes	

5.8.3

For PGUs Type 2 and storage systems

P

MST-BIE5-2500





5.8.3

For PGUs Type 2 and storage systems

P

MST-BIE5-2500




5.8.3		For PGUs Type 2 and storage systems				P	
MST-BIE5-2500							
4.2							
Condition						Measured value	
Item	No.	Parameter	Phase ref.	Time ref.	unit		
General Info.	0	Test number	--	--	--	4,2	
	1	Date	--	--	yyyy.mm.dd	2025/9/13	
	2	Time (start of test)	--	--	hh:mm:ss.f	19:46:20	
	3	Fault type (phase)	--	--	--	A	
	4	Setting voltage depth	Line to line	--	--	p.u.	0,85
	5	Setting dip duration		--	--	--	60000
	6	Point of fault entry	Total	--	--	ms	18457
	7	Point of fault clearance	Total	--	--	ms	78458
	8	Fault duration in empty load test	Total	--	--	ms	60001
	9	Voltage depth/height in empty load test	Total (Phase 1)	t1+100ms to t2 and t1-10s to t1	p.u.	0,849	
	10		Total (Phase 2)			0,848	
	11		Total (Phase 3)			0,849	
12	Positive sequence		0,849				
Before dip <t1	13	Voltage	Phase 1	t1-10s to t1	p.u.	0,999	
	14		Phase 2			0,998	
	15		Phase 3			0,999	
	16	Current	Pos.	t1-500ms to t1-100ms	p.u.	0,299	
	17	Active power	Total	t1-10s to t1	p.u.	0,299	
	18		Pos.			0,299	
	19	Reactive power	Total	t1-10s to t1	p.u.	0,014	
	20		Pos.			0,001	
21	Cosφ	Total	t1-10s to t1	--	0,999		
During dip t1 to t2	22	Voltage	Phase 1	t1+100ms to t2-20ms	p.u.	0,849	
	23		Phase 2			0,848	
	24		Phase 3			0,849	
	25	Line current	Phase 1	t1+60ms	p.u.	--	
	26		Phase 2			--	
	27		Phase 3			0,341	
	28	Line current	Phase 1	t1+100ms	p.u.	--	
	29		Phase 2			--	
	30		Phase 3			0,357	
	31	Active power	Total	t1+100ms to t2-20ms	p.u.	0,302	
32	Pos.		0,301				
After dip > t2	33	Voltage	Phase 1	t2+3s to t2+10s	p.u.	0,999	
	34		Phase 2			0,998	
	35		Phase 3			0,999	
	36	Active power	Total	t2+3s to t2+10s	p.u.	0,299	
	37		Pos.			0,299	
	38	Active power rising time	Total	--	s	0,060	
	39	Reactive power	Total	t2+3s to t2+10s	p.u.	0,014	
	40		Pos.			0,002	
	41	Reactive power rising time	total	--	s	--	
	42	PGU does not disconnect from grid till 60s after fault	--	t2 to t2+60s	Yes / No	Yes	

5.8.3

For PGUs Type 2 and storage systems

P

MST-BIE5-2500





5.8.3

For PGUs Type 2 and storage systems

P

MST-BIE5-2500



**5.8.3 For PGUs Type 2 and storage systems P**

**MST-BIE5-2500**

**4.3**



Condition						Measured value	
Item	No.	Parameter	Phase ref.	Time ref.	unit		
General Info.	0	Test number	--	--	--	4,3	
	1	Date	--	--	yyyy.mm.dd	2025/9/13	
	2	Time (start of test)	--	--	hh:mm:ss.f	13:56:50	
	3	Fault type (phase)	--	--	--	D1	
	4	Setting voltage depth	Line to line	--	--	p.u.	0,85
	5	Setting dip duration		--	--	--	60000
	6	Point of fault entry	Total	--	--	ms	16709
	7	Point of fault clearance	Total	--	--	ms	76712
	8	Fault duration in empty load test	Total	--	--	ms	60003
	9	Voltage depth/height in empty load test	Total (Phase 1)	t1+100ms to t2 and t1-10s to t1	p.u.	0,929	
	10		Total (Phase 2)			0,848	
	11		Total (Phase 3)			0,928	
12	Positive sequence		0,897				
Before dip <t1	13	Voltage	Phase 1	t1-10s to t1	p.u.	0,999	
	14		Phase 2			0,998	
	15		Phase 3			0,999	
	16	Current	Pos.	t1-500ms to t1-100ms	p.u.	1,002	
	17	Active power	Total	t1-10s to t1	p.u.	1,000	
	18		Pos.			1,000	
	19	Reactive power	Total	t1-10s to t1	p.u.	0,040	
	20		Pos.			0,008	
21	Cosφ	Total	t1-10s to t1	--	0,999		
During dip t1 to t2	22	Voltage	Phase 1	t1+100ms to t2-20ms	p.u.	0,929	
	23		Phase 2			0,848	
	24		Phase 3			0,928	
	25	Line current	Phase 1	t1+60ms	p.u.	--	
	26		Phase 2			--	
	27		Phase 3			1,054	
	28	Line current	Phase 1	t1+100ms	p.u.	--	
	29		Phase 2			--	
	30		Phase 3			1,089	
	31	Active power	Total	t1+100ms to t2-20ms	p.u.	1,006	
32	Pos.		1,006				
After dip > t2	33	Voltage	Phase 1	t2+3s to t2+10s	p.u.	0,999	
	34		Phase 2			0,998	
	35		Phase 3			0,999	
	36	Active power	Total	t2+3s to t2+10s	p.u.	1,000	
	37		Pos.			1,000	
	38	Active power rising time	Total	--	s	0,049	
	39	Reactive power	Total	t2+3s to t2+10s	p.u.	0,043	
	40		Pos.			0,009	
	41	Reactive power rising time	total	--	s	--	
	42	PGU does not disconnect from grid till 60s after fault	--	t2 to t2+60s	Yes / No	Yes	

5.8.3

For PGUs Type 2 and storage systems

P



MST-BIE5-2500



5.8.3 For PGUs Type 2 and storage systems

P

MST-BIE5-2500





5.8.3		For PGUs Type 2 and storage systems				P	
MST-BIE5-2500							
4.4							
Condition						Measured value	
Item	No.	Parameter	Phase ref.	Time ref.	unit		
General Info.	0	Test number	--	--	--	4,4	
	1	Date	--	--	yyyy.mm.dd	2025/9/13	
	2	Time (start of test)	--	--	hh:mm:ss.f	14:00:48	
	3	Fault type (phase)	--	--	--	D1	
	4	Setting voltage depth	Line to line	--	--	p.u.	0,85
	5	Setting dip duration		--	--	--	60000
	6	Point of fault entry	Total	--	--	ms	16196
	7	Point of fault clearance	Total	--	--	ms	76196
	8	Fault duration in empty load test	Total	--	--	ms	60000
	9	Voltage depth/height in empty load test	Total (Phase 1)	t1+100ms to t2 and t1-10s to t1	p.u.	0,929	
	10		Total (Phase 2)			0,848	
	11		Total (Phase 3)			0,929	
12	Positive sequence		0,897				
Before dip <t1	13	Voltage	Phase 1	t1-10s to t1	p.u.	0,999	
	14		Phase 2			0,998	
	15		Phase 3			0,999	
	16	Current	Pos.	t1-500ms to t1-100ms	p.u.	0,299	
	17	Active power	Total	t1-10s to t1	p.u.	0,299	
	18		Pos.			0,299	
	19	Reactive power	Total	t1-10s to t1	p.u.	0,013	
	20		Pos.			0,001	
21	Cosφ	Total	t1-10s to t1	--	0,999		
During dip t1 to t2	22	Voltage	Phase 1	t1+100ms to t2-20ms	p.u.	0,929	
	23		Phase 2			0,848	
	24		Phase 3			0,929	
	25	Line current	Phase 1	t1+60ms	p.u.	--	
	26		Phase 2			--	
	27		Phase 3			0,317	
	28	Line current	Phase 1	t1+100ms	p.u.	--	
	29		Phase 2			--	
	30		Phase 3			0,324	
	31	Active power	Total	t1+100ms to t2-20ms	p.u.	0,299	
32	Pos.		0,299				
After dip > t2	33	Voltage	Phase 1	t2+3s to t2+10s	p.u.	0,999	
	34		Phase 2			0,998	
	35		Phase 3			0,999	
	36	Active power	Total	t2+3s to t2+10s	p.u.	0,299	
	37		Pos.			0,299	
	38	Active power rising time	Total	--	s	0,069	
	39	Reactive power	Total	t2+3s to t2+10s	p.u.	0,013	
	40		Pos.			0,001	
	41	Reactive power rising time	total	--	s	--	
	42	PGU does not disconnect from grid till 60s after fault	--	t2 to t2+60s	Yes / No	Yes	

**5.8.3**

**For PGUs Type 2 and storage systems**

**P**

**MST-BIE5-2500**





5.8.3

For PGUs Type 2 and storage systems

P

MST-BIE5-2500




5.8.3		For PGUs Type 2 and storage systems				P	
MST-BIE5-2500							
5.1							
Condition						Measured value	
Item	No.	Parameter	Phase ref.	Time ref.	unit		
General Info.	0	Test number	--	--	--	5,1	
	1	Date	--	--	yyyy.mm.dd	2025/9/13	
	2	Time (start of test)	--	--	hh:mm:ss.f	9:48:24	
	3	Fault type (phase)	--	--	--	A	
	4	Setting voltage depth	Line to line	--	--	p.u.	1,25
	5	Setting dip duration		--	--	--	100
	6	Point of fault entry	Total	--	--	ms	18106
	7	Point of fault clearance	Total	--	--	ms	18209
	8	Fault duration in empty load test	Total	--	--	ms	103
	9	Voltage depth/height in empty load test	Total (Phase 1)	t1+100ms to t2 and t1-10s to t1	p.u.	1,246	
	10		Total (Phase 2)			1,249	
	11		Total (Phase 3)			1,251	
12	Positive sequence		1,243				
Before dip <t1	13	Voltage	Phase 1	t1-10s to t1	p.u.	0,999	
	14		Phase 2			0,998	
	15		Phase 3			0,999	
	16	Current	Pos.	t1-500ms to t1-100ms	p.u.	1,002	
	17	Active power	Total	t1-10s to t1	p.u.	1,000	
	18		Pos.			1,000	
	19	Reactive power	Total	t1-10s to t1	p.u.	0,044	
	20		Pos.			0,008	
21	Cosφ	Total	t1-10s to t1	--	0,999		
During dip t1 to t2	22	Voltage	Phase 1	t1+100ms to t2-20ms	p.u.	1,246	
	23		Phase 2			1,249	
	24		Phase 3			1,251	
	25	Line current	Phase 1	t1+60ms	p.u.	--	
	26		Phase 2			--	
	27		Phase 3			0,071	
	28	Line current	Phase 1	t1+100ms	p.u.	--	
	29		Phase 2			--	
	30		Phase 3			0,072	
	31	Active power	Total	t1+100ms to t2-20ms	p.u.	0,011	
	32		Pos.			0,011	
After dip > t2	33	Voltage	Phase 1	t2+3s to t2+10s	p.u.	0,999	
	34		Phase 2			0,998	
	35		Phase 3			0,999	
	36	Active power	Total	t2+3s to t2+10s	p.u.	1,000	
	37		Pos.			1,000	
	38	Active power rising time	Total	--	s	0,771	
	39	Reactive power	Total	t2+3s to t2+10s	p.u.	0,045	
	40		Pos.			0,008	
	41	Reactive power rising time	total	--	s	--	
	42	PGU does not disconnect from grid till 60s after fault	--	t2 to t2+60s	Yes / No	Yes	

5.8.3

For PGUs Type 2 and storage systems

P

MST-BIE5-2500




5.8.3

For PGUs Type 2 and storage systems

P


MST-BIE5-2500



5.8.3		For PGUs Type 2 and storage systems				P	
MST-BIE5-2500							
5.2							
Condition						Measured value	
Item	No.	Parameter	Phase ref.	Time ref.	unit		
General Info.	0	Test number	--	--	--	5,2	
	1	Date	--	--	yyyy.mm.dd	2025/9/13	
	2	Time (start of test)	--	--	hh:mm:ss.f	9:50:33	
	3	Fault type (phase)	--	--	--	A	
	4	Setting voltage depth	Line to line	--	--	p.u.	1,25
	5	Setting dip duration		--	--	--	100
	6	Point of fault entry	Total	--	--	ms	19380
	7	Point of fault clearance	Total	--	--	ms	19482
	8	Fault duration in empty load test	Total	--	--	ms	102
	9	Voltage depth/height in empty load test	Total (Phase 1)	t1+100ms to t2 and t1-10s to t1	p.u.	1,250	
	10		Total (Phase 2)			1,226	
	11		Total (Phase 3)			1,238	
12	Positive sequence		1,238				
Before dip <t1	13	Voltage	Phase 1	t1-10s to t1	p.u.	0,999	
	14		Phase 2			0,998	
	15		Phase 3			0,999	
	16	Current	Pos.	t1-500ms to t1-100ms	p.u.	0,298	
	17	Active power	Total	t1-10s to t1	p.u.	0,298	
	18		Pos.			0,298	
	19	Reactive power	Total	t1-10s to t1	p.u.	0,014	
	20		Pos.			0,001	
21	Cosφ	Total	t1-10s to t1	--	0,999		
During dip t1 to t2	22	Voltage	Phase 1	t1+100ms to t2-20ms	p.u.	1,250	
	23		Phase 2			1,226	
	24		Phase 3			1,238	
	25	Line current	Phase 1	t1+60ms	p.u.	--	
	26		Phase 2			--	
	27		Phase 3			0,073	
	28	Line current	Phase 1	t1+100ms	p.u.	--	
	29		Phase 2			--	
	30		Phase 3			0,072	
	31	Active power	Total	t1+100ms to t2-20ms	p.u.	0,011	
	32		Pos.			0,011	
After dip > t2	33	Voltage	Phase 1	t2+3s to t2+10s	p.u.	0,999	
	34		Phase 2			0,998	
	35		Phase 3			0,999	
	36	Active power	Total	t2+3s to t2+10s	p.u.	0,299	
	37		Pos.			0,299	
	38	Active power rising time	Total	--	s	0,811	
	39	Reactive power	Total	t2+3s to t2+10s	p.u.	0,014	
	40		Pos.			0,001	
	41	Reactive power rising time	total	--	s	--	
	42	PGU does not disconnect from grid till 60s after fault	--	t2 to t2+60s	Yes / No	Yes	

5.8.3 For PGUs Type 2 and storage systems P

MST-BIE5-2500




5.8.3

For PGUs Type 2 and storage systems

P

MST-BIE5-2500





5.8.3		For PGUs Type 2 and storage systems				P	
MST-BIE5-2500							
5.3							
Condition						Measured value	
Item	No.	Parameter	Phase ref.	Time ref.	unit		
General Info.	0	Test number	--	--	--	5,3	
	1	Date	--	--	yyyy.mm.dd	2025/9/13	
	2	Time (start of test)	--	--	hh:mm:ss.f	14:07:29	
	3	Fault type (phase)	--	--	--	D1	
	4	Setting voltage depth	Line to line	--	--	p.u.	1,25
	5	Setting dip duration		--	--	--	100
	6	Point of fault entry	Total	--	--	ms	18391
	7	Point of fault clearance	Total	--	--	ms	18492
	8	Fault duration in empty load test	Total	--	--	ms	100
	9	Voltage depth/height in empty load test	Total (Phase 1)	t1+100ms to t2 and t1-10s to t1	p.u.	1,085	
	10		Total (Phase 2)			1,238	
	11		Total (Phase 3)			1,060	
12	Positive sequence		1,124				
Before dip <t1	13	Voltage	Phase 1	t1-10s to t1	p.u.	0,999	
	14		Phase 2			0,998	
	15		Phase 3			0,999	
	16	Current	Pos.	t1-500ms to t1-100ms	p.u.	1,002	
	17	Active power	Total	t1-10s to t1	p.u.	1,000	
	18		Pos.			1,000	
	19	Reactive power	Total	t1-10s to t1	p.u.	0,043	
	20		Pos.			0,009	
21	Cosφ	Total	t1-10s to t1	--	0,999		
During dip t1 to t2	22	Voltage	Phase 1	t1+100ms to t2-20ms	p.u.	1,085	
	23		Phase 2			1,238	
	24		Phase 3			1,060	
	25	Line current	Phase 1	t1+60ms	p.u.	--	
	26		Phase 2			--	
	27		Phase 3			0,960	
	28	Line current	Phase 1	t1+100ms	p.u.	--	
	29		Phase 2			--	
	30		Phase 3			0,938	
	31	Active power	Total	t1+100ms to t2-20ms	p.u.	0,993	
32	Pos.		0,993				
After dip > t2	33	Voltage	Phase 1	t2+3s to t2+10s	p.u.	0,999	
	34		Phase 2			0,998	
	35		Phase 3			0,999	
	36	Active power	Total	t2+3s to t2+10s	p.u.	1,001	
	37		Pos.			1,001	
	38	Active power rising time	Total	--	s	0,069	
	39	Reactive power	Total	t2+3s to t2+10s	p.u.	0,044	
	40		Pos.			0,008	
	41	Reactive power rising time	total	--	s	--	
	42	PGU does not disconnect from grid till 60s after fault	--	t2 to t2+60s	Yes / No	Yes	

5.8.3

For PGUs Type 2 and storage systems

P

MST-BIE5-2500




**5.8.3**

**For PGUs Type 2 and storage systems**

**P**

**MST-BIE5-2500**



	A	B	Delta
Time [s]	0:18.510234	0:18.579507	0.069272
U1_IRMS_rc@3-phase Grid [V]	231.1346	230.6439	-0.490707
U2_IRMS_rc@3-phase Grid [V]	232.8972	229.5660	-3.331177
U3_IRMS_rc@3-phase Grid [V]	231.7151	230.3365	-1.381683
P3_L_rc@3-phase Grid [W]	2371.742	2499.416	127.6746
Q3_fund_rc@3-phase Grid [var]	-16.17004	-20.57445	-4.404409


5.8.3		For PGUs Type 2 and storage systems				P	
MST-BIE5-2500							
5.4							
Condition						Measured value	
Item	No.	Parameter	Phase ref.	Time ref.	unit		
General Info.	0	Test number	--	--	--	5,4	
	1	Date	--	--	yyyy.mm.dd	2025/9/13	
	2	Time (start of test)	--	--	hh:mm:ss.f	14:04:58	
	3	Fault type (phase)	--	--	--	D1	
	4	Setting voltage depth	Line to line	--	--	p.u.	1,25
	5	Setting dip duration		--	--	--	100
	6	Point of fault entry	Total	--	--	ms	16087
	7	Point of fault clearance	Total	--	--	ms	16189
	8	Fault duration in empty load test	Total	--	--	ms	102
	9	Voltage depth/height in empty load test	Total (Phase 1)	t1+100ms to t2 and t1-10s to t1	p.u.	1,084	
	10		Total (Phase 2)			1,248	
	11		Total (Phase 3)			1,060	
12	Positive sequence		1,120				
Before dip <t1	13	Voltage	Phase 1	t1-10s to t1	p.u.	0,999	
	14		Phase 2			0,998	
	15		Phase 3			0,999	
	16	Current	Pos.	t1-500ms to t1-100ms	p.u.	0,299	
	17	Active power	Total	t1-10s to t1	p.u.	0,299	
	18		Pos.			0,299	
	19	Reactive power	Total	t1-10s to t1	p.u.	0,013	
	20		Pos.			0,001	
21	Cosφ	Total	t1-10s to t1	--	0,999		
During dip t1 to t2	22	Voltage	Phase 1	t1+100ms to t2-20ms	p.u.	1,084	
	23		Phase 2			1,248	
	24		Phase 3			1,060	
	25	Line current	Phase 1	t1+60ms	p.u.	--	
	26		Phase 2			--	
	27		Phase 3			0,287	
	28	Line current	Phase 1	t1+100ms	p.u.	--	
	29		Phase 2			--	
	30		Phase 3			0,281	
	31	Active power	Total	t1+100ms to t2-20ms	p.u.	0,299	
	32		Pos.			0,298	
After dip > t2	33	Voltage	Phase 1	t2+3s to t2+10s	p.u.	0,999	
	34		Phase 2			0,998	
	35		Phase 3			0,999	
	36	Active power	Total	t2+3s to t2+10s	p.u.	0,298	
	37		Pos.			0,298	
	38	Active power rising time	Total	--	s	0,119	
	39	Reactive power	Total	t2+3s to t2+10s	p.u.	0,013	
	40		Pos.			0,001	
	41	Reactive power rising time	total	--	s	--	
	42	PGU does not disconnect from grid till 60s after fault	--	t2 to t2+60s	Yes / No	Yes	

5.8.3

For PGUs Type 2 and storage systems

P

MST-BIE5-2500




5.8.3

For PGUs Type 2 and storage systems

P

MST-BIE5-2500




5.8.3		For PGUs Type 2 and storage systems				P	
MST-BIE5-2500							
5.5							
Condition						Measured value	
Item	No.	Parameter	Phase ref.	Time ref.	unit		
General Info.	0	Test number	--	--	--	5,5	
	1	Date	--	--	yyyy.mm.dd	2025/9/13	
	2	Time (start of test)	--	--	hh:mm:ss.f	15:03:33	
	3	Fault type (phase)	--	--	--	D2	
	4	Setting voltage depth	Line to line	--	--	p.u.	1,25
	5	Setting dip duration		--	--	--	100
	6	Point of fault entry	Total	--	--	ms	18488
	7	Point of fault clearance	Total	--	--	ms	18588
	8	Fault duration in empty load test	Total	--	--	ms	100
	9	Voltage depth/height in empty load test	Total (Phase 1)	t1+100ms to t2 and t1-10s to t1	p.u.	1,080	
	10		Total (Phase 2)			1,247	
	11		Total (Phase 3)			1,060	
12	Positive sequence		1,121				
Before dip <t1	13	Voltage	Phase 1	t1-10s to t1	p.u.	0,999	
	14		Phase 2			0,997	
	15		Phase 3			0,997	
	16	Current	Pos.	t1-500ms to t1-100ms	p.u.	1,009	
	17	Active power	Total	t1-10s to t1	p.u.	1,007	
	18		Pos.			1,007	
	19	Reactive power	Total	t1-10s to t1	p.u.	0,043	
	20		Pos.			0,007	
21	Cosφ	Total	t1-10s to t1	--	0,999		
During dip t1 to t2	22	Voltage	Phase 1	t1+100ms to t2-20ms	p.u.	1,080	
	23		Phase 2			1,247	
	24		Phase 3			1,060	
	25	Line current	Phase 1	t1+60ms	p.u.	--	
	26		Phase 2			0,073	
	27		Phase 3			--	
	28	Line current	Phase 1	t1+100ms	p.u.	--	
	29		Phase 2			0,073	
	30		Phase 3			--	
	31	Active power	Total	t1+100ms to t2-20ms	p.u.	0,012	
32	Pos.		0,012				
After dip > t2	33	Voltage	Phase 1	t2+3s to t2+10s	p.u.	0,999	
	34		Phase 2			0,997	
	35		Phase 3			0,997	
	36	Active power	Total	t2+3s to t2+10s	p.u.	1,007	
	37		Pos.			1,007	
	38	Active power rising time	Total	--	s	0,785	
	39	Reactive power	Total	t2+3s to t2+10s	p.u.	0,043	
	40		Pos.			0,008	
	41	Reactive power rising time	total	--	s	--	
	42	PGU does not disconnect from grid till 60s after fault	--	t2 to t2+60s	Yes / No	Yes	

5.8.3

For PGUs Type 2 and storage systems


P

MST-BIE5-2500



**5.8.3 For PGUs Type 2 and storage systems P**

**MST-BIE5-2500**





5.8.3		For PGUs Type 2 and storage systems				P	
MST-BIE5-2500							
6.1							
Condition						Measured value	
Item	No.	Parameter	Phase ref.	Time ref.	unit		
General Info.	0	Test number	--	--	--	6,1	
	1	Date	--	--	yyyy.mm.dd	2025/9/13	
	2	Time (start of test)	--	--	hh:mm:ss.f	9:55:35	
	3	Fault type (phase)	--	--	--	A	
	4	Setting voltage depth	Line to line	--	--	p.u.	1,2
	5	Setting dip duration		--	--	--	5000
	6	Point of fault entry	Total	--	--	ms	20287
	7	Point of fault clearance	Total	--	--	ms	25287
	8	Fault duration in empty load test	Total	--	--	ms	5000
	9	Voltage depth/height in empty load test	Total (Phase 1)	t1+100ms to t2 and t1-10s to t1	p.u.	1,199	
	10		Total (Phase 2)			1,198	
	11		Total (Phase 3)			1,200	
12	Positive sequence		1,198				
Before dip <t1	13	Voltage	Phase 1	t1-10s to t1	p.u.	0,999	
	14		Phase 2			0,998	
	15		Phase 3			0,999	
	16	Current	Pos.	t1-500ms to t1-100ms	p.u.	1,002	
	17	Active power	Total	t1-10s to t1	p.u.	1,000	
	18		Pos.			1,000	
	19	Reactive power	Total	t1-10s to t1	p.u.	0,045	
	20		Pos.			0,008	
21	Cosφ	Total	t1-10s to t1	--	0,999		
During dip t1 to t2	22	Voltage	Phase 1	t1+100ms to t2-20ms	p.u.	1,199	
	23		Phase 2			1,198	
	24		Phase 3			1,200	
	25	Line current	Phase 1	t1+60ms	p.u.	--	
	26		Phase 2			--	
	27		Phase 3			0,068	
	28	Line current	Phase 1	t1+100ms	p.u.	--	
	29		Phase 2			--	
	30		Phase 3			0,069	
	31	Active power	Total	t1+100ms to t2-20ms	p.u.	0,010	
	32		Pos.			0,010	
After dip > t2	33	Voltage	Phase 1	t2+3s to t2+10s	p.u.	0,999	
	34		Phase 2			0,998	
	35		Phase 3			0,999	
	36	Active power	Total	t2+3s to t2+10s	p.u.	1,000	
	37		Pos.			1,000	
	38	Active power rising time	Total	--	s	0,889	
	39	Reactive power	Total	t2+3s to t2+10s	p.u.	0,045	
	40		Pos.			0,009	
	41	Reactive power rising time	total	--	s	--	
	42	PGU does not disconnect from grid till 60s after fault	--	t2 to t2+60s	Yes / No	Yes	

**5.8.3**

**For PGUs Type 2 and storage systems**

**P**



**MST-BIE5-2500**



5.8.3 For PGUs Type 2 and storage systems

P

MST-BIE5-2500





5.8.3		For PGUs Type 2 and storage systems				P	
MST-BIE5-2500							
6.2							
Condition						Measured value	
Item	No.	Parameter	Phase ref.	Time ref.	unit		
General Info.	0	Test number	--	--	--	6,2	
	1	Date	--	--	yyyy.mm.dd	2025/9/13	
	2	Time (start of test)	--	--	hh:mm:ss.f	9:53:06	
	3	Fault type (phase)	--	--	--	A	
	4	Setting voltage depth	Line to line	--	--	p.u.	1,2
	5	Setting dip duration		--	--	--	5000
	6	Point of fault entry	Total	--	--	ms	15777
	7	Point of fault clearance	Total	--	--	ms	20778
	8	Fault duration in empty load test	Total	--	--	ms	5001
	9	Voltage depth/height in empty load test	Total (Phase 1)	t1+100ms to t2 and t1-10s to t1	p.u.	1,199	
	10		Total (Phase 2)			1,198	
	11		Total (Phase 3)			1,200	
12	Positive sequence		1,198				
Before dip <t1	13	Voltage	Phase 1	t1-10s to t1	p.u.	0,999	
	14		Phase 2			0,998	
	15		Phase 3			0,999	
	16	Current	Pos.	t1-500ms to t1-100ms	p.u.	0,298	
	17	Active power	Total	t1-10s to t1	p.u.	0,298	
	18		Pos.			0,298	
	19	Reactive power	Total	t1-10s to t1	p.u.	0,014	
	20		Pos.			0,002	
21	Cosφ	Total	t1-10s to t1	--	0,999		
During dip t1 to t2	22	Voltage	Phase 1	t1+100ms to t2-20ms	p.u.	1,199	
	23		Phase 2			1,198	
	24		Phase 3			1,200	
	25	Line current	Phase 1	t1+60ms	p.u.	--	
	26		Phase 2			--	
	27		Phase 3			0,071	
	28	Line current	Phase 1	t1+100ms	p.u.	--	
	29		Phase 2			--	
	30		Phase 3			0,069	
	31	Active power	Total	t1+100ms to t2-20ms	p.u.	0,011	
32	Pos.		0,011				
After dip > t2	33	Voltage	Phase 1	t2+3s to t2+10s	p.u.	0,999	
	34		Phase 2			0,998	
	35		Phase 3			0,999	
	36	Active power	Total	t2+3s to t2+10s	p.u.	0,299	
	37		Pos.			0,299	
	38	Active power rising time	Total	--	s	0,733	
	39	Reactive power	Total	t2+3s to t2+10s	p.u.	0,014	
	40		Pos.			0,001	
	41	Reactive power rising time	total	--	s	--	
	42	PGU does not disconnect from grid till 60s after fault	--	t2 to t2+60s	Yes / No	Yes	

5.8.3

For PGUs Type 2 and storage systems

P

MST-BIE5-2500





5.8.3

For PGUs Type 2 and storage systems

P

MST-BIE5-2500





5.8.3		For PGUs Type 2 and storage systems				P	
MST-BIE5-2500							
6.3							
Condition						Measured value	
Item	No.	Parameter	Phase ref.	Time ref.	unit		
General Info.	0	Test number	--	--	--	6,3	
	1	Date	--	--	yyyy.mm.dd	2025/9/13	
	2	Time (start of test)	--	--	hh:mm:ss.f	14:13:35	
	3	Fault type (phase)	--	--	--	D1	
	4	Setting voltage depth	Line to line	--	--	p.u.	1,2
	5	Setting dip duration		--	--	--	5000
	6	Point of fault entry	Total	--	--	ms	16017
	7	Point of fault clearance	Total	--	--	ms	21020
	8	Fault duration in empty load test	Total	--	--	ms	5003
	9	Voltage depth/height in empty load test	Total (Phase 1)	t1+100ms to t2 and t1-10s to t1	p.u.	1,059	
	10		Total (Phase 2)			1,198	
	11		Total (Phase 3)			1,049	
12	Positive sequence		1,095				
Before dip <t1	13	Voltage	Phase 1	t1-10s to t1	p.u.	0,999	
	14		Phase 2			0,998	
	15		Phase 3			0,999	
	16	Current	Pos.	t1-500ms to t1-100ms	p.u.	1,005	
	17	Active power	Total	t1-10s to t1	p.u.	1,004	
	18		Pos.			1,004	
	19	Reactive power	Total	t1-10s to t1	p.u.	0,041	
	20		Pos.			0,007	
21	Cosφ	Total	t1-10s to t1	--	0,999		
During dip t1 to t2	22	Voltage	Phase 1	t1+100ms to t2-20ms	p.u.	1,059	
	23		Phase 2			1,198	
	24		Phase 3			1,049	
	25	Line current	Phase 1	t1+60ms	p.u.	--	
	26		Phase 2			--	
	27		Phase 3			0,976	
	28	Line current	Phase 1	t1+100ms	p.u.	--	
	29		Phase 2			--	
	30		Phase 3			0,950	
	31	Active power	Total	t1+100ms to t2-20ms	p.u.	0,998	
	32		Pos.			0,998	
After dip > t2	33	Voltage	Phase 1	t2+3s to t2+10s	p.u.	0,999	
	34		Phase 2			0,998	
	35		Phase 3			0,999	
	36	Active power	Total	t2+3s to t2+10s	p.u.	1,005	
	37		Pos.			1,005	
	38	Active power rising time	Total	--	s	0,063	
	39	Reactive power	Total	t2+3s to t2+10s	p.u.	0,040	
	40		Pos.			0,007	
	41	Reactive power rising time	total	--	s	--	
	42	PGU does not disconnect from grid till 60s after fault	--	t2 to t2+60s	Yes / No	Yes	

5.8.3

For PGUs Type 2 and storage systems



P

MST-BIE5-2500



5.8.3 For PGUs Type 2 and storage systems P

MST-BIE5-2500




5.8.3		For PGUs Type 2 and storage systems				P	
MST-BIE5-2500							
6.4							
Condition						Measured value	
Item	No.	Parameter	Phase ref.	Time ref.	unit		
General Info.	0	Test number	--	--	--	6,4	
	1	Date	--	--	yyyy.mm.dd	2025/9/13	
	2	Time (start of test)	--	--	hh:mm:ss.f	14:14:47	
	3	Fault type (phase)	--	--	--	D1	
	4	Setting voltage depth	Line to line	--	--	p.u.	1,2
	5	Setting dip duration		--	--	--	5000
	6	Point of fault entry	Total	--	--	ms	15809
	7	Point of fault clearance	Total	--	--	ms	20814
	8	Fault duration in empty load test	Total	--	--	ms	5005
	9	Voltage depth/height in empty load test	Total (Phase 1)	t1+100ms to t2 and t1-10s to t1	p.u.	1,059	
	10		Total (Phase 2)			1,198	
	11		Total (Phase 3)			1,049	
12	Positive sequence		1,095				
Before dip <t1	13	Voltage	Phase 1	t1-10s to t1	p.u.	0,999	
	14		Phase 2			0,998	
	15		Phase 3			0,999	
	16	Current	Pos.	t1-500ms to t1-100ms	p.u.	0,299	
	17	Active power	Total	t1-10s to t1	p.u.	0,298	
	18		Pos.			0,298	
	19	Reactive power	Total	t1-10s to t1	p.u.	0,014	
	20		Pos.			0,001	
21	Cosφ	Total	t1-10s to t1	--	0,999		
During dip t1 to t2	22	Voltage	Phase 1	t1+100ms to t2-20ms	p.u.	1,059	
	23		Phase 2			1,198	
	24		Phase 3			1,049	
	25	Line current	Phase 1	t1+60ms	p.u.	--	
	26		Phase 2			--	
	27		Phase 3			0,291	
	28	Line current	Phase 1	t1+100ms	p.u.	--	
	29		Phase 2			--	
	30		Phase 3			0,283	
	31	Active power	Total	t1+100ms to t2-20ms	p.u.	0,297	
	32		Pos.			0,297	
After dip > t2	33	Voltage	Phase 1	t2+3s to t2+10s	p.u.	0,999	
	34		Phase 2			0,998	
	35		Phase 3			0,999	
	36	Active power	Total	t2+3s to t2+10s	p.u.	0,298	
	37		Pos.			0,298	
	38	Active power rising time	Total	--	s	0,060	
	39	Reactive power	Total	t2+3s to t2+10s	p.u.	0,014	
	40		Pos.			0,001	
	41	Reactive power rising time	total	--	s	--	
	42	PGU does not disconnect from grid till 60s after fault	--	t2 to t2+60s	Yes / No	Yes	

5.8.3

For PGUs Type 2 and storage systems



P

MST-BIE5-2500



5.8.3 For PGUs Type 2 and storage systems P

MST-BIE5-2500




5.8.3		For PGUs Type 2 and storage systems				P	
MST-BIE5-2500							
7.1							
Condition						Measured value	
Item	No.	Parameter	Phase ref.	Time ref.	unit		
General Info.	0	Test number	--	--	--	7,1	
	1	Date	--	--	yyyy.mm.dd	2025/9/13	
	2	Time (start of test)	--	--	hh:mm:ss.f	9:58:40	
	3	Fault type (phase)	--	--	--	A	
	4	Setting voltage depth	Line to line	--	--	p.u.	1,15
	5	Setting dip duration		--	--	--	60000
	6	Point of fault entry	Total	--	--	ms	17515
	7	Point of fault clearance	Total	--	--	ms	77518
	8	Fault duration in empty load test	Total	--	--	ms	60003
	9	Voltage depth/height in empty load test	Total (Phase 1)	t1+100ms to t2 and t1-10s to t1	p.u.	1,148	
	10		Total (Phase 2)			1,147	
	11		Total (Phase 3)			1,148	
12	Positive sequence		1,147				
Before dip <t1	13	Voltage	Phase 1	t1-10s to t1	p.u.	0,999	
	14		Phase 2			0,998	
	15		Phase 3			0,999	
	16	Current	Pos.	t1-500ms to t1-100ms	p.u.	1,003	
	17	Active power	Total	t1-10s to t1	p.u.	1,001	
	18		Pos.			1,001	
	19	Reactive power	Total	t1-10s to t1	p.u.	0,047	
	20		Pos.			0,008	
21	Cosφ	Total	t1-10s to t1	--	0,999		
During dip t1 to t2	22	Voltage	Phase 1	t1+100ms to t2-20ms	p.u.	1,148	
	23		Phase 2			1,147	
	24		Phase 3			1,148	
	25	Line current	Phase 1	t1+60ms	p.u.	--	
	26		Phase 2			--	
	27		Phase 3			0,909	
	28	Line current	Phase 1	t1+100ms	p.u.	--	
	29		Phase 2			--	
	30		Phase 3			0,862	
	31	Active power	Total	t1+100ms to t2-20ms	p.u.	0,990	
	32		Pos.			0,990	
After dip > t2	33	Voltage	Phase 1	t2+3s to t2+10s	p.u.	0,999	
	34		Phase 2			0,998	
	35		Phase 3			0,999	
	36	Active power	Total	t2+3s to t2+10s	p.u.	1,001	
	37		Pos.			1,001	
	38	Active power rising time	Total	--	s	0,064	
	39	Reactive power	Total	t2+3s to t2+10s	p.u.	0,046	
	40		Pos.			0,008	
	41	Reactive power rising time	total	--	s	--	
42	PGU does not disconnect from grid till 60s after fault	--	t2 to t2+60s	Yes / No	Yes		

5.8.3

For PGUs Type 2 and storage systems



P

MST-BIE5-2500



5.8.3 For PGUs Type 2 and storage systems P

MST-BIE5-2500





5.8.3		For PGUs Type 2 and storage systems				P	
MST-BIE5-2500							
7.2							
Condition						Measured value	
Item	No.	Parameter	Phase ref.	Time ref.	unit		
General Info.	0	Test number	--	--	--	7,2	
	1	Date	--	--	yyyy.mm.dd	2025/9/13	
	2	Time (start of test)	--	--	hh:mm:ss.f	10:02:12	
	3	Fault type (phase)	--	--	--	A	
	4	Setting voltage depth	Line to line	--	--	p.u.	1,15
	5	Setting dip duration		--	--	--	60000
	6	Point of fault entry	Total	--	--	ms	16829
	7	Point of fault clearance	Total	--	--	ms	76831
	8	Fault duration in empty load test	Total	--	--	ms	60002
	9	Voltage depth/height in empty load test	Total (Phase 1)	t1+100ms to t2 and t1-10s to t1	p.u.	1,148	
	10		Total (Phase 2)			1,147	
	11		Total (Phase 3)			1,148	
12	Positive sequence		1,147				
Before dip <t1	13	Voltage	Phase 1	t1-10s to t1	p.u.	0,999	
	14		Phase 2			0,998	
	15		Phase 3			0,999	
	16	Current	Pos.	t1-500ms to t1-100ms	p.u.	0,299	
	17	Active power	Total	t1-10s to t1	p.u.	0,298	
	18		Pos.			0,298	
	19	Reactive power	Total	t1-10s to t1	p.u.	0,014	
	20		Pos.			0,002	
21	Cosφ	Total	t1-10s to t1	--	0,999		
During dip t1 to t2	22	Voltage	Phase 1	t1+100ms to t2-20ms	p.u.	1,148	
	23		Phase 2			1,147	
	24		Phase 3			1,148	
	25	Line current	Phase 1	t1+60ms	p.u.	--	
	26		Phase 2			--	
	27		Phase 3			0,271	
	28	Line current	Phase 1	t1+100ms	p.u.	--	
	29		Phase 2			--	
	30		Phase 3			0,255	
	31	Active power	Total	t1+100ms to t2-20ms	p.u.	0,295	
	32		Pos.			0,295	
After dip > t2	33	Voltage	Phase 1	t2+3s to t2+10s	p.u.	0,999	
	34		Phase 2			0,998	
	35		Phase 3			0,999	
	36	Active power	Total	t2+3s to t2+10s	p.u.	0,299	
	37		Pos.			0,299	
	38	Active power rising time	Total	--	s	0,064	
	39	Reactive power	Total	t2+3s to t2+10s	p.u.	0,014	
	40		Pos.			0,002	
	41	Reactive power rising time	total	--	s	--	
	42	PGU does not disconnect from grid till 60s after fault	--	t2 to t2+60s	Yes / No	Yes	

5.8.3

For PGUs Type 2 and storage systems

P

MST-BIE5-2500





5.8.3

For PGUs Type 2 and storage systems

P

MST-BIE5-2500





5.8.3		For PGUs Type 2 and storage systems				P	
MST-BIE5-2500							
7.3							
Condition						Measured value	
Item	No.	Parameter	Phase ref.	Time ref.	unit		
General Info.	0	Test number	--	--	--	7,3	
	1	Date	--	--	yyyy.mm.dd	2025/9/13	
	2	Time (start of test)	--	--	hh:mm:ss.f	14:22:17	
	3	Fault type (phase)	--	--	--	D1	
	4	Setting voltage depth	Line to line	--	--	p.u.	1,15
	5	Setting dip duration		--	--	--	60000
	6	Point of fault entry	Total	--	--	ms	17657
	7	Point of fault clearance	Total	--	--	ms	77663
	8	Fault duration in empty load test	Total	--	--	ms	60006
	9	Voltage depth/height in empty load test	Total (Phase 1)	t1+100ms to t2 and t1-10s to t1	p.u.	1,039	
	10		Total (Phase 2)			1,148	
	11		Total (Phase 3)			1,039	
12	Positive sequence		1,069				
Before dip <t1	13	Voltage	Phase 1	t1-10s to t1	p.u.	0,999	
	14		Phase 2			0,998	
	15		Phase 3			0,999	
	16	Current	Pos.	t1-500ms to t1-100ms	p.u.	1,007	
	17	Active power	Total	t1-10s to t1	p.u.	1,006	
	18		Pos.			1,006	
	19	Reactive power	Total	t1-10s to t1	p.u.	0,037	
	20		Pos.			0,008	
21	Cosφ	Total	t1-10s to t1	--	0,999		
During dip t1 to t2	22	Voltage	Phase 1	t1+100ms to t2-20ms	p.u.	1,039	
	23		Phase 2			1,148	
	24		Phase 3			1,039	
	25	Line current	Phase 1	t1+60ms	p.u.	--	
	26		Phase 2			--	
	27		Phase 3			0,974	
	28	Line current	Phase 1	t1+100ms	p.u.	--	
	29		Phase 2			--	
	30		Phase 3			0,962	
	31	Active power	Total	t1+100ms to t2-20ms	p.u.	1,001	
32	Pos.		1,001				
After dip > t2	33	Voltage	Phase 1	t2+3s to t2+10s	p.u.	0,999	
	34		Phase 2			0,998	
	35		Phase 3			0,999	
	36	Active power	Total	t2+3s to t2+10s	p.u.	1,007	
	37		Pos.			1,007	
	38	Active power rising time	Total	--	s	0,049	
	39	Reactive power	Total	t2+3s to t2+10s	p.u.	0,036	
	40		Pos.			0,007	
	41	Reactive power rising time	total	--	s	--	
	42	PGU does not disconnect from grid till 60s after fault	--	t2 to t2+60s	Yes / No	Yes	

5.8.3

For PGUs Type 2 and storage systems

P

MST-BIE5-2500





5.8.3

For PGUs Type 2 and storage systems

P

MST-BIE5-2500





5.8.3		For PGUs Type 2 and storage systems				P	
MST-BIE5-2500							
7.4							
Condition						Measured value	
Item	No.	Parameter	Phase ref.	Time ref.	unit		
General Info.	0	Test number	--	--	--	7,4	
	1	Date	--	--	yyyy.mm.dd	2025/9/13	
	2	Time (start of test)	--	--	hh:mm:ss.f	14:32:25	
	3	Fault type (phase)	--	--	--	D1	
	4	Setting voltage depth	Line to line	--	--	p.u.	1,15
	5	Setting dip duration		--	--	--	60000
	6	Point of fault entry	Total	--	--	ms	16793
	7	Point of fault clearance	Total	--	--	ms	76800
	8	Fault duration in empty load test	Total	--	--	ms	60007
	9	Voltage depth/height in empty load test	Total (Phase 1)	t1+100ms to t2 and t1-10s to t1	p.u.	1,038	
	10		Total (Phase 2)			1,145	
	11		Total (Phase 3)			1,039	
12	Positive sequence		1,070				
Before dip <t1	13	Voltage	Phase 1	t1-10s to t1	p.u.	0,999	
	14		Phase 2			0,998	
	15		Phase 3			0,999	
	16	Current	Pos.	t1-500ms to t1-100ms	p.u.	0,299	
	17	Active power	Total	t1-10s to t1	p.u.	0,299	
	18		Pos.			0,299	
	19	Reactive power	Total	t1-10s to t1	p.u.	0,014	
	20		Pos.			0,001	
21	Cosφ	Total	t1-10s to t1	--	0,999		
During dip t1 to t2	22	Voltage	Phase 1	t1+100ms to t2-20ms	p.u.	1,038	
	23		Phase 2			1,145	
	24		Phase 3			1,039	
	25	Line current	Phase 1	t1+60ms	p.u.	--	
	26		Phase 2			--	
	27		Phase 3			0,291	
	28	Line current	Phase 1	t1+100ms	p.u.	--	
	29		Phase 2			--	
	30		Phase 3			0,287	
	31	Active power	Total	t1+100ms to t2-20ms	p.u.	0,298	
	32		Pos.			0,298	
After dip > t2	33	Voltage	Phase 1	t2+3s to t2+10s	p.u.	0,999	
	34		Phase 2			0,998	
	35		Phase 3			0,999	
	36	Active power	Total	t2+3s to t2+10s	p.u.	0,299	
	37		Pos.			0,299	
	38	Active power rising time	Total	--	s	0,048	
	39	Reactive power	Total	t2+3s to t2+10s	p.u.	0,014	
	40		Pos.			0,001	
	41	Reactive power rising time	total	--	s	--	
	42	PGU does not disconnect from grid till 60s after fault	--	t2 to t2+60s	Yes / No	Yes	

5.8.3

For PGUs Type 2 and storage systems



P

MST-BIE5-2500



5.8.3 For PGUs Type 2 and storage systems P

MST-BIE5-2500



## **Annex 2 – Pictures of the unit**

**Enclosure front view**



**Enclosure rear side view**



Enclosure side view-1



Enclosure side view-2



**Enclosure TOP view**



**Enclosure bottom view**



**Enclosure internal view**



## **Annex 3 – Test equipment list**

Date(s) of performance of tests: 2025-09-03 to 2025-11-23

Equipment	Internal No.	Manufacturer	Type	Serial No.	Next Calibration
AC source	HC-ENG-030	KEWELL	KAC-45-345-33	6018888220300485	Monitored by Power Analyzer
DC source	HC-ENG-043	KEWELL	S7000-21K-2000-0040	6018888221003326	
RLC load	HC-ENG-005	Qunling Energy Resources	ACLT-3803H	93H006289	
RCD Load	HC-ENG-059	LYNS-Tci	IMAX5345-45KVA	20230415013	
Power analyser	HC-ENG-029	DEWETRON	TRION-1820-POWER	ACLT-3803H	2026-03-20
Current sensor	HC-ENG-029-001	SIGNALTEC	CT 400	1221300587	2026-03-20
	HC-ENG-029-002	SIGNALTEC	CT 400	1221300588	2026-03-20
	HC-ENG-029-003	SIGNALTEC	CT 400	1221300595	2026-03-20
	HC-ENG-029-004	SIGNALTEC	CT 400	1221300596	2026-03-20
Humidity & Temperature recorder	HC-ENG-002	Jiangsu Jingchuang Electric Co., Ltd.	GSP-8A	CMA215000031	2026-03-23

---End of test report---